



C&K Industrial Services, Inc.
5617 E. Schaaf Rd.
Independence, Ohio 44131
216-642-0055


PACP Report with Pipe Run and Incident Snapshots

Surveyed by: Mike Head		Certificate number: 123456		Owner: C & K Industrial Service, Inc		Customer:		Drainage area:		P/O number:		Sheet number:	
Pipe segment ref.: SNG12				Start date/time: 20220915 13:40		Street: ERIE ST				City: MASSILLON			
Location details:				Upstream MH No: 1288 SR21				Rim to invert:		Grade to invert:		Rim to grade:	
Pipe use: SS		Direction: D		Flow control:		Downstream MH No: 1297 SR21				Rim to invert:		Grade to invert:	
Height: 78 in.		Width: 60 in.		Shape: T		Material: RCP		Lining method:		Pipe joint length:		Total length: 37.000 ft.	
Length surveyed: 37.000 ft.		Purpose:		Sewer category:		Media label:		Pre-cleaning: N		Date cleaned:		Weather: 1	
Project name: CITY OF MASSILLON				Additional info:									


Grade	Structural:					O&M:					Overall:	
	Amount of Defects	Segment Grade	Pipe Rating	Quick Rating	Pipe Rating Index	Amount of Defects	Segment Grade	Pipe Rating	Quick Rating	Pipe Rating Index	Pipe Rating	Pipe Rating Index
1	0	0	0	0000	0.0	0	0	10	2500	2.0	10	2.0
2	0	0				5	10					
3	0	0				0	0					
4	0	0				0	0					
5	0	0				0	0					

Observations

Distance	Video Ref.	PACP Code	Continuous	S/M/L	Value Inches (mm)		%	Joint	Circumferential Location		Rating	Image Ref.	Remarks
					1st	2nd			At/From	To			
0.0 ft.		AOC						☐	/			CITY OF MASSILLON-AOC '1288 SR21'-AMH '1297 SR21'-AOC at 0.0 ft.JPG	1288 SR21
0.0 ft.		MWL					20	☐	/			CITY OF MASSILLON-AOC '1288 SR21'-AMH '1297 SR21'-MWL at 0.0 ft.JPG	
9.1 ft.	00:01:09	DSGV	S01				10	☐	5 / 7		2	CITY OF MASSILLON-AOC '1288 SR21'-AMH '1297 SR21'-DSGV at 9.1 ft.JPG	
32.2 ft.	00:03:06	DSGV	F01				10	☐	5 / 7		2	CITY OF MASSILLON-AOC '1288 SR21'-AMH '1297 SR21'-DSGV at 32.2 ft.JPG	
32.2 ft.	00:02:20	MSC			60.000			☐	/			CITY OF MASSILLON-AOC '1288 SR21'-AMH '1297 SR21'-MSC at 32.2 ft.JPG	TRAP TO CIRCLE
37.0 ft.	00:04:44	AMH						☐	/			CITY OF MASSILLON-AOC '1288 SR21'-AMH '1297 SR21'-AMH at 37.0 ft.JPG	1297 SR21



Photos



At: 0 ft. AOC - Access Point Special Chamber
Joint: No 1288 SR21



At: 0 ft. MWL - Miscellaneous Water Level
Joint: No 20 %




At: 9.1 ft. 5/7 DSGV - Deposits Settled Gravel
Joint: No 10 %



At: 32.2 ft. 5/7 DSGV - Deposits Settled Gravel
Joint: No 10 %

Photos



At: 32.2 ft. MSC - Miscellaneous Shape/Size Change
Joint: No TRAP TO CIRCLE



At: 37 ft. AMH - Manhole
Joint: No 1297 SR21