

STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

# Permit for Sewer Connection

Permit No. 48266

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation therefore, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

**The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.**

Address: 8452 WOODED POINT NW  
Lot 22  
Parcel 16-27766  
Subdivision SCENIC RIDGE  
Township NE 29 JACKSON

Area charge \$2,000.00  
Local charge \$.00 (if app.)  
Permit fee \$ 50.00  
Connection charge \$2,050.00 (Total)  
Installation  
Cash Y 1/6/2016

Usage: SINGLE FAMILY RES 1 HOUSE/6

Date of issuance: 1/6/2016  
(Expires in 365 days)

Owner of property described:

REA BLDG CORP,  
8230 LUTZ AVE NW  
MASSILLON OH 44646

By: [Signature]  
Licensed Drain Layer MALAMITE EXCAVATING, INC.  
TJM

Issued by:

County Sanitary Engineer: MICHAEL S. ARMOGIDA

Notes: FLOWLINE IS 19.86 FEET ABOVE DS MH#16-1725 FLOWLINE

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of the City of MASSILLON

Sewer District 16  
Property is located on the E side (direction)  
of RANIER St.  
between AT WOODED POINT St.  
and St.  
Main sewer is in RANIER  
Y, branch is 88 feet  
(direction) SOUTH  
of MH No. 16-1725  
at WOODED POINT

LATERAL SEWER:  
House conn. is 58.00 feet long and  
end of branch is 88 feet  
(direction) SOUTH  
of MH No. 16-1725  
and is approx. 11.0 feet deep.  
service sewer: 6 inch PVC pipe  
Sewer Book No. 5 Page 561 562  
Wye Book No. 10 Page 343



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

# Permit for Sewer Connection

Permit No. 48267

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation therefore, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

**The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.**

Address: 7374 MONTELLA NW  
Lot 416  
Parcel 10006229  
Subdivision EMERALD ESTATES #10  
Township NE 07 JACKSON

Area charge \$2,000.00  
Local charge \$.00 (if app.)  
Permit fee \$ 50.00  
Connection charge \$2,050.00 (Total)  
Installation  
Cash Y 1/12/2016

Usage: SINGLE FAMILY RES 1 HOUSE/S

Date of issuance: 1/12/2016  
(Expires in 365 days)

Owner of property described:  
PULTE HOMES OF OHIO LLC  
11590 N MERIDIAN ST STE 5  
CARMEL, IN 46032

By: X Andrew Schneider  
Licensed Drain Layer SCHNEIDER ELECTRIC & PLUMBING INC

Issued by: RLH

County Sanitary Engineer: MICHAEL S. ARMOGIDA

Notes: 50' SOUTH & 30' WEST OF MH 16-1491

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of the City of MASSILLON

Sewer District 16  
Property is located on the S side (direction)  
of MONTELLA St.  
between AT SOUTH CUL-DE-SAC  
and St.  
Main sewer is in MONTELLA  
Y, branch is STUB feet  
(direction)  
of MH No. 16-1491  
at SOUTH MONTELLA CUL-DE-SAC  
LATERAL SEWER:  
House conn. is 50.00 feet long and  
end of branch is 30 feet  
(direction) W  
of MH No. 16-1491  
and is approx. 10.0 feet deep.  
service sewer: 6 inch PVC pipe  
Sewer Book No. 5 Page 595  
Wye Book No. 10 Page 375



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

# Permit for Sewer Connection

Permit No. 48270

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation therefore, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

**The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.**

Address: 7179 GALENA NW  
Lot 381  
Parcel 10004856  
Subdivision EMERALD ESTATES #9  
Township SW 7 JACKSON

Area charge \$2,000.00  
Local charge \$.00 (if app.)  
Permit fee \$ 50.00  
Connection charge \$2,050.00 (Total)  
Installation  
Cash Y 1/13/2016

Usage: SINGLE FAMILY RES 1 HOUSE/S

Date of issuance: 1/13/2016  
(Expires in 365 days)

Owner of property described:

RYAN HOMES  
6770 SNOWVILLE RD  
BRECKSVILLE, OH 44141

By: [Signature]  
Licensed Drain Layer CARR EXCAVATING LLC

Issued by: ALH

County Sanitary Engineer: MICHAEL S. ARMOGIDA

Sewer District 16  
Property is located on the S side (direction)  
of GALENA St.  
between AT EMERALD GLEN St.  
and St.  
Main sewer is in GALENA  
Y, branch is 28 feet  
(direction) WEST  
of MH No. 16-2047  
at EMERALD GLEN

LATERAL SEWER:  
House conn. is 35.00 feet long and  
end of branch is 28 feet  
(direction) WEST  
of MH No. 16-2047  
and is approx. 9.0 feet deep.  
service sewer: 6 inch PVC pipe  
Sewer Book No. 5 Page 654  
Wye Book No. 10 Page 347

Notes: FLOWLINE IS 13.68 FEET ABOVE DOWNSTREAM MH #16-2047 FLOWLINE

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of the City of MASSILLON

DISTRIBUTION OF COPIES: Green (County)

Pink (City)

Yellow (Contractor)

White (Inspection Dept.)



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

# Permit for Sewer Connection

Permit No. 48275

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation therefore, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

**The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.**

Address: 6997 EMERALD COVE NW

Lot 327

Parcel 16-29864

Subdivision EMERALD ESTATES #7

Township SW 7 JACKSON

Area charge \$2,000.00

Local charge \$.00 (if app.)

Permit fee \$ 50.00

Connection charge \$2,050.00 (Total)

Installation

Cash Y 1/26/2016

Usage: SINGLE FAMILY RES 1 HOUSE/S

Date of issuance: 1/26/2016

(Expires in 365 days)

Owner of property described:

SMITH HOMES,  
6360 PROMLER AVE  
N CANTON, OH 44720

By: [Signature] Licensed Drain Layer

BACHTEL EXCAVATING, INC.

Issued by: [Signature]

County Sanitary Engineer: MICHAEL S. ARMOGIDA

Notes: FLOWLINE IS 16.97' ABOVE DOWNSTREAM MH#16-1851 FLOWLINE -15' STACK

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of the City of MASSILLON

Sewer District 16

Property is located on the W side (direction)

of EMERALD COVE St.

between EMERALD BLUFF St.

and EMERALD BAY St.

Main sewer is in EMERALD COVE

Y, branch is 115 feet

(direction) NORTH

of MH No. 16-1851

at 1ST NORTH OF EMERALD BLUFF

LATERAL SEWER:

House conn. is 18.00 feet long and

end of branch is 115 feet

(direction) NORTH

of MH No. 16-1851

and is approx. 12.0 feet deep.

service sewer: 6 inch PVC pipe

Sewer Book No. 5 Page 605

Wye Book No. 10 Page 315



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

# Permit for Sewer Connection

Permit No. **48273**

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation therefore, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

**The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.**

Address: 7210 GALENA NW  
Lot 369  
Parcel 10004875  
Subdivision EMERALD ESTATES #9  
Township SW 7 JACKSON  
  
Area charge \$2,000.00  
Local charge \$ .00 (if app.)  
Permit fee \$ 50.00  
Connection charge \$2,050.00 (Total)  
Installation Cash Y 1/21/2016

Usage: SINGLE FAMILY RES 1 HOUSE/S

Date of issuance: 1/21/2016  
(Expires in 365 days)

Owner of property described:

NVR/RYAN HOMES,  
6770 SNOWVILLE RD  
BRECKSVILLE, OH 44141

By: TJM  
Licensed Drain Layer CARR EXCAVATING LLC

Issued by: TJM

County Sanitary Engineer: MICHAEL S. ARMOGIDA

Notes: FLOWLINE IS 5.45 FEET ABOVE DOWNSTREAM MH #16-2046 FLOWLINE

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of the City of MASSTILLON

Sewer District 16  
Property is located on the N side (direction)  
of GALENA St.  
between EMERALD GLEN St.  
and DIAMOND RIDGE St.  
Main sewer is in GALENA  
Y, branch is 61 feet  
(direction) WEST  
of MH No. 16-2046  
at 1ST MH WEST OF EMERALD GLEN  
  
LATERAL SEWER:  
House conn. is 36.00 feet long and  
end of branch is 61 feet  
(direction) WEST  
of MH No. 16-2046  
and is approx. 8.5 feet deep.  
service sewer: 6 inch PVC pipe  
Sewer Book No. 5 Page 654  
Wye Book No. 10 Page 347



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

# Permit for Sewer Connection

Permit No. **48277**

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation therefore, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

**The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.**

Address: 4824 RANIER NW

Lot 6

Parcel 16-27750

Subdivision SCENIC RIDGE

Township NE 29 JACKSON

Area charge \$2,000.00

Local charge \$ .00 (if app.)

Permit fee \$ 50.00

Connection charge \$2,050.00 (Total)

Installation Cash Y 1/27/2016

Usage: SINGLE FAMILY RES 1 HOUSE/S

Date of issuance: 1/27/2016

(Expires in 365 days)

Owner of property described:

WAGLER ENTERPRISES  
3700 TABS DR  
UNIONTOWN, OH 44685

By: B. B. A.

Licensed Drain Layer BONTRAGER EXCAVATING INC.

Issued by: RLH

County Sanitary Engineer: MICHAEL S. ARMOGIDA

Notes: FLOWLINE IS 0.67 FEET ABOVE DS MH#16-1731 FLOWLINE

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of the City of MASSILLON

Sewer District 16  
Property is located on the W side (direction)

of RANIER St.

between AT TURN AROUND St.

and  St.

Main sewer is in W. R/W OF RANIER

Y, branch is 20 feet

(direction) SOUTH

of MH No. 16-1731

at TURN AROUND

LATERAL SEWER:  
House conn. is 13.00 feet long and

end of branch is 20 feet

(direction) SOUTH

of MH No. 16-1731

and is approx. 12.0 feet deep.

service sewer: 6 inch PVC pipe

Sewer Book No. 5 Page 550 560

Wye Book No. 10 Page 343



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

# Permit for Sewer Connection

Permit No. 48278

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation therefore, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.

Address: 8435 WOODED POINT NW

Lot 18

Parcel 16-27762

Subdivision SCENIC RIDGE

Township NE 29 JACKSON

Area charge \$2,000.00

Local charge \$.00 (if app.)

Permit fee \$ 50.00

Connection charge \$2,050.00 (Total)

Installation

Cash Y 1/27/2016

Usage: SINGLE FAMILY RES 1 HOUSE/S

Date of issuance: 1/27/2016

(Expires in 365 days)

Owner of property described:

WAGLER ENTERPRISES

3700 TABS DR

UNIONTOWN, OH 44685

By: B. B. B.

Licensed Drain Layer BONTRAGER EXCAVATING INC.

Issued by: RLH

County Sanitary Engineer: MICHAEL S. ARMOGIDA

Notes: FLOWLINE IS 2.26 FEET ABOVE DS MH#16-1723 FLOWLINE

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of the City of MASSILLON

Sewer District 16

Property is located on the W side (direction)

of WOODED POINT St.

between AT CUL-DE-SAC St.

and St.

Main sewer is in EASEMENT

Y, branch is 109 feet

(direction) SOUTH

of MH No. 16-1723

at 1ST NORTH OF CUL-DE-SAC IN EA

LATERAL SEWER:

House conn. is 10.00 feet long and

end of branch is 109 feet

(direction) SOUTH

of MH No. 16-1723

and is approx. 10.0 feet deep.

service sewer: 6 inch PVC pipe

Sewer Book No. 5 Page 562

Wye Book No. 10 Page 344



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

# Permit for Sewer Connection

Permit No. 48279

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation therefore, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.

Address: 3850 OLD HICKORY NW  
Lot 9  
Parcel 10006688  
Subdivision GLENDALE VILLAGE #1  
Township SW 26 JACKSON

Area charge \$2,000.00  
Local charge \$.00 (if app.)  
Permit fee \$ 50.00  
Connection charge \$2,050.00 (Total)  
Installation  
Cash Y 1/29/2016

Usage: SINGLE FAMILY RES 1 HOUSE/S

Date of issuance: 1/29/2016

(Expires in 365 days)

Owner of property described:

REGAL CONSTR.,  
7056 MEARS GATE NW  
N. CANTON, OH 44720

By: [Signature]  
Licensed Drain Layer MALAVETE EXCAVATING, INC.

Issued by: TJM

County Sanitary Engineer:

MICHAEL S. ARMOGIDA

Notes: FLOWLINE IS 7.35' ABOVE DOWNSTREAM MH 25-1129 FLOWLINE

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of the City of

Sewer District 25  
Property is located on the E side (direction)  
of OLD HICKORY St.  
between MARZILLI St.  
and END OF ST St.  
Main sewer is in OLD HICKORY  
Y, branch is 156 feet  
(direction) NORTH  
of MH No. 25-1129  
at 2ND NORTH OF MARZILLI  
LATERAL SEWER:  
House conn. is 17.00 feet long and  
end of branch is 156 feet  
(direction) NORTH  
of MH No. 25-1129  
and is approx. 8.5 feet deep.  
service sewer: 6 inch PVC pipe  
Sewer Book No. 8 Page 252  
Wye Book No. 8 Page 350



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

# Permit for Sewer Connection

Permit No. **48284**

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation therefore, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

**The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.**

Address: 77231 GALENA NW  
Lot 385  
Parcel 10004852  
Subdivision EMERALD ESTATES #9  
Township SW 7 JACKSON  
Area charge \$2,000.00  
Local charge 0.00 (if app.)  
Permit fee \$ 50.00  
Connection charge \$2,050.00 (Total)  
Installation  
Cash CK #8235

Usage: SINGLE FAMILY RES 1 HOUSE/S

Date of issuance: 02/01/16  
(Expires in 365 days)

Owner of property described:  
PATRICK LONG HOMES  
3333 MASSILLON BL STE 10  
AKRON OH 44312

By: J. TROIKE  
Licensed Drain Layer BONTRAGER INC.

Issued by: TJM  
County Sanitary Engineer: MICHAEL S. ARMOGIDA

Notes: FLOWLINE 15.36' ABOVE D.S. MAIN #16-2046 FLOWLINE

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of the City of

Sewer District 16  
Property is located on the S side (direction)  
of GALENA St.  
between EMERALD GLEN St.  
and DIAMOND RIDGE St.  
Main sewer is in GALENA  
Y, branch is 190 feet  
(direction) WEST W  
of MH No. 16-2046  
at 1ST W OF EMERALD GLEN  
LATERAL SEWER:  
House conn. is 45 feet long and  
end of branch is 190 feet  
(direction) WEST W  
of MH No. 16-2046  
and is approx. 9.5 feet deep.  
service sewer: 6 inch PVC pipe  
Sewer Book No. 5 Page 654  
Wye Book No. 10 Page 347



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

# Permit for Sewer Connection

Permit No. 48290

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation therefore, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

**The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.**

Address: 5864 WELLINGTON NW

Lot 120

Parcel 16-09455

Subdivision JACKSON MEADOWS 3

Township SW 16 JACKSON

Area charge \$2,000.00

Local charge \$ .00 (if app.)

Permit fee \$ 50.00

Connection charge \$2,050.00 (Total)

Installation

Cash Y 2/8/2016

Usage: SINGLE FAMILY RES 1 HOUSE/S

Date of issuance: 2/8/2016

(Expires in 365 days)

Owner of property described:

BURNS, SIDNEY A  
5864 WELLINGTON CIR NW  
MASSILLON, OHIO 44646

By: [Signature]

Licensed Drain Layer UNDERGROUND SERVICES INC.

Issued by: RLH

County Sanitary Engineer: MICHAEL S. ARMOGIDA

Notes: FLOWLINE IS 0.51' ABOVE DS MH 16-1989 FL - EOL = 26' NORTH & 51' EAST

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of the City of MASSILLON

Sewer District 16

Property is located on the NE side (direction)

of WELLINGTON St.

between CRANFORD St.

and CUL DE SAC St.

Main sewer is in WELLINGTON

Y, branch is STUB feet

(direction) IN

of MH No. 16-1989

at CUL DE SAC

LATERAL SEWER:

House conn. is 60.00 feet long and

end of branch is 26 feet

(direction) NORTH

of MH No. 16-1989

and is approx. 9.0 feet deep.

service sewer: 6 inch PVC pipe

Sewer Book No. Page

Wye Book No. 10 Page 182



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

# Permit for Sewer Connection

Permit No. 48292

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation therefore, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

**The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.**

Address: 7850 GREENWICH NW  
Lot 9  
Parcel 10001942  
Subdivision GREENWICH PLACE  
Township SW 16 JACKSON  
Area charge \$2,000.00  
Local charge \$.00 (if app.)  
Permit fee \$ 50.00  
Connection charge \$2,050.00 (Total)  
Installation  
Cash Y 2/9/2016  
Usage: SINGLE FAMILY RES 1 HOUSE/S  
Date of issuance: 2/9/2016  
(Expires in 365 days)  
Owner of property described:  
MEMMER HOMES  
7265 PORTAGE ST.  
MASSILLON, OH 44646  
By: *East Malavite*  
Licensed Drain Layer MALAVITE EXCAVATING, INC.  
Issued by: RLH  
County Sanitary Engineer: MICHAEL S. ARMOGIDA

Sewer District 16  
Property is located on the E side (direction)  
of GREENWICH St.  
between ARLINGTON St.  
and CUL DE SAC St.  
Main sewer is in GREENWICH  
Y, branch is 91 feet  
(direction) NORTH  
of MH No. 16-2003  
at 3RD NORTH OF  
ARLINGTON RD ENTR  
LATERAL SEWER:  
House conn. is 63.00 feet long and  
end of branch is 91 feet  
(direction) NORTH  
of MH No. 16-2003  
and is approx. 7.5 feet deep.  
service sewer: 6 inch PVC pipe  
Sewer Book No. 5 Page 644  
Wye Book No. 10 Page 185

Notes: FLOWLINE IS 2.41' ABOVE DOWNSTREAM MH 16-2003 FLOWLINE

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of the City of MASSILLON

DISTRIBUTION OF COPIES: Green (County)

Pink (City)

Yellow (Contractor)

White (Inspection Dept.)



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

# Permit for Sewer Connection

Permit No. **48307**

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation therefore, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.

Address: 7306 MONTELLA NW

Lot 413

Parcel 10006225

Subdivision EMERALD ESTATES #10

Township NE 07 JACKSON

Area charge \$2,000.00

Local charge \$ .00 (if app.)

Permit fee \$ 50.00

Connection charge \$2,050.00 (Total)

Installation Cash Y 3/8/2016

Usage: SINGLE FAMILY RES 1 HOUSE/S

Date of issuance: 3/8/2016

(Expires in 365 days)

Owner of property described:

PULTE HOMES OF OH,  
11590 N MERIDIAN ST STE 5  
CARMEL, IN 46032

By: A. Ronald Mott

Licensed Drain Layer SCHNEIDER ELECTRIC & PLUMBING INC

Issued by: TJM

County Sanitary Engineer: MICHAEL S. ARMOGIDA

Notes:

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of the City of MASSILLON

Sewer District 16

Property is located on the S side (direction)

of MONTELLA St.

between WEST END OF MONTELLA

and S MONTELLA CUL-DE-SAC

Main sewer is in R/W N SIDE OF MONTELLA

Y, branch is STUB feet

(direction)

of MH No. 16-1463

at 2ND WEST OF S MONTELLA CUL-DE-SAC

LATERAL SEWER:

House conn. is 52.00 feet long and

end of branch is 0 feet

(direction)

of MH No. 16-1463

and is approx. 10.0 feet deep.

service sewer: 6 inch PVC pipe

Sewer Book No. 5 Page 596

Wye Book No. 10 Page 376



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

# Permit for Sewer Connection

Permit No. 48308

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation therefore, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.

Address: 7328 MONTELLA NW  
Lot 414  
Parcel 10006230  
Subdivision EMERALD ESTATES #10  
Township NE 07 JACKSON

Area charge \$2,000.00  
Local charge \$.00 (if app.)  
Permit fee \$ 50.00  
Connection charge \$2,050.00 (Total)  
Installation  
Cash Y 3/8/2016

Usage: SINGLE FAMILY RES 1 HOUSE/S

Date of issuance: 3/8/2016  
(Expires in 365 days)

Owner of property described:  
PULTE HOMES OF OH,  
11590 N MERIDIAN ST STE 5  
CARMEL, IN 46032

By: [Signature]  
Licensed Drain Layer SCHNEIDER ELECTRIC & PLUMBING INC

Issued by: TJM

County Sanitary Engineer: MICHAEL S. ARMOGIDA

## Notes:

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of the City of MASSILLON

Sewer District 16  
Property is located on the S side (direction)  
of MONTELLA St.  
between WEST END MONTELLA St.  
and S MONTELLA CUL-DE-SAC

Main sewer is in R/W N SIDE MONTELLA  
Y, branch is 149 feet  
(direction) E  
of MH No. 16- 1463  
at 2ND EAST OF S MONTELLA CUL- D

LATERAL SEWER:  
House conn. is 45.00 feet long and  
end of branch is 149 feet  
(direction) E  
of MH No. 16- 1463  
and is approx. 10.0 feet deep.

service sewer: 6 inch PVC pipe  
Sewer Book No. 5 Page 596  
Wye Book No. 10 Page 376



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

# Permit for Sewer Connection

Permit No. 48311

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation therefore, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.

Address: 9543 MONT CLAIR NW

Lot 3

Parcel 16-27543

Subdivision MONT CLAIR PROVINCE AT LORD'S LAKE

Township NE 18 JACKSON

Area charge \$2,000.00

Local charge \$.00 (if app.)

Permit fee \$ 50.00

Connection charge \$2,050.00 (Total)

Installation

Cash Y 3/11/2016

Usage:

SINGLE FAMILY RES 1 HOUSE/S

Date of issuance: 3/11/2016

(Expires in 365 days)

Owner of property described:

OLD WORLD CLASSICS,  
7056 MEARS GATE NW  
N CANTON, OH 44720

By:

Licensed Drain Layer BONTRAGER EXCAVATING INC.

Issued by:

TJM

County Sanitary Engineer: MICHAEL S. ARMOGIDA

Notes: FLOWLINE IS 1.75 FEET ABOVE DS MH#16-1701 FLOWLINE

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of the City of MASSILLON

Sewer District 16

Property is located on the N side (direction)

of MONT CLAIR St.

between HIGHMILL St.

and PROVINCE St.

Main sewer is in MONT CLAIR

Y, branch is 143 feet

(direction) EAST

of MH No. 1701

at 1ST EAST OF HIGH MILL

LATERAL SEWER:

House conn. is 14.00 feet long and

end of branch is 143 feet

(direction) EAST

of MH No. 1701

and is approx. 10.0 feet deep.

service sewer: 6 inch PVC pipe

Sewer Book No. 5 Page 556

Wye Book No. 10 Page 124



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

# Permit for Sewer Connection

Permit No. 48317

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation therefore, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.

Address: 7123 MOSSY OAKS NW

Lot 51

Parcel 16-29776

Subdivision HUNTER'S CHASE #2

Township SE 7 JACKSON

Area charge \$2,000.00

Local charge \$.00 (if app.)

Permit fee \$ 50.00

Connection charge \$2,050.00 (Total)

Installation

Cash Y 3/23/2016

Usage: SINGLE FAMILY RES 1 HOUSE/S

Date of issuance: 3/23/2016

(Expires in 365 days)

Owner of property described:

REA BLDG CORP,  
8230 LUTZ AVE NW  
MASSILLON, OH 44646

By: *Garret Malawite*  
Licensed Drain Layer MALAWITE EXCAVATING, INC.

Issued by: TJM

County Sanitary Engineer: MICHAEL S. ARMOGIDA

Notes: FLOWLINE IS 3.93 FEET ABOVE DS MH#16-1880 FLOWLINE

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of the City of MASSILLON

Sewer District 16

Property is located on the W side (direction)

of MOSSY OAKS St.

between BROADLAND St.

and HUNTERS CHASE St.

Main sewer is in MOSSY OAKS

Y, branch is 80 feet

(direction) NORTH

of MH No. 16-1880

at 1ST NORTH OF BROADLAND

LATERAL SEWER:

House conn. is 27.00 feet long and

end of branch is 80 feet

(direction) NORTH

of MH No. 16-1880

and is approx. 9.0 feet deep.

service sewer: 6 inch PVC pipe

Sewer Book No. 5 Page 612

Wye Book No. 10 Page 384



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

# Permit for Sewer Connection

Permit No. **48328**

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation therefore, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.

Address: 3435 VINEYARD NW  
Lot 2  
Parcel 16-27009  
Subdivision PROVIDENCE  
Township NE 33 JACKSON  
  
Area charge \$2,000.00  
Local charge \$ .00 (if app.)  
Permit fee \$ 50.00  
Connection charge \$2,050.00 (Total)  
Installation Cash Y 4/7/2016

Usage: SINGLE FAMILY RES 1 HOUSE/S

Date of issuance: 4/7/2016

(Expires in 365 days)

Owner of property described:

COLLIER CONSTR,  
650 KAYMONT AVE SE  
MASSILLON, OH 44646

By: [Signature]  
Licensed Drain Layer ALBORN EXCAVATING

Issued by: TJM

County Sanitary Engineer: MICHAEL S. ARMOGIDA

Notes: FLOWLINE IS 8.84 FEET ABOVE DOWNSTREAM MH#1369 FLOWLINE

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of the City of MASSILLON

Sewer District 16  
  
Property is located on the W side (direction)  
of VINEYARD St.  
between HILLS & DALES St.  
and CHILMARK St.  
  
Main sewer is in VINEYARD  
  
Y, branch is 205 feet  
(direction) NORTH  
of MH No. 1369  
at 2ND SOUTH OF  
  
CHI  
LATERAL SEWER:  
House conn. is 15.00 feet long and  
end of branch is 205 feet  
(direction) NORTH  
of MH No. 1369  
and is approx. 11.0 feet deep.  
service sewer: 6 inch PVC pipe  
Sewer Book No. 5 Page 4675  
Wye Book No. 10 Page 316

DISTRIBUTION OF COPIES: Green (County)

Pink (City)

Yellow (Contractor)

White (Inspection Dept.)



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

# Permit for Sewer Connection

Permit No. 48319

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation therefore, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.

Address: 8011 HILLS AND DALES NE

Lot

Parcel 1618966

Subdivision

Township SW 33 JACKSON

Area charge \$24,000.00

Local charge \$.00 (if app.)

Permit fee \$ 50.00

Connection charge \$24,050.00 (Total)

Installation

Cash Y 3/25/2016

Usage: COMMERCIAL MULTI-UNIT 0 UNITS

Date of issuance: 3/25/2016

(Expires in 365 days)

Owner of property described:

CAMPBELL OIL CO  
7977 HILLS AND DALES  
MASSILLON, OH 44646

By: x [Signature]

Licensed Drain Layer TISSOT EXCAVATING, INC.

Issued by: RLH J. MILLER & SON

County Sanitary Engineer: MICHAEL S. ARMOGIDA

Notes: SEE PLANS AND INSPECTOR FOR LOCATION AND METHODS PREV PER # 22939

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of the City of MASSILLON

Sewer District 16

Property is located on the N side (direction)

of HILLS AND DALES St.

between WALES St.

and AARONWOOD St.

Main sewer is in EASEMENT

Y, branch is TAP feet

(direction) NORTH

of MH No. 16-417

at 2ND EAST OF WALES IN EASEMENT

LATERAL SEWER:

House conn. is feet long and

end of branch is feet

(direction) NORTH

of MH No. 16-417

and is approx. feet deep.

service sewer: 6 inch PVC pipe

Sewer Book No. 5 Page 182

Wye Book No. 5 Page 230



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

# Permit for Sewer Connection

Permit No. 48332

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation therefore, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.

Address: 7710 CRANFORD NW

Lot 51

Parcel 16-09384

Subdivision JACKSON MEADOWS 2

Township SW 16 JACKSON

Area charge \$2,000.00

Local charge \$.00 (if app.)

Permit fee \$ 50.00

Connection charge \$50.00 (Total)

Installation

Cash Y 4/8/2016

Usage: SINGLE FAMILY RES 1 HOUSE/S

Date of issuance: 4/8/2016

(Expires in 365 days)

Owner of property described:  
CONANT, VINCENT V & LOU A  
7710 CRANFORD ST NW  
MASSILLON, OHIO 44646

By: [Signature]  
Licensed Drain Layer

Issued by: TJM

County Sanitary Engineer: MICHAEL S. ARMOGIDA

Notes: FL IS 7.45' ABV DS MH 1981 FL; 4.79' STACK; REISSUED-PREV PERMIT #47649

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of the City of MASSILLON

Sewer District 16

Property is located on the S side (direction)

of CRANFORD St.

between CRANFORD St.

and VANTAGE HILL St.

Main sewer is in CRANFORD

Y, branch is 315.5 feet

(direction) WEST

of MH No. 16-1981

at 2ND SOUTH OF CHERYL LANE

LATERAL SEWER:  
House conn. is 26.00 feet long and

end of branch is 315.5 feet

(direction) WEST

of MH No. 16-1981

and is approx. 12.0 feet deep.

service sewer: 6 inch PVC pipe

Sewer Book No. Page

Wye Book No. 10 Page 183



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

# Permit for Sewer Connection

Permit No. **48334**

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation therefore, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.

Address: 7358 KNIGHT NW  
Lot 60  
Parcel 16-03031  
Subdivision CLOVER DALE #2  
Township SE 33 JACKSON

Area charge \$600.00  
Local charge \$ .00 (if app.)  
Permit fee \$ 50.00  
Connection charge \$650.00 (Total)  
Installation Y Cash 4/11/2016

Usage: SINGLE FAMILY RES 1 HOUSE/S

Date of issuance: 4/11/2016  
(Expires in 365 days)

Owner of property described:

MILLER, KEVIN P  
7358 KNIGHT ST NW  
MASSILLON, OHIO 44646

By: [Signature]  
Licensed Drain Layer UNDERGROUND SERVICES INC.

Issued by: TJM

County Sanitary Engineer: MICHAEL S. ARMOGIDA

Notes: FL IS 2.97' ABV DS MH 1088 FL; REISSUED - ORIG PERMIT #44847

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of the City of MASSILLON

Sewer District 25  
Property is located on the S side (direction)  
of KNIGHT St.  
between AT RADCLIFF St.  
and  St.

Main sewer is in KNIGHT  
Y, branch is 121 feet  
(direction) WEST  
of MH No. 25-1088  
at 2ND EAST OF KIPLING

LATERAL SEWER:  
House conn. is 21.00 feet long and  
end of branch is 121 feet  
(direction) WEST  
of MH No. 25-1088  
and is approx. 8.0 feet deep.

service sewer: 6 inch PVC pipe  
Sewer Book No. 5 8 Page 241  
Wye Book No. 8 Page 336



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

# Permit for Sewer Connection

Permit No. 48335

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation therefore, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.

Address: 1138-40 SINGING BROOK NW

Lot 6

Parcel 43-12060

Subdivision BROOKSIDE ACRES

Township SW 3 PERRY

Area charge \$3,340.00

Local charge \$10,111.62 (if app.)

Permit fee \$ 50.00

Connection charge \$13,501.62 (Total)

Installation

Cash Y 4/13/2016

Usage:

0 Multiple Use

Date of issuance: 4/13/2016

(Expires in 365 days)

Owner of property described:

HINKLE, HUSTON AND NICOLE

722 MALLARD CIR NW

MASSILLON, OH 44646

By:

Licensed Drain Layer MALAVITE EXCAVATING, INC.

Issued by: RLH

County Sanitary Engineer: MICHAEL S. ARMOGIDA

Notes: FULL LOCAL CHARGE; COUNTY INSTALL 1.5" SDR 26 GRINDER PUMP

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of the City of MASSILLON

Sewer District 25

Property is located on the E side (direction)

of SINGING BROOK St.

between AT 12TH St.

and St.

Main sewer is in 12TH

Y, branch is feet

(direction)

of MH No.

at

LATERAL SEWER:

House conn. is feet long and

end of branch is feet

(direction)

of MH No.

and is approx. feet deep.

service sewer: 0 inch pipe

Sewer Book No. 8 Page

Wye Book No. Page



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

# Permit for Sewer Connection

Permit No. 48336

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation therefore, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.

Address: 7284 MONTELLA NW  
Lot 412  
Parcel 10006216  
Subdivision EMERALD ESTATES #10  
Township NE 07 JACKSON

Area charge \$2,000.00  
Local charge \$.00 (if app.)  
Permit fee \$ 50.00  
Connection charge \$2,050.00 (Total)  
Installation  
Cash Y 4/18/2016

Usage: SINGLE FAMILY RES 1 HOUSE/S

Date of issuance: 4/18/2016  
(Expires in 365 days)

Owner of property described:  
PULTE HOMES OF OHIO,  
11590 N MERIDIAN ST, STE  
CARMEL, IN 46903

By: *[Signature]*  
Licensed Drain Layer

Issued by: TJM

County Sanitary Engineer: MICHAEL S. ARMOGIDA

Sewer District 16  
Property is located on the S side (direction)  
of MONTELLA St.  
between WEST END OF St.  
and S MONTELLA CUL-DE-SAC  
Main sewer is in R/W N SIDE MONTELLA  
Y, branch is 298 feet  
(direction) E  
of MH No. 16-1462  
at WEST END MONTELLA @ EASEMENT

LATERAL SEWER:  
House conn. is 52.00 feet long and  
end of branch is 298 feet  
(direction) E  
of MH No. 16-1462  
and is approx. 10.0 feet deep.  
service sewer: 6 inch PVC pipe  
Sewer Book No. 5 Page 596  
Wye Book No. 10 Page 376

## Notes:

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of the City of MASSILLON

DISTRIBUTION OF COPIES: Green (County)

Pink (City)

Yellow (Contractor)

White (Inspection Dept.)



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

# Permit for Sewer Connection

Permit No. 48337

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation therefore, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.

Address: 7265 MONTELLA NW  
Lot 408  
Parcel 10006226  
Subdivision EMERALD ESTATES #10  
Township NE 07 JACKSON

Area charge \$2,000.00  
Local charge \$.00 (if app.)  
Permit fee \$ 50.00

Connection charge \$2,050.00 (Total)  
Installation  
Cash Y 4/18/2016

Usage: SINGLE FAMILY RES 1 HOUSE/S

Date of issuance: 4/18/2016

(Expires in 365 days)

Owner of property described:  
PULTE HOMES OF OHIO,  
11590 N MERIDIAN ST, STE  
CARMEL, IN 46032

By: *Robert Schneider*

Licensed Drain Layer SCHNEIDER ELECTRIC & PLUMBING INC

Issued by: TJM

County Sanitary Engineer: MICHAEL S. ARMOGIDA

## Notes:

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of the City of MASSILLON

Sewer District 16  
Property is located on the N side (direction)  
of MONTELLA St.  
between WEST END OF MONTELLA  
and S MONTELLA CUL-DE-SAC  
Main sewer is in R/W N SIDE MONTELLA  
Y, branch is 196 feet  
(direction) E  
of MH No. 16-1462  
at WEST END MONTELLA @ EASEMENT  
LATERAL SEWER:  
House conn. is 18.00 feet long and  
end of branch is 196 feet  
(direction) E  
of MH No. 16-1462  
and is approx. 10.0 feet deep.  
service sewer: 6 inch PVC pipe  
Sewer Book No. 5 Page 596  
Wye Book No. 10 Page 376

DISTRIBUTION OF COPIES: Green (County)

Pink (City)

Yellow (Contractor)

White (Inspection Dept.)



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

# Permit for Sewer Connection

Permit No. 48344

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation therefore, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.

Address: 7446 MONTELLA NW

Lot 420

Parcel 10006224

Subdivision EMERALD ESTATES #10

Township NE 07 JACKSON

Area charge \$2,000.00

Local charge \$.00 (if app.)

Permit fee \$ 50.00

Connection charge \$2,050.00 (Total)

Installation Cash Y 4/21/2016

Usage: SINGLE FAMILY RES 1 HOUSE/S

Date of issuance: 4/21/2016

(Expires in 365 days)

Owner of property described:

MIRAMAR, VILLA  
6800 FREEDOM NW  
NORTH CANTON, OH 44720

By: [Signature]

Licensed Drain Layer SCHNEIDER ELECTRIC & PLUMBING INC

Issued by: RLH

County Sanitary Engineer: MICHAEL S. ARMOGIDA

Notes: 0' SOUTH & 52' EAST OF MH 16-1490

Sewer District 16

Property is located on the E side (direction)

of MONTELLA St.

between EMERALD ISLE St.

and S MONTELLA CUL-DE-SAC

Main sewer is in R/W W SIDE OF MONTELLA

Y, branch is STUB feet

(direction)

of MH No. 16-1490

at 1ST NORTH OF EMERALD ISLE

LATERAL SEWER:

House conn. is 52.00 feet long and

end of branch is 0 feet

(direction) S

of MH No. 16-1490

and is approx. 9.0 feet deep.

service sewer: 6 inch PVC pipe

Sewer Book No. 5 Page 595

Wye Book No. 10 Page 375

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of the City of MASSILLON

DISTRIBUTION OF COPIES: Green (County)

Pink (City)

Yellow (Contractor)

White (Inspection Dept.)



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

# Permit for Sewer Connection

Permit No. 48345

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation therefore, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.

Address: 4637 LISMORE NW  
Lot 409  
Parcel 16-30667  
Subdivision EST OF GLENMOOR #24  
Township NE 27 JACKSON  
Area charge \$2,000.00  
Local charge \$.00 (if app.)  
Permit fee \$ 50.00  
Connection charge \$2,050.00 (Total)  
Installation  
Cash Y 4/22/2016

Usage: SINGLE FAMILY RES. 1 HOUSE/S

Date of issuance: 4/22/2016  
(Expires in 365 days)

Owner of property described:

CAMPANELLI CONSTRUCTION  
4429 FULTON DR NW  
CANTON, OH 44718

By: *[Signature]*  
Licensed Drain Layer MALAVITE EXCAVATING, INC.

Issued by: RLH

County Sanitary Engineer: MICHAEL S. ARMOGIDA

Notes: FLOWLINE IS 1.45' ABOVE DOWNSTREAM MH #25-1119 FLOWLINE

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of the City of MASSILLON

Sewer District 25  
Property is located on the W side (direction)  
of LISMORE St.  
between ARMANDALE St.  
and CUL-DE-SAC St.  
Main sewer is in LISMORE  
Y, branch is 78 feet  
(direction) NORTH  
of MH No. 25-1119  
at 2ND NORTH OF ARMANDALE  
LATERAL SEWER:  
House conn. is 28.00 feet long and  
end of branch is 78 feet  
(direction) NORTH  
of MH No. 25-1119  
and is approx. 12.0 feet deep.  
service sewer: 6 inch PVC pipe  
Sewer Book No. 8 Page 251  
Wye Book No. 8 Page 347



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

# Permit for Sewer Connection

Permit No. 48346

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation therefore, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.

Address: 7728 CRANFORD NW  
Lot 52  
Parcel 16-09385  
Subdivision JACKSON MEADOWS 2  
Township SW 16 JACKSON

Area charge \$2,000.00  
Local charge \$.00 (if app.)  
Permit fee \$ 50.00  
Connection charge \$2,050.00 (Total)  
Installation  
Cash Y 4/22/2016

Usage: SINGLE FAMILY RES 1 HOUSE/S

Date of issuance: 4/22/2016  
(Expires in 365 days)

Owner of property described:

COBB, CHRISTOPHER A  
7728 CRANFORD ST NW  
MASSILLON, OHIO 44646

By: [Signature]  
Licensed Drain Layer UNDERGROUND SERVICES INC.

Issued by: RLH

County Sanitary Engineer: MICHAEL S. ARMOGIDA

Notes: FLOWLINE IS 8.79' ABOVE DS MH 1982 FL - 7.24' STACK

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of the City of MASSILLON

Sewer District 16  
Property is located on the S side (direction)  
of CRANFORD St.  
between CRANFORD St.  
and VANTAGE HILL St.  
Main sewer is in CRANFORD  
Y, branch is 18 feet  
(direction) WEST  
of MH No. 16-1982  
at 2ND EAST OF VANTAGE HILL  
LATERAL SEWER:  
House conn. is 27.00 feet long and  
end of branch is 23 feet  
(direction) WEST  
of MH No. 16-1982  
and is approx. 11.5 feet deep.  
service sewer: 6 inch PVC pipe  
Sewer Book No. 5 Page 640  
Wye Book No. 10 Page 183



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

# Permit for Sewer Connection

Permit No. **48354**

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation therefore, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.

Address: 7680 CRANFORD NW

Lot 50

Parcel 16-09383

Subdivision JACKSON MEADOWS 2

Township SW 16 JACKSON

Area charge \$2,000.00

Local charge \$ .00 (if app.)

Permit fee \$ 50.00

Connection charge \$2,050.00 (Total)

Installation Cash Y 4/29/2016

Usage: SINGLE FAMILY RES 1 HOUSE/S

Date of issuance: 4/29/2016

(Expires in 365 days)

Owner of property described:

PHILLABAUM, THOMAS  
7680 CRANFORD ST NW  
MASSILLON, OHIO 44646

By: [Signature]

Licensed Drain Layer

RLH

Issued by: MICHAEL S. ARMOGIDA

County Sanitary Engineer:

Notes: FLOWLINE IS 10.75' ABOVE DOWNSTREAM MH 16-1981 FLOWLINE

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of the City of MASSILLON

Sewer District 16  
Property is located on the S side (direction)

of CRANFORD St.

between CRANFORD St.

and VANTAGE HILL St.

Main sewer is in CRANFORD

Y, branch is 178 feet

(direction) WEST

of MH No. 16-1981

at 2ND SOUTH OF CHERYL LANE

LATERAL SEWER:  
House conn. is 29.00 feet long and

end of branch is 180 feet

(direction) WEST

of MH No. 16-1981

and is approx. 9.5 feet deep.

service sewer: 6 inch PVC pipe

Sewer Book No. 10 Page 183

Wye Book No. 10 Page 183



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

# Permit for Sewer Connection

Permit No. **48356**

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation therefore, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.

Address: 9050 CANAL PLACE NW

Lot BLDG#4

Parcel 16-29527

Subdivision CANAL PLACE CONDOS

Township SW 29 JACKSON

Area charge \$2,000.00

Local charge \$ .00 (if app.)

Permit fee \$ 50.00

Connection charge \$2,050.00 (Total)

Installation Cash Y 4/29/2016

Usage: SINGLE FAMILY RES 1 HOUSE/S

Date of issuance: 4/29/2016

(Expires in 365 days)

Owner of property described:

COCKLIN, AUBREY

1603 S MAIN ST, UNIT D

\* CANTON, OH 44709

By: [Signature]

Licensed Drain Layer MALAVITE EXCAVATING, INC.

Issued by: TJM

County Sanitary Engineer: MICHAEL S. ARMOGIDA

Notes: FLOWLINE 2.0FT ABOVE DOWNSTREAM MH#1143 FLOWLINE

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of the City of MASSILLON

Sewer District 16

Property is located on the S side (direction)

of CANAL PLACE St.

between ERIE St.

and END OF St.

Main sewer is in CANAL PLACE

Y, branch is 56 feet

(direction) EAST

of MH No. 1143

at 3RD SOUTHEAST OF

ERIE & FORTY CORNE

LATERAL SEWER:

House conn. is 40.00 feet long and

end of branch is 56 feet

(direction) EAST

of MH No. 1143

and is approx. 10.5 feet deep.

service sewer: 6 inch PVC pipe

Sewer Book No. 5D Page 400

Wye Book No. 10 Page 276



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

# Permit for Sewer Connection

Permit No. **48357**

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation therefore, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.

Address: 8010 LUTZ NW  
Lot 3.56  
Parcel 10007449  
Subdivision \_\_\_\_\_  
Township SW 5 JACKSON

Area charge \$2,000.00  
Local charge \$ .00 (if app.)  
Permit fee \$ 50.00  
Connection charge \$2,050.00 (Total)  
Installation \_\_\_\_\_  
Cash Y 5/3/2016

Usage: SINGLE FAMILY RES 1 HOUSE/S

Date of issuance: 5/3/2016

(Expires in 365 days)

Owner of property described:

AYAYO, KARELYNNE  
9390 HOOKING ST NW  
MASSILLON, OH 44646

By: [Signature]  
Licensed Drain Layer MALAVITE EXCAVATING, INC.

Issued by: \_\_\_\_\_  
MICHAEL S. ARMOGIDA

County Sanitary Engineer:

Notes: WYE ONLY OWNER INSTALL OR TAP MAIN/ RUN LATERAL TO EASEMENT

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of the City of

Sewer District 16  
Property is located on the E side (direction)  
of LUTZ St.  
between PAULDING St.  
and STRAUSSER St.  
Main sewer is in LUTZ WEST R/W  
Y, branch is 98 feet  
(direction) N  
of MH No. 16-1510  
at 2 ND SOUTH OF PAULDING  
LATERAL SEWER:  
House conn. is \_\_\_\_\_ feet long and  
end of branch is \_\_\_\_\_ feet  
(direction) \_\_\_\_\_  
of MH No. \_\_\_\_\_  
and is approx. \_\_\_\_\_ feet deep.  
service sewer: 0 inch pipe  
Sewer Book No. 5 Page 476  
Wye Book No. 6 Page 417



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

# Permit for Sewer Connection

Permit No. **48363**

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation therefore, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.

Address: 5581 EAST BLVD NW  
Lot 106  
Parcel 16-03666  
Subdivision LAKE CABLE SEC D  
Township SE 14 JACKSON

Area charge \$ .00  
Local charge \$ .00 (if app.)  
Permit fee \$ 50.00  
Connection charge \$50.00 (Total)  
Installation Cash Y 5/9/2016

Usage: SINGLE FAMILY RES 1 HOUSE/S

Date of issuance: 5/9/2016

(Expires in 365 days)

Owner of property described:  
ROTH, BRUCE R & KELLY A  
5581 EAST BLVD NW  
CANTON, OH 44718

By: Bill Alborn  
Licensed Drain Layer ALBORN EXCAVATING

Issued by: MICHAEL S. ARMOGIDA

County Sanitary Engineer:

RE-CONNECT TO EX LAT; PREV PERMIT #00074

Notes:

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of the City of

Sewer District 29  
Property is located on the W side (direction)  
of EAST BLVD St.  
between LAKE CABLE RD St.  
and VILLA PADOVA St.

Main sewer is in EASEMENT  
Y, branch is 230 feet  
(direction) S  
of MH No. 29-119  
at 1ST SW OF EAST BLVD IN EASEME

LATERAL SEWER:  
House conn. is 8.00 feet long and  
end of branch is 230 feet  
(direction) S  
of MH No. 29-119  
and is approx. 3.0 feet deep.

service sewer: 6 inch VCP pipe  
Sewer Book No. 7 Page 113  
Wye Book No. 11 Page 113

DISTRIBUTION OF COPIES: Green (County)

Pink (City)

Yellow (Contractor)

White (Inspection Dept.)



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

# Permit for Sewer Connection

Permit No. **48365**

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation therefore, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.

Address: 5360R S ISLAND NW  
Lot 168,169  
Parcel 16-16071  
Subdivision LAKE CABLE SEC C  
Township NW 23 JACKSON

Area charge \$ .00  
Local charge \$ .00 (if app.)  
Permit fee \$ 50.00  
Connection charge \$50.00 (Total)  
Installation Cash Y 5/11/2016

Usage: SINGLE FAMILY RES 1 HOUSE/S

Date of issuance: 5/11/2016

(Expires in 365 days)

Owner of property described:  
OSTROUT JR TRUSTEE, CHARLES  
5526 LILLYS LN NW  
CANTON, OH 44718

By: [Signature]  
MALAVITE EXCAVATING, INC.  
Licensed Drain Layer

Issued by: MICHAEL S. ARMOGIDA

County Sanitary Engineer:

Notes: EX HOUSE RAZED-PREV PERMIT #01391-EXTENDING EXISTING LATERAL

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of the City of

Sewer District 29  
Property is located on the S side (direction)  
of ISLAND St.  
between REX St.  
and E END OF ISLAND St.

Main sewer is in EASEMENT REAR  
Y, branch is \_\_\_\_\_ feet  
(direction) \_\_\_\_\_  
of MH No. \_\_\_\_\_  
at \_\_\_\_\_

LATERAL SEWER:  
House conn. is \_\_\_\_\_ feet long and  
end of branch is \_\_\_\_\_ feet  
(direction) \_\_\_\_\_  
of MH No. \_\_\_\_\_  
and is approx. \_\_\_\_\_ feet deep.

service sewer: 0 inch pipe  
7 28  
Sewer Book No. Page  
7 221  
Wye Book No. Page



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

# Permit for Sewer Connection

Permit No. **48368**

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation therefore, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

**The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.**

Address: 1375R DEERMONT SW

Lot \_\_\_\_\_

Parcel 7401334

Subdivision \_\_\_\_\_

Township NE 14 TUSC

Area charge \$ .00

Local charge \$ .00 (if app.)

Permit fee \$ 50.00

Connection charge \$50.00 (Total)

Installation \_\_\_\_\_

Cash Y 5/11/2016

Usage: SINGLE FAMILY RES 1 HOUSE/S

Date of issuance: 5/11/2016

(Expires in 365 days)

Owner of property described:

PFISTER JR, ROBERT  
1375 DEERMONT AVE SW  
MASSILLON, OH 44647

By: [Signature]  
Licensed Drain Layer TISSOT EXCAVATING, INC.

Issued by: RLH

County Sanitary Engineer: MICHAEL S. ARMOGIDA

Notes: RE-CONNECT TO EXISTING LATERAL AFTER DISCONNECT

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of the City of MASSILLON

Sewer District 27

Property is located on the W side (direction)

of DEERMONT St.

between RUBY St.

and LOCKWOOD St.

Main sewer is in DEERMONT

Y, branch is 119 feet

(direction) SOUTH

of MH No. 27-62

at 3RD SOUTH OF RUBY

LATERAL SEWER:  
House conn. is 27.00 feet long and

end of branch is 119 feet

(direction) SOUTH

of MH No. 27-62

and is approx. 9.5 feet deep.

service sewer: 6 inch PVC pipe

Sewer Book No. 7 Page \_\_\_\_\_

Wye Book No. 11 Page \_\_\_\_\_



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

# Permit for Sewer Connection

Permit No. **48372**

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation therefore, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.

Address: 9650 EMERALD HILL NW  
Lot 421  
Parcel 10007409  
Subdivision EMERALD ESTATES #11  
Township SW 7 JACKSON  
Area charge \$2,000.00  
Local charge \$ .00 (if app.)  
Permit fee \$ 50.00  
Connection charge \$2,050.00 (Total)  
Installation Cash Y 5/12/2016

Usage: SINGLE FAMILY RES 1 HOUSE/S

Date of issuance: 5/12/2016

(Expires in 365 days)

Owner of property described:

NVR/RIAN HOMES,  
6770 SNOWVILLE RD  
BRECKSVILLE, OH 44141

By: [Signature]  
Licensed Drain Layer CARR EXCAVATING LLC

Issued by: [Signature]  
MICHAEL S. ARMOGIDA

County Sanitary Engineer:

Notes: FLOWLINE IS 7.95' ABOVE DOWNSTREAM MH #16-2061 FLOWLINE

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of the City of

Sewer District 16  
Property is located on the S side (direction)  
of EMERALD HILL St.  
between AT EMERALD BAY St.  
and  St.  
Main sewer is in EMERALD HILL  
Y, branch is 46 feet  
(direction) WEST  
of MH No. 16-2061  
at EMERALD BAY  
LATERAL SEWER:  
House conn. is 55.00 feet long and  
end of branch is 46 feet  
(direction) WEST  
of MH No. 16-2061  
and is approx. 10.0 feet deep.  
service sewer: 6 inch PVC pipe  
Sewer Book No. 5 Page   
Wye Book No.  Page

DISTRIBUTION OF COPIES: Green (County)

Pink (City)

Yellow (Contractor)

White (Inspection Dept.)



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

# Permit for Sewer Connection

Permit No. **48373**

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation therefore, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

**The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.**

Address: 7198 EMERALD MARSH NW  
Lot 429  
Parcel 10007408  
Subdivision EMERALD ESTATES #11  
Township SW 7 JACKSON  
Area charge \$2,000.00  
Local charge \$ .00 (if app.)  
Permit fee \$ 50.00  
Connection charge \$2,050.00 (Total)  
Installation Cash Y 5/12/2016

Usage: SINGLE FAMILY RES 1 HOUSE/S

Date of issuance: 5/12/2016

(Expires in 365 days)

Owner of property described:

NVR/RIAN HOMES,  
6770 SNOWVILLE RD  
BRECKSVILLE, OH 44141

By: [Signature]  
Licensed Drain Layer CARR EXCAVATING LLC

Issued by: [Signature]  
MICHAEL S. ARMOGIDA

County Sanitary Engineer:

Notes: FL IS 2.60' ABV DS MH# 2060 FL; EOL IS 27' N, 69' E

Sewer District 16  
Property is located on the NE side (direction)  
of EMERALD MARSH St.  
between AT CUL-DE-SAC St.  
and  St.  
Main sewer is in EMERALD MARSH  
Y, branch is STUB feet  
(direction) IN  
of MH No. 16-2060  
at CUL-DE-SAC  
LATERAL SEWER:  
House conn. is 78.00 feet long and  
end of branch is 27 feet  
(direction) N  
of MH No. 16-2060  
and is approx. 9.0 feet deep.  
service sewer: 6 inch PVC pipe  
Sewer Book No. 5 Page   
Wye Book No.  Page

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of the City of

DISTRIBUTION OF COPIES: Green (County)

Pink (City)

Yellow (Contractor)

White (Inspection Dept.)



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

# Permit for Sewer Connection

Permit No. **48374**

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation therefore, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.

Address: 9619 EMERALD HILL NW  
Lot 423  
Parcel 10007403  
Subdivision EMERALD ESTATES #11  
Township SW 7 JACKSON

Area charge \$2,000.00  
Local charge \$ .00 (if app.)  
Permit fee \$ 50.00  
Connection charge \$2,050.00 (Total)  
Installation Cash Y 5/12/2016

Usage: SINGLE FAMILY RES 1 HOUSE/S

Date of issuance: 5/12/2016

(Expires in 365 days)

Owner of property described:

NVR/RYAN HOMES,  
6770 SNOWVILLE RD  
BRECKSVILLE, OH 44141

By: CARR EXCAVATING LLC  
Licensed Drain Layer

Issued by: MICHAEL S. ARMOGIDA

County Sanitary Engineer:

Notes: FLOWLINE IS 4.13' ABOVE DOWNSTREAM MH #16-2058 FLOWLINE

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of the City of

Sewer District 16  
Property is N side (direction)  
located on the EMERALD HILL St.  
of AT EMERALD MARSH St.  
between EMERALD MARSH St.  
and EMERALD MARSH St.  
Main sewer is in EMERALD MARSH  
Y, branch is 59 feet  
(direction) NORTH  
of MH No. 16-2058  
at EMERALD HILL  
LATERAL SEWER: 35.00  
House conn. is 59 feet long and  
end of branch is NORTH feet  
(direction) 16-2058  
of MH No. 9.0  
and is approx. 9.0 feet deep.  
service sewer: 6 inch PVC pipe  
Sewer Book No. 5 Page  
Wye Book No. 5 Page



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

# Permit for Sewer Connection

Permit No. **48375**

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation therefore, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

**The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.**

Address: 7179 EMERALD MARSH NW  
Lot 425  
Parcel 10007418  
Subdivision EMERALD ESTATES #11  
Township SW 7 JACKSON

Area charge \$2,000.00  
Local charge \$ .00 (if app.)  
Permit fee \$ 50.00  
Connection charge \$2,050.00 (Total)  
Installation Cash Y 5/12/2016

Usage: SINGLE FAMILY RES 1 HOUSE/S

Date of issuance: 5/12/2016

(Expires in 365 days)

Owner of property described:

NVR/ RIAN HOMES,  
6770 SNOWVILLE RD  
BRECKSVILLE, OH 44141

By: [Signature]  
Licensed Drain Layer CARR EXCAVATING LLC

Issued by: [Signature]  
MICHAEL S. ARMOGIDA

County Sanitary Engineer:

Notes: FLOWLINE IS 14.72' ABOVE DOWNSTREAM MH #16-2058 FLOWLINE

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of the City of

Sewer District 16  
Property is located on the W side (direction)  
of EMERALD MARSH St.  
between EMERALD HILL St.  
and CUL-DE-SAC St.

Main sewer is in EMERALD MARSH  
Y, branch is 220 feet  
(direction) NORTH  
of MH No. 16-2058  
at EMERALD HILL

LATERAL SEWER:  
House conn. is 35.00 feet long and  
end of branch is 220 feet  
(direction) NORTH  
of MH No. 16-2058  
and is approx. 9.0 feet deep.

service sewer: 6 inch PVC pipe  
5  
Sewer Book No. 5 Page 5  
Wye Book No. 5 Page 5



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

# Permit for Sewer Connection

Permit No. **48376**

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation therefore, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.

Address: 9602 EMERALD HILL NW  
Lot 436  
Parcel 10007417  
Subdivision EMERALD ESTATES #11  
Township SW 7 JACKSON  
Area charge \$2,000.00  
Local charge \$ .00 (if app.)  
Permit fee \$ 50.00  
Connection charge \$2,050.00 (Total)  
Installation Cash Y 5/12/2016

Usage: SINGLE FAMILY RES 1 HOUSE/S

Date of issuance: 5/12/2016

(Expires in 365 days)

Owner of property described:

NVR/RYAN HOMES,  
6770 SNOWVILLE RD  
BRECKSVILLE, OH 44141

By: [Signature]  
Licensed Drain Layer CARR EXCAVATING LLC

Issued by: [Signature]  
MICHAEL S. ARMOGIDA

County Sanitary Engineer:

Notes: FLOWLINE IS 1.25' ABOVE DOWNSTREAM MH #16-2058 FLOWLINE

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of the City of

Sewer District 16  
Property is located on the S side (direction)  
of EMERALD HILL St.  
between EMERALD MARSH St.  
and E END OF ST St.  
Main sewer is in EMERALD HILL  
Y, branch is 45 feet  
(direction) EAST  
of MH No. 16-2058  
at EMERALD MARSH  
LATERAL SEWER:  
House conn. is 35.00 feet long and  
end of branch is 45 feet  
(direction) EAST  
of MH No. 16-2058  
and is approx. 8.5 feet deep.  
service sewer: 6 inch PVC pipe  
Sewer Book No. 5 Page 5  
Wye Book No. 5 Page 5

DISTRIBUTION OF COPIES: Green (County)

Pink (City)

Yellow (Contractor)

White (Inspection Dept.)



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

# Permit for Sewer Connection

Permit No. **48371**

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation therefore, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.

Address: 7191 EMERALD MARSH NW

Lot

426

Parcel

10007407

Subdivision

EMERALD ESTATES #11

Township

SW 7 JACKSON

Area charge

\$2,000.00

Local charge

\$ .00 (if app.)

Permit fee

\$ 50.00

Connection charge

\$2,050.00 (Total)

Installation

Cash Y 5/12/2016

Usage:

SINGLE FAMILY RES

1 HOUSE/S

Date of issuance:

5/12/2016

(Expires in 365 days)

Owner of property described:

NVR/RYAN HOMES,  
6770 SNOWVILLE RD  
BRECKSVILLE, OH 44141

By:

Licensed Drain Layer

CARR EXCAVATING LLC

Issued by:

MICHAEL S. ARMOGIDA

County Sanitary Engineer:

FLOWLINE IS 16.67' ABOVE DOWNSTREAM MH #16-2058 FLOWLINE

Notes:

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of the City of

Sewer District 16

Property is located on the

W

side (direction)

of

EMERALD MARSH

St.

between

AT CUL-DE-SAC

St.

and

St.

Main sewer is in

EMERALD MARSH

Y, branch is

282

feet

(direction)

NORTH

of MH No.

16-2058

at

EMERALD HILL

LATERAL SEWER:

House conn. is

55.00

feet long and

end of branch is

282

feet

(direction)

NORTH

of MH No.

16-2058

and is approx.

9.0

feet deep.

service sewer:

6

inch

PVC

pipe

Sewer Book No.

5

Page

Wye Book No.

Page



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

# Permit for Sewer Connection

Permit No. 48377

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation therefore, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.

Address: 7182 EMERALD MARSH NW  
Lot 431  
Parcel 10007420  
Subdivision EMERALD ESTATES #11  
Township SW 7 JACKSON  
Area charge \$2,000.00  
Local charge \$.00 (if app.)  
Permit fee \$ 50.00  
Connection charge \$2,050.00 (Total)  
Installation Y 5/12/2016  
Cash -

Usage: SINGLE FAMILY RES 1 HOUSE/S

Date of issuance: 5/12/2016

(Expires in 365 days)

Owner of property described:

RYAN HOMES  
6770 SNOWVILLE RD  
BRECKSVILLE, OH 44141

By: [Signature]  
Licensed Drain Layer CARR EXCAVATING LLC

Issued by: [Signature]  
MICHAEL S. ARMOGIDA

County Sanitary Engineer:  
13.62 VF ABOVE MH 16-2058

Notes:

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of the City of

Sewer District 16  
Property is located on the E side (direction)  
of EMERALD MARSH St.  
between EMERALD HILL St.  
and COL-DE-SAC St.  
Main sewer is in EMERALD MARSH  
Y, branch is 234 feet  
(direction) N  
of MH No. 16-2058  
at EMERALD HILL  
LATERAL SEWER: 45.00 feet long and  
House conn. is 234 feet  
end of branch is N feet  
(direction) N  
of MH No. 16-2058  
and is approx. 10.0 feet deep.  
service sewer: 6 inch PVC pipe  
Sewer Book No. 5 Page  
Wye Book No. Page

DISTRIBUTION OF COPIES: Green (County)

Pink (City)

Yellow (Contractor)

White (Inspection Dept.)



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

# Permit for Sewer Connection

Permit No. **48378**

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation therefore, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.

Address: 7167 EMERALD MARSH NW  
Lot 424  
Parcel 10007419  
Subdivision EMERALD ESTATES #11  
Township SW 7 JACKSON  
Area charge \$2,000.00  
Local charge \$ .00 (if app.)  
Permit fee \$ 50.00  
Connection charge \$2,050.00 (Total)  
Installation Cash Y 5/12/2016

Usage: SINGLE FAMILY RES 1 HOUSE/S

Date of issuance: 5/12/2016

(Expires in 365 days)

Owner of property described:

RYAN HOMES,  
6770 SNOWVILLE RD  
BRECKSVILLE, OH 44141

By: MICHAEL S. ARMOGIDA  
Licensed Drain Layer

Issued by: MICHAEL S. ARMOGIDA

County Sanitary Engineer:

Notes:

FLOWLINE IS 14.72 FEET ABOVE DS MH# 16-2058 FLOWLINE

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of the City of

Sewer District 16  
Property is W side (direction)  
located on the EMERALD MARSH St.  
of EMERALD HILL St.  
between CUL-DE-SAC St.  
and EMERALD MARSH  
Main sewer is in 160 feet  
Y, branch is NORTH  
(direction) 16-2058  
of MH No. EMERALD HILL  
at EMERALD MARSH  
LATERAL SEWER: 35.00  
House conn. is 160 feet long and  
end of branch is NORTH feet  
(direction) 16-2058  
of MH No. 9.0  
and is approx. 6 inch PVC pipe  
service sewer: 5 Page  
Sewer Book No. 5 Page  
Wye Book No. 5 Page

DISTRIBUTION OF COPIES: Green (County)

Pink (City)

Yellow (Contractor)

White (Inspection Dept.)



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

# Permit for Sewer Connection

Permit No. 48379

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation therefore, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.

Address: 7170 EMERALD MARSH NW  
Lot 432  
Parcel 10007406  
Subdivision EMERALD ESTATES #11  
Township SW 7 JACKSON  
Area charge \$2,000.00  
Local charge \$.00 (if app.)  
Permit fee \$ 50.00  
Connection charge \$2,050.00 (Total)  
Installation Y 5/12/2016  
Cash

Usage: SINGLE FAMILY RES. 1 HOUSE/S

Date of issuance: 5/12/2016

(Expires in 365 days)

Owner of property described:

RYAN HOMES,  
6770 SNOWVILLE RD  
BRECKSVILLE, OH 44141

By: CARR EXCAVATING LLC  
Licensed Drain Layer

Issued by: MICHAEL S. ARMOGIDA

County Sanitary Engineer:

FLOWLINE IS 12.13 FEET ABOVE DS MH#16-2058 FLOWLINE

Notes:

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of the City of

Sewer District 16  
Property is located on the E side (direction)  
of EMERALD MARSH St.  
between EMERALD HILL St.  
and CUL-DE-SAC St.  
Main sewer is in EMERALD MARSH  
Y, branch is 176 feet  
(direction) NORTH  
of MH No. 16-2058  
at EMERALD HILL  
LATERAL SEWER: 45.00 feet long and  
House conn. is 176 feet  
end of branch is NORTH  
(direction) 16-2058  
of MH No. 9.5 feet deep.  
and is approx. 6 inch PVC pipe  
service sewer: 5  
Sewer Book No. Page  
Wye Book No. Page

DISTRIBUTION OF COPIES: Green (County)

Pink (City)

Yellow (Contractor)

White (Inspection Dept.)



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

# Permit for Sewer Connection

Permit No. **48383**

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation therefore, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

**The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.**

Address: 7194 EMERALD MARSH NW  
Lot 430  
Parcel 10007413  
Subdivision EMERALD ESTATES #11  
Township SW 7 JACKSON  
  
Area charge \$2,000.00  
Local charge \$ .00 (if app.)  
Permit fee \$ 50.00  
Connection charge \$2,050.00 (Total)  
Installation Cash Y 5/16/2016

Usage: SINGLE FAMILY RES 1 HOUSE/S

Date of issuance: 5/16/2016

(Expires in 365 days)

Owner of property described:

RYAN HOMES  
6770 SNOWVILLE RD  
BRECKSVILLE, OH 44141

By: [Signature]  
Licensed Drain Layer CARR EXCAVATING LLC

Issued by: [Signature]  
MICHAEL S. ARMOGIDA

County Sanitary Engineer:

Notes: 16.73 VF ABOVE MH 16-2058

Sewer District 16  
  
Property is located on the E side (direction)  
of EMERALD MARSH St.  
between EMERALD HILL St.  
and CUL-DE-SAC St.  
  
Main sewer is in EMERALD MARSH  
Y, branch is 295 feet  
(direction) N  
of MH No. 16-2058  
at EMERALD HILL  
  
LATERAL SEWER:  
House conn. is 70.00 feet long and  
end of branch is 295 feet  
(direction) N  
of MH No. 16-2058  
and is approx. 9.0 feet deep.  
service sewer: 6 inch PVC pipe  
Sewer Book No.          Page           
Wye Book No.          Page         

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of the City of

DISTRIBUTION OF COPIES: Green (County)

Pink (City)

Yellow (Contractor)

White (Inspection Dept.)



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

# Permit for Sewer Connection

Permit No. **48387**

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation therefore, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

**The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.**

Address: 7447 GALENA NW  
Lot 401  
Parcel 10004879  
Subdivision EMERALD ESTATES #9  
Township NW 7 JACKSON  
Area charge \$2,000.00  
Local charge \$ .00 (if app.)  
Permit fee \$ 50.00  
Connection charge \$2,050.00 (Total)  
Installation Cash Y 5/20/2016

Usage: SINGLE FAMILY RES\_ 1 HOUSE/S

Date of issuance: 5/20/2016

(Expires in 365 days)

Owner of property described:

PATRICK LONG HOMES  
11685 CLEVELAND AVE NW  
UNIONTOWN, OH 44685

By: Ellen Bontrager  
Licensed Drain Layer BONTRAGER EXCAVATING INC.

Issued by: RLH  
MICHAEL S. ARMOGIDA

County Sanitary Engineer:

Notes: FLOWLINE IS 6.85 FEET ABOVE DOWNSTREAM MH #16-1856 FLOWLINE

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of the City of

Sewer District 16  
Property is located on the W side (direction)  
of GALENA St.  
between DIAMOND RIDGE St.  
and EMERALD GLEN St.  
Main sewer is in GALENA  
Y, branch is 102 feet  
(direction) SOUTH  
of MH No. 16-1856  
at 1ST SOUTH OF DIAMOND RIDGE  
LATERAL SEWER:  
House conn. is 42.00 feet long and  
end of branch is 102 feet  
(direction) SOUTH  
of MH No. 16-1856  
and is approx. 6.0 feet deep.  
service sewer: 6 inch PVC pipe  
Sewer Book No. 5 Page 653  
Wye Book No. 10 Page 347



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

# Permit for Sewer Connection

Permit No. **48388**

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation therefore, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.

Address: 8510 SANDBROOK NW  
Lot 4  
Parcel 16-29551  
Subdivision MUDBROOK VILLAGE CONDOS  
Township NE 17 JACKSON  
  
Area charge \$2,000.00  
Local charge \$ .00 (if app.)  
Permit fee \$ 50.00  
Connection charge \$2,050.00 (Total)  
Installation Cash Y 5/23/2016

Usage: SINGLE FAMILY RES 1 HOUSE/S

Date of issuance: 5/23/2016

(Expires in 365 days)

Owner of property described:

SCHEETZ RES CONSTR,  
8060 FRANK AVE NW  
N CANTON, OH 44720

By: [Signature]  
Licensed Drain Layer KYLER EXCAVATING

Issued by: RLH  
MICHAEL S. ARMOGIDA

County Sanitary Engineer:

Notes: FLOWLINE IS 4.32' ABOVE DOWNSTREAM MH 16-1791 FLOWLINE

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of the City of MASSILLON

Sewer District 16  
Property is located on the S side (direction)

of SANDBROOK St.

between GLENBROOK St.

and WEST St.

Main sewer is in SANDBROOK

Y, branch is 10 feet

(direction) WEST

of MH No. 16-1791

at 1ST WEST OF GLENBROOK

LATERAL SEWER:  
House conn. is 66.00 feet long and

end of branch is 67 feet

(direction) WEST

of MH No. 16-1791

and is approx. 12.5 feet deep.

service sewer: 6 inch PVC pipe

Sewer Book No. 5 Page 581

Wye Book No. 10 Page 129



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

# Permit for Sewer Connection

Permit No. 48391

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation therefore, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.

Address: 7944 CHERYL LANE NW

Lot 87

Parcel 16-09422

Subdivision JACKSON MEADOWS 3

Township SW 16 JACKSON

Area charge \$ .00

Local charge \$ .00 (if app.)

Permit fee \$ 50.00

Connection charge \$50.00 (Total)

Installation  
Cash Y 5/25/2016

Usage: SINGLE FAMILY RES 1 HOUSE/S

Date of issuance: 5/25/2016

(Expires in 365 days)

Owner of property described:

HARST, ERIC T & JEANNIE  
7944 CHERYL LANE ST NW  
MASSILLON, OHIO 44646

By: [Signature]  
Licensed Drain Layer UNDERGROUND SERVICES INC.

Issued by: TJM

MICHAEL S. ARMOGIDA

County Sanitary Engineer:

Notes: FL IS 3.56' ABV DS MH 1971 FL; REISSUED-PREV PERMIT #47650

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of the City of MASSILLON

Sewer District 16

Property is located on the S side (direction)

of CHERYL LANE St.

between VANTAGE HILL St.

and ARLINGTON St.

Main sewer is in CHERYL LANE

Y, branch is 238 feet

(direction) WEST

of MH No. 16-1971

at 1ST WEST OF VANTAGE HILL

LATERAL SEWER:

House conn. is 29.00 feet long and

end of branch is 238 feet

(direction) WEST

of MH No. 16-1971

and is approx. 11.5 feet deep.

service sewer: 6 inch PVC pipe

Sewer Book No. 5 Page

Wye Book No. 10 Page 180



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

# Permit for Sewer Connection

Permit No. **48392**

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation therefore, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

**The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.**

Address:	7756 CHERYL LANE NW	Sewer District	16
Lot	65	Property is located on the	S side (direction)
Parcel	16-09398	of	CHERYL LANE St.
Subdivision	JACKSON MEADOWS 2	between	CHELSEA St.
Township	SW 16 JACKSON	and	VANTAGE HILL St.
Area charge	\$ .00	Main sewer is in	CHERYL LANE
Local charge	\$ .00 (if app.)	Y, branch is	77 feet
Permit fee	\$ 50.00	(direction)	WEST
Connection charge	\$50.00 (Total)	of MH No.	16-1968
Installation		at	1ST WEST OF CHELSEA
Cash	Y 5/25/2016		
Usage:	SINGLE FAMILY RES_ 1 HOUSE/S	LATERAL SEWER:	
Date of issuance:	5/25/2016	House conn. is	22.00 feet long and
	(Expires in 365 days)	end of branch is	77 feet
Owner of property described:		(direction)	WEST
DENNIS, MICHELLE R		of MH No.	16-1968
7756 CHERYL LANE ST NW		and is approx.	10.0 feet deep.
MASSILLON, OHIO 44646		service sewer:	6 inch PVC pipe
By: <i>[Signature]</i>		Sewer Book No.	5 Page
Licensed Drain Layer	UNDERGROUND SERVICES INC.	Wye Book No.	10 Page 179
Issued by:			
County Sanitary Engineer:	MICHAEL S. ARMOGIDA		
Notes:	FL 5.75' ABV DS MH 1968 FL; REISSUED - PREV PERMIT #47529		

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of the City of MASSILLON

DISTRIBUTION OF COPIES: Green (County) Pink (City) Yellow (Contractor) White (Inspection Dept.)



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

# Permit for Sewer Connection

Permit No. **48396**

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation therefore, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.

Address: 7199 EMERALD MARSH NW  
Lot 427  
Parcel 10007415  
Subdivision EMERALD ESTATES #11  
Township SW 07 JACKSON

Area charge \$2,000.00  
Local charge \$ .00 (if app.)  
Permit fee \$ 50.00  
Connection charge \$2,050.00 (Total)  
Installation Cash Y 5/31/2016

Usage: SINGLE FAMILY RES 1 HOUSE/S

Date of issuance: 5/31/2016  
(Expires in 365 days)

Owner of property described:  
NVR/RYAN HOMES,  
6770 SNOWVILLE RD  
BRECKSVILLE, OH 44141

By: Licensed Drain Layer CARR EXCAVATING LLC

Issued by: TJM

County Sanitary Engineer: MICHAEL S. ARMOGIDA

Notes: EOL 60' WEST 12' NORTH / FL 1.91 VF ABOVE DSMH 16-2060

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of the City of MASSILLON

Sewer District 16  
Property is located on the W side (direction)  
of EMERALD MARSH St.  
between AT CUL-DE-SAC St.  
and \_\_\_\_\_ St.

Main sewer is in EMERALD MARSH  
Y, branch is STUB feet  
(direction) \_\_\_\_\_  
of MH No. 16-2060  
at CUL-DE-SAC

LATERAL SEWER:  
House conn. is 65.00 feet long and  
end of branch is 12 feet  
(direction) N  
of MH No. 16-2060  
and is approx. 9.0 feet deep.  
service sewer: 6 inch PVC pipe  
Sewer Book No. 5 Page \_\_\_\_\_  
Wye Book No. \_\_\_\_\_ Page \_\_\_\_\_



**STARK COUNTY METROPOLITAN SEWER DISTRICT**  
**SANITARY ENGINEERING DEPARTMENT**

**Permit for Sewer Connection**

**Permit No. 48401**

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation thereof, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

**The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.**

<p>Address: <u>9594 EMERALD HILL NW</u></p> <p>Lot: <u>435</u></p> <p>Parcel: <u>10007414</u></p> <p>Subdivision: <u>EMERALD ESTATES #11</u></p> <p>Township: <u>JACKSON SW 07</u></p> <p>Area Charge: <u>2,000.00</u></p> <p>Local Charge: <u>0.00</u> (if app.)</p> <p>Permit Fee: <u>50.00</u></p> <p>Connection Charge: <u>2,050.00</u> (Total)</p> <p>Installation: <u>Payments: Check #937409 06/07/2016</u></p> <p>Usage: <u>SINGLE FAMILY RES 1 HOUSE/S</u></p> <p>Date of Issuance: <u>06/07/2016</u> (Expires in 365 Days)</p> <p>Owner of Property Described: <u>RYAN HOMES,</u> <u>6770 SNOWVILLE RD</u> <u>BRECKSVILLE, OH 44141</u></p> <p>By: <u>CARR EXCAVATING LLC</u> <small>Licensed Drain Layer</small></p> <p>Issued By: <u>RLH</u></p> <p>County Sanitary Engineer: <u>JAMES F. TROIKE, P.E.</u></p> <p>Notes: <u>FL IS 2.60 VF ABOVE DSMH 16-2058 FL</u></p>	<p>Sewer District <u>16</u> Project No: _____</p> <p>Property is located on the <u>S</u> side (direction) of <u>EMERALD HILL</u> St. between <u>EMERALD MARSH</u> St. and _____ St.</p> <p>Main sewer is in <u>EMERALD HILL</u></p> <p>Y, branch is <u>113</u> feet (direction) <u>E</u> of MH No. <u>16-2058</u> at <u>EMERALD MARSH</u></p> <p>LATERAL SEWER: House conn. is <u>35</u> feet long and end of branch is <u>113</u> feet (direction) <u>E</u> of MH No. <u>16-2058</u> and is approx. <u>8.0</u> feet deep. Height above Downstream Manhole Flowline: <u>2.60</u></p> <p>Service sewer: <u>6</u> inch <u>PVC</u> pipe</p> <p>Sewer Book No. <u>5</u> Page _____</p> <p>Wye Book No. _____ Page _____</p>
---	---

DISTRIBUTION OF COPIES: White (County) Yellow (Contractor) Pink (City) Gold (Inspection Dept.)



**STARK COUNTY METROPOLITAN SEWER DISTRICT**  
**SANITARY ENGINEERING DEPARTMENT**

**Permit for Sewer Connection**

**Permit No. 48402**

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation thereof, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

**The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.**

<p>Address: <u>7407 MONTELLA NW</u></p> <p>Lot: <u>404</u></p> <p>Parcel: <u>10006222</u></p> <p>Subdivision: <u>EMERALD ESTATES #10</u></p> <p>Township: <u>JACKSON NE 07</u></p> <p>Area Charge: <u>2,000.00</u></p> <p>Local Charge: <u>0.00</u> (if app.)</p> <p>Permit Fee: <u>50.00</u></p> <p>Connection Charge: <u>2,050.00</u> (Total)</p> <p>Installation: _____</p> <p>Payments: Check #50573962 06/09/2016</p> <p>Usage: <u>SINGLE FAMILY RES</u> <u>1</u> HOUSE/S</p> <p>Date of Issuance: <u>06/09/2016</u> (Expires in 365 Days)</p> <p>Owner of Property Described: <u>PULTE HOMES OF OHIO LLC</u> <u>11590 N MERIDIAN ST, STE 530</u> <u>MASSILLON, OH 44646</u></p> <p>By: <u>[Signature]</u> Licensed Drain Layer</p> <p>Issued By: TJM PLMG INC</p> <p>County Sanitary Engineer: JAMES F. TROIKE, P.E.</p> <p>Notes: _____</p>	<p>Sewer District <u>16</u> Project No: _____</p> <p>Property is located on the <u>W</u> side (direction) of <u>MONTELLA</u> St. between <u>EMERALD ISLE</u> St. and <u>S MONTELLA CUL-DE-SA</u> St.</p> <p>Main sewer is in <u>R/W WEST SIDE MONTELLA</u> Y, branch is <u>217</u> feet (direction) <u>S</u> of MH No. <u>16-1490</u> at <u>1ST SOUTH OF EMERALD ISLE</u></p> <p>LATERAL SEWER: House conn. is <u>18</u> feet long and end of branch is <u>217</u> feet (direction) <u>S</u> of MH No. <u>16/1490</u> and is approx. <u>9.0</u> feet deep. Height above _____</p> <p>Downstream Manhole Flowline: _____</p> <p>Service sewer: <u>6</u> inch <u>PVC</u> pipe</p> <p>Sewer Book No. <u>5</u> Page <u>595</u></p> <p>Wye Book No. <u>10</u> Page <u>375</u></p>
--	--

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of MASSILLON

DISTRIBUTION OF COPIES: White (County) Yellow (Contractor) Pink (City) Gold (Inspection Dept.)



**STARK COUNTY METROPOLITAN SEWER DISTRICT**  
**SANITARY ENGINEERING DEPARTMENT**

**Permit for Sewer Connection**

**Permit No. 48403**

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation thereof, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

**The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.**

<p>Address: <u>7551 ROLLING GREEN NW</u></p> <p>Lot: <u>47</u></p> <p>Parcel: <u>10000090</u></p> <p>Subdivision: <u>ROLLING GREEN #4</u></p> <p>Township: <u>JACKSON NW 8</u></p> <p>Area Charge: <u>2,000.00</u></p> <p>Local Charge: <u>0.00</u> (if app.)</p> <p>Permit Fee: <u>50.00</u></p> <p>Connection Charge: <u>2,050.00</u> (Total)</p> <p>Installation: _____</p> <p>Payments: Check #3424 06/13/2016</p> <p>Usage: <u>SINGLE FAMILY RES_ 1 HOUSE/S</u></p> <p>Date of Issuance: <u>06/13/2016</u> (Expires in 365 Days)</p> <p>Owner of Property Described: <u>AURORA CUSTOM HOMES,</u> <u>PO BOX 35365</u> <u>CANTON, OH 44735</u></p> <p>By: <u><i>Jennifer Conn</i></u> Licensed Drain Layer</p> <p>Issued By: TJM</p> <p>County Sanitary Engineer: JAMES F. TROIKE, P.E.</p>	<p>Sewer District <u>16</u> Project No: _____</p> <p>Property is located on the <u>W</u> side (direction) of <u>ROLLING GREEN</u> St. between <u>IRONS</u> St. and <u>BLAKNEY</u> St.</p> <p>Main sewer is in <u>ROLLING GREEN</u> Y, branch is <u>51</u> feet (direction) <u>SOUTH</u> of MH No. <u>16-1836</u> at <u>1ST SOUTH OF IRONS</u></p> <p>LATERAL SEWER: House conn. is <u>63</u> feet long and end of branch is <u>51</u> feet (direction) <u>SOUTH</u> of MH No. <u>16-1836</u> and is approx. <u>9.0</u> feet deep.</p> <p>Height above Downstream Manhole Flowline: _____</p> <p>Service sewer: <u>6</u> inch <u>PVC</u> pipe</p> <p>Sewer Book No. <u>5</u> Page <u>600</u></p> <p>Wye Book No. <u>10</u> Page <u>132</u></p>
--	---

Notes: FLOWLINE IS 0.94' ABOVE DOWNSTREAM MH 16-1836 FLOWLINE

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of MASSILLON

DISTRIBUTION OF COPIES: White (County)      Yellow (Contractor)      Pink (City)      Gold (Inspection Dept.)



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

Permit for Sewer Connection

Permit No. 48406

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation thereof, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.

Address: 5542 LILLYS LN NW	Sewer District 29 Project No: _____
Lot: 244,245	Property is located on the S side (direction)
Parcel: 1604279	of LILLYS LN St.
Subdivision: LAKE CABLE	between N ISLAND St.
Township: JACKSON SW 14	and END St.
Area Charge: 0.00	Main sewer is in LAKEFRONT
Local Charge: 0.00 (if app.)	Y, branch is 8 feet
Permit Fee: 50.00	(direction) EAST
Connection Charge: 50.00 (Total)	of MH No. 29-47
Installation: Payments: Cash 06/16/2016	at MH ON LOT
Usage: SINGLE FAMILY RES 1 HOUSE/S	LATERAL SEWER: House conn. is _____ feet long and
Date of Issuance: 06/16/2016 (Expires in 365 Days)	end of branch is _____ feet
Owner of Property Described: DOLL, JEFFREY H 5613 LILLYS LN NW CANTON, OH 44718	(direction) _____
By: <i>Pink Allen</i> Licensed Drain Layer ALBORN EXCAVATING	of MH No. _____
Issued By: TJM	and is approx. _____ feet deep.
County Sanitary Engineer: JAMES F. TROIKE, P.E.	Height above _____
Notes: EX HOME RAZED, PREV PERMIT #00911 - MOST LIKELY USING EXISTING LATERAL	Downstream Manhole Flowline: _____
Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of MASSILLON	Service sewer: 6 inch CLAY pipe
DISTRIBUTION OF COPIES: White (County) Yellow (Contractor) Pink (City) Gold (Inspection Dept.)	Sewer Book No. 8 Page 76
	Wye Book No. 8-7 Page 215



**STARK COUNTY METROPOLITAN SEWER DISTRICT**  
**SANITARY ENGINEERING DEPARTMENT**

**Permit for Sewer Connection**

**Permit No. 48411**

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation thereof, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

**The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.**

<p>Address: <u>6170 LAVENHAM SW</u></p> <p>Lot: <u>59</u></p> <p>Parcel: <u>4319388</u></p> <p>Subdivision: <u>BISHOP MEADOWS #3</u></p> <p>Township: <u>PERRY NE 22</u></p> <p>Area Charge: <u>2,000.00</u></p> <p>Local Charge: <u>0.00</u> (if app.)</p> <p>Permit Fee: <u>50.00</u></p> <p>Connection Charge: <u>2,050.00</u> (Total)</p> <p>Installation: <u>Payments: Check #937449 06/20/2016</u></p> <p>Usage: <u>SINGLE FAMILY RES 1 HOUSE/S</u></p> <p>Date of Issuance: <u>06/20/2016</u> (Expires in 365 Days)</p> <p>Owner of Property Described: <u>RYAN HOMES</u> <u>6770 SNOWVILLE RD.</u> <u>BRECKSVILLE, OH 44141</u></p> <p>By: <u>Licensed Drain Layer CARR EXCAVATING LLC</u></p> <p>Issued By: <u>RLH</u></p> <p>County Sanitary Engineer: <u>JAMES F. TROIKE, P.E.</u></p>	<p>Sewer District <u>22</u> Project No: _____</p> <p>Property is located on the <u>S</u> side (direction) of <u>LAVENHAM</u> St. between <u>ASHWELL</u> St. and <u>END OF</u> St.</p> <p>Main sewer is in <u>LAVENHAM</u> Y, branch is <u>95</u> feet (direction) <u>WEST</u> of MH No. <u>22-644</u> at <u>3RD EAST OF ASHWELL</u></p> <p>LATERAL SEWER: House conn. is <u>62</u> feet long and end of branch is <u>95</u> feet (direction) <u>WEST</u> of MH No. <u>22-644</u> and is approx. <u>12.0</u> feet deep. Height above Downstream Manhole Flowline: <u>11.69</u></p> <p>Service sewer: <u>6</u> inch <u>PVC</u> pipe</p> <p>Sewer Book No. <u>12</u> Page <u>285</u></p> <p>Wye Book No. <u>8</u> Page <u>345</u></p>
---	--

Notes: Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of MASSILLON

DISTRIBUTION OF COPIES: White (County) Yellow (Contractor) Pink (City) Gold (Inspection Dept.)



**STARK COUNTY METROPOLITAN SEWER DISTRICT**  
**SANITARY ENGINEERING DEPARTMENT**

## Permit for Sewer Connection

Permit No. 48416

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation thereof, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

**The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.**

Address: 7150 EMERALD MARSH NW Lot: 434 Parcel: 10007404 Subdivision: EMERALD ESTATES # 11 Township: JACKSON SW 07  Area Charge: 2,000.00 Local Charge: 0.00 (if app.) Permit Fee: 50.00 Connection Charge: 2,050.00 (Total) Installation: Payments: Check #937491 06/20/2016  Usage: SINGLE FAMILY RES 1 HOUSE/S  Date of Issuance: 06/20/2016 (Expires in 365 Days) Owner of Property Described: RYAN HOMES 6770 SNOWVILLE RD BRECKSVILLE, OH 44141  By: _____ Licensed Drain Layer CARR EXCAVATING LLC  Issued By: RLH  County Sanitary Engineer: JAMES F. TROIKE, P.E.	Sewer District 16 Project No: _____ Property is located on the E side (direction) of EMERALD MARSH St. between AT EMERALD HILL St. and _____ St. Main sewer is in EMERALD MARSH Y, branch is 63 feet (direction) NORTH of MH No. 16-2058 at EMERALD HILL  LATERAL SEWER: House conn. is 45 feet long and end of branch is 63 feet (direction) NORTH of MH No. 16-2058 and is approx. 9.0 feet deep. Height above Downstream Manhole Flowline: 4.70 Service sewer: 6 inch PVC pipe Sewer Book No. _____ Page _____ Wye Book No. _____ Page _____
--	--

Notes:

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of MASSILLON

DISTRIBUTION OF COPIES: White (County)

Yellow (Contractor)

Pink (City)

Gold (Inspection Dept.)



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

Permit for Sewer Connection

Permit No. 48417

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation thereof, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.

Address: 1300 GENOA SW	Sewer District 9	Project No: _____
Lot: _____	Property is located on the E side (direction)	
Parcel: 4319512	of GENOA St.	
Subdivision: _____	between 12TH St.	
Township: PERRY SE 2	and LINCOLN WAY St.	
Area Charge: 0.00	Main sewer is in GENOA	
Local Charge: 0.00 (if app.)	Y, branch is STUB feet	
Permit Fee: 50.00	(direction) _____	
Connection Charge: 50.00 (Total)	of MH No. 09-41	
Installation: _____	at 2ND SOUTH OF 12TH ST.	
Payments: Cash 06/22/2016		
Usage: SINGLE FAMILY RES 0 HOUSE/S	LATERAL SEWER:	
	House conn. is 35 feet long and	
	end of branch is _____ feet	
	(direction) _____	
	of MH No. 09-41	
	and is approx. 7.5 feet deep.	
	Height above _____	
	Downstream Manhole Flowline: _____	
	Service sewer: 6 inch VCP pipe	
	Sewer Book No. 2 Page 6	
	Wye Book No. 2 Page 330	
Date of Issuance: 06/22/2016 (Expires in 365 Days)		
Owner of Property Described: WAIKEM, NANCY C. TRUSTE 3190 INWOOD DR. NW MASSILLON, OH 44646		
By: <i>[Signature]</i> Licensed Drain Layer BACHTEL EXCAVATING, INC.		
Issued By: TJM		
County Sanitary Engineer: JAMES F. TROIKE, P.E.		

Notes: EX HOME MUST BE DISCONNECTED BEFORE THE NEW HOME CONNECTS. USING SAME LATERAL P

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of MASSILLON

DISTRIBUTION OF COPIES: White (County) Yellow (Contractor) Pink (City) Gold (Inspection Dept.)



**STARK COUNTY METROPOLITAN SEWER DISTRICT**  
**SANITARY ENGINEERING DEPARTMENT**

**Permit for Sewer Connection**


Permit No. 48423

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation thereof, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

**The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.**

Address: 6055 GLENPOINTE NW Lot: 18 Parcel: 10001951 Subdivision: GREENWICH PLACE Township: JACKSON SW 16 Area Charge: 2,000.00 Local Charge: 0.00 (if app.) Permit Fee: 50.00 Connection Charge: 2,050.00 (Total) Installation: Payments: Check #1217 06/30/2016 Usage: SINGLE FAMILY RES_ 1 HOUSE/S Date of Issuance: 06/30/2016 (Expires in 365 Days) Owner of Property Described: VICTORYGATE, 5376 FULTON DR NW CANTON, OH 44718 By:  Licensed Drain Layer BONTRAGER EXCAVATING Issued By: TJM INC. County Sanitary Engineer: JAMES F. TROIKE, P.E.	Sewer District 16 Project No: _____ Property is located on the S side (direction) of GLENPOINTE St. between ARLINGTON St. and GLENPOINTE St. Main sewer is in EASEMENT Y, branch is 343 feet (direction) EAST of MH No. 16-1999 at 3RD EAST OF ARLINGTON LATERAL SEWER: House conn. is 10 feet long and end of branch is 343 feet (direction) EAST of MH No. 16-1999 and is approx. 11.0 feet deep. Height above Downstream Manhole Flowline: _____ Service sewer: 6 inch PVC pipe Sewer Book No. 5 Page 643 Wye Book No. 10 Page 185
--	---

Notes: FLOWLINE IS 2.64' ABOVE DOWNSTREAM MH 16-1999 FLOWLINE

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of MASSILLON

DISTRIBUTION OF COPIES: White (County) Yellow (Contractor) Pink (City) Gold (Inspection Dept.)



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

Permit for Sewer Connection


Permit No. 48426

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation thereof, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.

Address: 3822 OLD HICKORY NW  
Lot: 11  
Parcel: 10006700  
Subdivision: GLENDALE VILLAGE #1  
Township: JACKSON SW 26  
Area Charge: 2,000.00  
Local Charge: 0.00 (if app.)  
Permit Fee: 50.00  
Connection Charge: 2,050.00 (Total)  
Installation:  
Payments: Check #35396 07/05/2016  
Usage: SINGLE FAMILY RES 1 HOUSE/S  
Date of Issuance: 07/05/2016 (Expires in 365 Days)  
Owner of Property Described:  
REGAL CONSTR CO,  
7056 MEARS GATE DR NW  
N CANTON, OH 44720  
By:   
Licensed Drain Layer MALAVITE EXCAVATING,  
Issued By: TJM INC.  
County Sanitary Engineer: JAMES F. TROIKE, P.E.

Sewer District 25 Project No: \_\_\_\_\_  
Property is located on the E side (direction)  
of OLD HICKORY St.  
between MARZILLI St.  
and END OF ST St.  
Main sewer is in OLD HICKORY  
Y, branch is 204 feet  
(direction) NORTH  
of MH No. 25-1128  
at 1ST NORTH OF MARZILLI  
LATERAL SEWER:  
House conn. is 16 feet long and  
end of branch is 204 feet  
(direction) NORTH  
of MH No. 25-1128  
and is approx. 8.0 feet deep.  
Height above  
Downstream Manhole Flowline: \_\_\_\_\_  
Service sewer: 6 inch PVC pipe  
Sewer Book No. 8 Page 252  
Wye Book No. 8 Page 350

Notes: FLOWLINE IS 8.95' ABOVE DOWNSTREAM MH 25-1128 FLOWLINE

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of MASSILLON

DISTRIBUTION OF COPIES: White (County) Yellow (Contractor) Pink (City) Gold (Inspection Dept.)



**STARK COUNTY METROPOLITAN SEWER DISTRICT**  
**SANITARY ENGINEERING DEPARTMENT**

**Permit for Sewer Connection**

**Permit No. 48427**

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation thereof, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

**The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.**

<p>Address: <u>3857 OLD HICKORY NW</u></p> <p>Lot: <u>5</u></p> <p>Parcel: <u>10006693</u></p> <p>Subdivision: <u>GLENDALE VILLAGE #1</u></p> <p>Township: <u>JACKSON SW 26</u></p> <p>Area Charge: <u>2,000.00</u></p> <p>Local Charge: <u>0.00</u> (if app.)</p> <p>Permit Fee: <u>50.00</u></p> <p>Connection Charge: <u>2,050.00</u> (Total)</p> <p>Installation: _____</p> <p>Payments: Check #35396 07/05/2016</p> <p>Usage: <u>SINGLE FAMILY RES 1 HOUSE/S</u></p> <p>Date of Issuance: <u>07/05/2016</u> (Expires in 365 Days)</p> <p>Owner of Property Described: REGAL CONSTR CO, 7056 MEARS GATE DR NW N CANTON, OHIO 44720</p> <p>By: <u>[Signature]</u> Licensed Drain Layer MALAVITE EXCAVATING, Issued By: TJM INC.</p> <p>County Sanitary Engineer: JAMES F. TROIKE, P.E.</p>	<p>Sewer District <u>25</u> Project No: _____</p> <p>Property is located on the <u>W</u> side (direction) of <u>OLD HICKORY</u> St. between <u>MARZILLI</u> St. and <u>END OF ST</u> St.</p> <p>Main sewer is in <u>OLD HICKORY</u> Y, branch is <u>186</u> feet (direction) <u>NORTH</u> of MH No. <u>25-1129</u> at <u>2ND NORTH OF MARZILLI</u></p> <p>LATERAL SEWER: House conn. is <u>53</u> feet long and end of branch is <u>186</u> feet (direction) <u>NORTH</u> of MH No. <u>25-1129</u> and is approx. <u>8.5</u> feet deep. Height above _____</p> <p>Downstream Manhole Flowline: _____</p> <p>Service sewer: <u>6</u> inch <u>PVC</u> pipe</p> <p>Sewer Book No. <u>8</u> Page <u>252</u></p> <p>Wye Book No. <u>8</u> Page <u>350</u></p>
---	--

Notes: FLOWLINE IS 8.41' ABOVE DOWNSTREAM MH 25-1129 FLOWLINE

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of MASSILLON

DISTRIBUTION OF COPIES: White (County) Yellow (Contractor) Pink (City) Gold (Inspection Dept.)



**STARK COUNTY METROPOLITAN SEWER DISTRICT**  
**SANITARY ENGINEERING DEPARTMENT**

**Permit for Sewer Connection**

**Permit No. 48434**

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation thereof, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

**The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.**

Address: <u>9316 BROADLAND NW</u>	Sewer District <u>16</u> Project No: _____
Lot: <u>62</u>	Property is located on the <u>S</u> side (direction)
Parcel: <u>16-29787</u>	of <u>BROADLAND</u> St.
Subdivision: <u>HUNTERS CHASE #2</u>	between <u>WILD FOX RUN</u> St.
Township: <u>JACKSON SE 7</u>	and <u>MOSSY OAKS</u> St.
Area Charge: <u>2,000.00</u>	Main sewer is in <u>BROADLAND</u>
Local Charge: <u>0.00</u> (if app.)	Y, branch is <u>15</u> feet
Permit Fee: <u>50.00</u>	(direction) <u>WEST</u>
Connection Charge: <u>2,050.00</u> (Total)	of MH No. <u>16-1422</u>
Installation: _____	at <u>1ST WEST OF WILD FOX</u>
Payments: Check #38587 07/12/2016	<u>RUN</u>
Usage: <u>SINGLE FAMILY RES 1 HOUSE/S</u>	LATERAL SEWER: _____
	House conn. is <u>39</u> feet long and
	end of branch is <u>15</u> feet
	(direction) <u>WEST</u>
	of MH No. <u>16-1422</u>
	and is approx. <u>9.0</u> feet deep.
	Height above _____
	Downstream Manhole Flowline: _____
	Service sewer: <u>6</u> inch <u>PVC</u> pipe
	Sewer Book No. <u>5</u> Page <u>514</u>
	Wye Book No. <u>10</u> Page <u>336</u>
Date of Issuance: <u>07/12/2016</u> (Expires in 365 Days)	
Owner of Property Described: <u>REA BLDG CORP</u> <u>8230 LUTZ AVE NW</u> <u>MASSILLON, OH 44646</u>	
By: <u>[Signature]</u> Licensed Drain Layer <u>MALAVITE EXCAVATING, INC.</u>	
Issued By: <u>RLH</u>	
County Sanitary Engineer: <u>JAMES F. TROIKE, P.E.</u>	
Notes: FLOWLINE IS 1.39' ABOVE DOWNSTREAM MH #16-1422 FLOWLINE	
Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of <u>MASSILLON</u>	

DISTRIBUTION OF COPIES: White (County) Yellow (Contractor) Pink (City) Gold (Inspection Dept.)



**STARK COUNTY METROPOLITAN SEWER DISTRICT**  
**SANITARY ENGINEERING DEPARTMENT**

## Permit for Sewer Connection

Permit No. 48430

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation thereof, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

**The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.**

Address: 9635 EMERALD HILL NW Lot: 422 Parcel: 10007410 Subdivision: EMERALD ESTATES #11 Township: JACKSON SW 07  Area Charge: 2,000.00 Local Charge: 0.00 (if app.) Permit Fee: 50.00 Connection Charge: 2,050.00 (Total) Installation: Payments: Check #937631 07/11/2016  Usage: SINGLE FAMILY RES_ 1 HOUSE/S  Date of Issuance: 07/11/2016 (Expires in 365 Days) Owner of Property Described: NVR/RYAN HOMES, 6770 SNOWVILLE RD BRECKSVILLE, OH 44141  By: _____ Licensed Drain Layer CARR EXCAVATING LLC  Issued By: TJM  County Sanitary Engineer: JAMES F. TROIKE, P.E.	Sewer District 16 Project No: _____ Property is located on the N side (direction) of EMERALD HILL St. between AT EMERALD BAY St. and _____ St. Main sewer is in EMERALD HILL Y, branch is 26 feet (direction) E of MH No. MH16-2057 at EMERALD BAY  LATERAL SEWER: House conn. is 45 feet long and end of branch is 26 feet (direction) E of MH No. 16-2057 and is approx. 11.0 feet deep. Height above Downstream Manhole Flowline: 1.33 Service sewer: 6 inch PVC pipe Sewer Book No. 5 Page 655 Wye Book No. 10 Page 362
--	--

Notes: FL 1.33 VF ABOVE DSMH 16-2057 FL

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of MASSILLON

DISTRIBUTION OF COPIES: White (County) Yellow (Contractor) Pink (City) Gold (Inspection Dept.)



**STARK COUNTY METROPOLITAN SEWER DISTRICT**  
**SANITARY ENGINEERING DEPARTMENT**

## Permit for Sewer Connection

Permit No. 48431

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation thereof, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

**The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.**

Address: 7124 EMERALD BAY NW Lot: 437 Parcel: 10007416 Subdivision: EMERALD ESTATES #11 Township: JACKSON SW 7 Area Charge: 2,000.00 Local Charge: 0.00 (if app.) Permit Fee: 50.00 Connection Charge: 2,050.00 (Total) Installation: Payments: Check #937632 07/11/2016 Usage: SINGLE FAMILY RES 1 HOUSE/S Date of Issuance: 07/11/2016 (Expires in 365 Days) Owner of Property Described: RYAN HOMES 6770 SNOWVILLE RD BRECKSVILLE, OH 44141 By: [Signature] Licensed Drain Layer Issued By: RLH County Sanitary Engineer: JAMES F. TROIKE, P.E.	Sewer District 16 Project No: _____ Property is located on the E side (direction) of EMERALD BAY St. between AT EMERALD HILL St. and _____ St. Main sewer is in EMERALD BAY Y, branch is 305 feet (direction) NORTH of MH No. 16-2056 at 1ST SOUTH OF EMERALD HILL LATERAL SEWER: House conn. is 35 feet long and end of branch is 305 feet (direction) NORTH of MH No. 16-2056 and is approx. 11.0 feet deep. Height above Downstream Manhole Flowline: 5.13 Service sewer: 6 inch PVC pipe Sewer Book No. 5 Page 655 Wye Book No. 10 Page 314
---	--

Notes: NEW HOME

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of MASSILLON

DISTRIBUTION OF COPIES: White (County) Yellow (Contractor) Pink (City) Gold (Inspection Dept.)



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

Permit for Sewer Connection

Permit No. 48435

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation thereof, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.

Address: 5064 DRESDEN NW	Sewer District 25 Project No: _____
Lot: 76	Property is located on the S side (direction)
Parcel: 4313939	of DRESDEN St.
Subdivision: ARDMORE ALL'T #2	between WORTHINGTON St.
Township: PERRY NE 02	and SAXONY St.
Area Charge: 0.00	Main sewer is in DRESDEN
Local Charge: 0.00 (if app.)	Y, branch is STUB feet
Permit Fee: 50.00	(direction) IN
Connection Charge: 50.00 (Total)	of MH No. 25-283
Installation: Payments: Check #5855 07/13/2016	at WORTHINGTON
Usage: SINGLE FAMILY RES 1 HOUSE/S	LATERAL SEWER: House conn. is feet long and
Date of Issuance: 07/13/2016 (Expires in 365 Days)	end of branch is feet
Owner of Property Described: MATASICH, STEPHEN E, D/ 5064 DRESDEN DR NW CANTON, OH 44708	(direction) of MH No.
By: [Signature] Licensed Drain Layer PLUMBING 911, INC.	and is approx. feet deep.
Issued By: TJM	Height above
County Sanitary Engineer: JAMES F. TROIKE, P.E.	Downstream Manhole Flowline: Service sewer: 6 inch PVC pipe
	Sewer Book No. 8 Page
	Wye Book No. Page

Notes: REROUTING SEWER; PREV PERMIT #25-991

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of

DISTRIBUTION OF COPIES: White (County) Yellow (Contractor) Pink (City) Gold (Inspection Dept.)



**STARK COUNTY METROPOLITAN SEWER DISTRICT**  
**SANITARY ENGINEERING DEPARTMENT**

**Permit for Sewer Connection**

**Permit No. 48438**

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation thereof, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

**The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.**

<p>Address: <u>3033 CROSS CREEK SW</u></p> <p>Lot: <u>29</u></p> <p>Parcel: <u>7206958</u></p> <p>Subdivision: <u>HUNTERS POINTE DEV</u></p> <p>Township: <u>TUSC SE 24</u></p> <p>Area Charge: <u>2,000.00</u></p> <p>Local Charge: <u>0.00</u> (if app.)</p> <p>Permit Fee: <u>50.00</u></p> <p>Connection Charge: <u>2,050.00</u> (Total)</p> <p>Installation: _____</p> <p>Payments: Check #5007 07/18/2016</p> <p>Usage: <u>SINGLE FAMILY RES</u> <u>1</u> HOUSE/S</p> <p>Date of Issuance: <u>07/18/2016</u> (Expires in 365 Days)</p> <p>Owner of Property Described: <u>HUNTERS POINTE DEV E,</u> <u>1670 AKRON PENINSULA RD, STE 1C</u> <u>AKRON, OH 44313</u></p> <p>By: _____ Licensed Drain Layer <u>BONTRAGER EXCAVATING</u></p> <p>Issued By: <u>TJM</u> <u>INC.</u></p> <p>County Sanitary Engineer: <u>JAMES F. TROIKE, P.E.</u></p> <p>Notes: _____</p>	<p>Sewer District <u>27</u> Project No: _____</p> <p>Property is located on the <u>W</u> side (direction) of <u>CROSS CREEK</u> St. between <u>HUNTERS WAY</u> St. and <u>N CUL-DE-SAC</u> St.</p> <p>Main sewer is in <u>WEST SIDE CROSS CREEK E.</u> Y, branch is <u>64</u> feet (direction) <u>SOUTH</u> of MH No. <u>27-195</u> at <u>1ST NORTH OF HUNTERS WAY</u></p> <p>LATERAL SEWER: House conn. is <u>14</u> feet long and end of branch is <u>64</u> feet (direction) <u>SOUTH</u> of MH No. <u>27-195</u> and is approx. <u>8.5</u> feet deep. Height above Downstream Manhole Flowline: <u>1.50</u></p> <p>Service sewer: <u>6</u> inch <u>PVC</u> pipe</p> <p>Sewer Book No. <u>7</u> Page <u>51</u></p> <p>Wye Book No. <u>11</u> Page <u>231</u></p>
--	---

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of MASSILLON

DISTRIBUTION OF COPIES: White (County) Yellow (Contractor) Pink (City) Gold (Inspection Dept.)



**STARK COUNTY METROPOLITAN SEWER DISTRICT**  
**SANITARY ENGINEERING DEPARTMENT**

**Permit for Sewer Connection**

**Permit No. 48442**

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation thereof, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

**The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.**

Address: <u>7431 MONTELLA NW</u> Lot: <u>403</u> Parcel: <u>10006220</u> Subdivision: <u>EMERALD ESTATES #10</u> Township: <u>JACKSON NE 07</u> Area Charge: <u>2,000.00</u> Local Charge: <u>0.00</u> (if app.) Permit Fee: <u>50.00</u> Connection Charge: <u>2,050.00</u> (Total) Installation: <u>Payments: Check #50574982 07/19/2016</u> Usage: <u>SINGLE FAMILY RES 1 HOUSE/S</u> Date of Issuance: <u>07/19/2016</u> (Expires in 365 Days) Owner of Property Described: <u>PULTE HOMES OF OHIO LLC</u> <u>11590 N MERIDIAN ST, STE 530</u> <u>CARMEL, IN 46032</u> By: <u>Melissa Muli</u> Licensed Drain Layer <u>SCHNEIDER ELECTRIC &amp;</u> Issued By: <u>TJM</u> <u>PLMG INC</u> County Sanitary Engineer: <u>JAMES F. TROIKE, P.E.</u>	Sewer District <u>16</u> Project No: _____ Property is located on the <u>W</u> side (direction) of <u>MONTELLA</u> St. between <u>EMERALD ISLE</u> St. and <u>S MONTELLA CUL-DE-SA</u> St. Main sewer is in <u>R/W W SIDE OF MONTELLA</u> Y, branch is <u>91</u> feet (direction) <u>S</u> of MH No. <u>16-1490</u> at <u>1ST SOUTH OF EMERALD ISLE</u> LATERAL SEWER: House conn. is <u>18</u> feet long and end of branch is <u>91</u> feet (direction) <u>S</u> of MH No. <u>16-1490</u> and is approx. <u>9.0</u> feet deep. Height above Downstream Manhole Flowline: _____ Service sewer: <u>6</u> inch <u>PVC</u> pipe Sewer Book No. <u>5</u> Page <u>595</u> Wye Book No. <u>10</u> Page <u>375</u>
---	---

**Notes:**

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of MASSILLON

DISTRIBUTION OF COPIES: White (County) Yellow (Contractor) Pink (City) Gold (Inspection Dept.)



**STARK COUNTY METROPOLITAN SEWER DISTRICT**  
**SANITARY ENGINEERING DEPARTMENT**

**Permit for Sewer Connection**

**Permit No. 48445**

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation thereof, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

**The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.**

<p>Address: <u>7162 EMERALD MARSH NW</u></p> <p>Lot: <u>433</u></p> <p>Parcel: <u>10007402</u></p> <p>Subdivision: <u>EMERALD ESTATES #11</u></p> <p>Township: <u>JACKSON SW 7</u></p> <p>Area Charge: <u>2,000.00</u></p> <p>Local Charge: <u>0.00</u> (if app.)</p> <p>Permit Fee: <u>50.00</u></p> <p>Connection Charge: <u>2,050.00</u> (Total)</p> <p>Installation: <u>Payments: Check #937730 07/21/2016</u></p> <p>Usage: <u>SINGLE FAMILY RES 1 HOUSE/S</u></p> <p>Date of Issuance: <u>07/21/2016</u> (Expires in 365 Days)</p> <p>Owner of Property Described: <u>RYAN HOMES</u> <u>6770 SNOWVILLE RD</u> <u>BRECKSVILLE, OH 44141</u></p> <p>By: <u>CARR EXCAVATING LLC</u> <small>Licensed Drain Layer</small></p> <p>Issued By: <u>RLH</u></p> <p>County Sanitary Engineer: <u>JAMES F. TROIKE, P.E.</u></p>	<p>Sewer District <u>16</u> Project No: _____</p> <p>Property is located on the <u>E</u> side (direction) of <u>EMERALD MARSH</u> St. between <u>EMERALD HILL</u> St. and <u>CUL-DE-SAC</u> St.</p> <p>Main sewer is in <u>EMERALD MARSH</u></p> <p>Y, branch is <u>114</u> feet (direction) <u>N</u> of MH No. <u>16-2058</u> at <u>EMERALD HILL</u></p> <p>LATERAL SEWER: House conn. is <u>45</u> feet long and end of branch is <u>114</u> feet (direction) <u>N</u> of MH No. <u>16-2058</u> and is approx. <u>10.0</u> feet deep. Height above Downstream Manhole Flowline: <u>7.10</u></p> <p>Service sewer: <u>6</u> inch <u>PVC</u> pipe</p> <p>Sewer Book No. <u>5</u> Page <u>655</u></p> <p>Wye Book No. <u>10</u> Page <u>361</u></p>
---	--

Notes: FL IS 7.10 VF ABOVE DSMH 16-2058 FL

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of MASSILLON

DISTRIBUTION OF COPIES: White (County) Yellow (Contractor) Pink (City) Gold (Inspection Dept.)



**STARK COUNTY METROPOLITAN SEWER DISTRICT**  
**SANITARY ENGINEERING DEPARTMENT**

**Permit for Sewer Connection**

**Permit No. 48450**

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation thereof, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

**The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.**

<p>Address: <u>7203 EMERALD MARSH NW</u></p> <p>Lot: <u>428</u></p> <p>Parcel: <u>10007412</u></p> <p>Subdivision: <u>EMERALD ESTATES #11</u></p> <p>Township: <u>JACKSON SW 07</u></p> <p>Area Charge: <u>2,000.00</u></p> <p>Local Charge: <u>0.00</u> (if app.)</p> <p>Permit Fee: <u>50.00</u></p> <p>Connection Charge: <u>2,050.00</u> (Total)</p> <p>Installation: <u>Payments: Check #937789 07/27/2016</u></p> <p>Usage: <u>SINGLE FAMILY RES 1 HOUSE/S</u></p> <p>Date of Issuance: <u>07/27/2016</u> (Expires in 365 Days)</p> <p>Owner of Property Described: <u>NVR/RYAN HOMES,</u> <u>6770 SNOWVILLE RD</u> <u>BRECKSVILLE, OH 44141</u></p> <p>By: <u>CARR EXCAVATING LLC</u> <small>Licensed Drain Layer</small></p> <p>Issued By: <u>TJM</u></p> <p>County Sanitary Engineer: <u>JAMES F. TROIKE, P.E.</u></p> <p>Notes: <u>FL 2.09 VF ABOVE DSMH 16-2060 FL</u></p>	<p>Sewer District <u>16</u> Project No: _____</p> <p>Property is located on the <u>N</u> side (direction) of <u>EMERALD MARSH</u> St. between <u>AT CUL-DE-SAC</u> St. and _____ St.</p> <p>Main sewer is in <u>EMERALD MARSH</u> Y, branch is <u>STUB</u> feet (direction) _____ of MH No. <u>16-2060</u> at <u>CUL-DE-SAC</u></p> <p>LATERAL SEWER: House conn. is <u>68</u> feet long and end of branch is <u>66</u> feet (direction) <u>N</u> of MH No. <u>16-2060</u> and is approx. <u>9.0</u> feet deep. Height above Downstream Manhole Flowline: <u>2.09</u></p> <p>Service sewer: <u>6</u> inch <u>PVC</u> pipe</p> <p>Sewer Book No. <u>5</u> Page <u>655</u></p> <p>Wye Book No. <u>10</u> Page <u>361</u></p>
---	--

DISTRIBUTION OF COPIES: White (County) Yellow (Contractor) Pink (City) Gold (Inspection Dept.)



**STARK COUNTY METROPOLITAN SEWER DISTRICT**  
**SANITARY ENGINEERING DEPARTMENT**

**Permit for Sewer Connection**

**Permit No. 48446**

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation thereof, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

**The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.**

<p>Address: <u>10038 STRAUSSER NW</u></p> <p>Lot: <u>225</u></p> <p>Parcel: <u>16-28085</u></p> <p>Subdivision: <u>EMERALD ESTATES #6A</u></p> <p>Township: <u>JACKSON NW 7</u></p> <p>Area Charge: <u>2,000.00</u></p> <p>Local Charge: <u>0.00</u> (if app.)</p> <p>Permit Fee: <u>50.00</u></p> <p>Connection Charge: <u>2,050.00</u> (Total)</p> <p>Installation: _____</p> <p>Payments: Check # <u>07/21/2016</u></p> <p>Usage: <u>SINGLE FAMILY RES</u> <u>1</u> HOUSE/S</p> <p>Date of Issuance: <u>07/21/2016</u> (Expires in 365 Days)</p> <p>Owner of Property Described: <u>RYAN HOMES</u> <u>6770 SNOWVILLE RD</u> <u>BRECKSVILLE, OH 44141</u></p> <p>By: _____ Licensed Drain Layer <u>CARR EXCAVATING LLC</u></p> <p>Issued By: <u>TJM</u></p> <p>County Sanitary Engineer: <u>JAMES F. TROIKE, P.E.</u></p>	<p>Sewer District <u>16</u> Project No: _____</p> <p>Property is located on the <u>S</u> side (direction) of <u>STRAUSSER</u> St.</p> <p>between <u>HIGHMILL</u> St. and <u>GALENA</u> St.</p> <p>Main sewer is in <u>NORTH R/W STRAUSSER</u></p> <p>Y, branch is <u>172</u> feet (direction) <u>WEST</u></p> <p>of MH No. <u>16-1555</u></p> <p>at <u>2ND EAST OF HIGHMILL</u></p> <p>LATERAL SEWER: House conn. is <u>66</u> feet long and end of branch is <u>172</u> feet (direction) <u>WEST</u></p> <p>of MH No. <u>16-1555</u></p> <p>and is approx. <u>9.0</u> feet deep.</p> <p>Height above _____</p> <p>Downstream Manhole Flowline: _____</p> <p>Service sewer: <u>6</u> inch <u>PVC</u> pipe</p> <p>Sewer Book No. <u>5</u> Page <u>499</u></p> <p>Wye Book No. <u>6</u> Page <u>77</u></p>
---	--

Notes: FLOWLINE IS 9.35 FEET ABOVE DS MH#9.35 FLOWLINE

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of MASSILLON

DISTRIBUTION OF COPIES: White (County) Yellow (Contractor) Pink (City) Gold (Inspection Dept.)



**STARK COUNTY METROPOLITAN SEWER DISTRICT**  
**SANITARY ENGINEERING DEPARTMENT**

**Permit for Sewer Connection**

**Permit No. 48457**

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation thereof, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

**The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.**

<p>Address: <u>7262 MONTELLA NW</u></p> <p>Lot: <u>411</u></p> <p>Parcel: <u>10006215</u></p> <p>Subdivision: <u>EMERALD ESTATES #10</u></p> <p>Township: <u>JACKSON NE 07</u></p> <p>Area Charge: <u>2,000.00</u></p> <p>Local Charge: <u>0.00</u> (if app.)</p> <p>Permit Fee: <u>50.00</u></p> <p>Connection Charge: <u>2,050.00</u> (Total)</p> <p>Installation: <u>Payments: Check #50575360 08/04/2016</u></p> <p>Usage: <u>SINGLE FAMILY RES 1 HOUSE/S</u></p> <p>Date of Issuance: <u>08/04/2016</u> (Expires in 365 Days)</p> <p>Owner of Property Described: <u>MIRAMAR, VILLA</u> <u>6800 FREEDOM AVE. NW</u> <u>NORTH CANTON, OH 44720</u></p> <p>By: <u>Melhor Mella</u> Licensed Drain Layer <u>SCHNEIDER ELECTRIC &amp;</u></p> <p>Issued By: <u>RLH</u> <u>PLMG INC</u></p> <p>County Sanitary Engineer: <u>JAMES F. TROIKE, P.E.</u></p>	<p>Sewer District <u>16</u> Project No: _____</p> <p>Property is located on the <u>S</u> side (direction) of <u>MONTELLA</u> St. between <u>WEST END OF MONTELLA St.</u> and <u>S MONTELLA CUL-DE-SA St.</u></p> <p>Main sewer is in <u>R/W N SIDE OF MONTELLA</u> Y, branch is <u>180</u> feet (direction) <u>E</u> of MH No. <u>16-1462</u> at <u>WEST END MONTELLA</u></p> <p>LATERAL SEWER: House conn. is <u>52</u> feet long and end of branch is <u>180</u> feet (direction) <u>E</u> of MH No. <u>16-1462</u> and is approx. <u>10.0</u> feet deep. Height above</p> <p>Downstream Manhole Flowline: _____</p> <p>Service sewer: <u>6</u> inch <u>PVC</u> pipe</p> <p>Sewer Book No. <u>5</u> Page <u>596</u></p> <p>Wye Book No. <u>10</u> Page <u>376</u></p>
---	---

**Notes:**

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of MASSILLON

DISTRIBUTION OF COPIES: White (County)

Yellow (Contractor)

Pink (City)

Gold (Inspection Dept.)



**STARK COUNTY METROPOLITAN SEWER DISTRICT**  
**SANITARY ENGINEERING DEPARTMENT**

**Permit for Sewer Connection**

**Permit No. 48458**

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation thereof, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

**The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.**

<p>Address: <u>7240 MONTELLA NW</u></p> <p>Lot: <u>410</u></p> <p>Parcel: <u>10006223</u></p> <p>Subdivision: <u>EMERALD ESTATES #10</u></p> <p>Township: <u>JACKSON NE 07</u></p> <p>Area Charge: <u>2,000.00</u></p> <p>Local Charge: <u>0.00</u> (if app.)</p> <p>Permit Fee: <u>50.00</u></p> <p>Connection Charge: <u>2,050.00</u> (Total)</p> <p>Installation: <u>Payments: Check #50575405 08/04/2016</u></p> <p>Usage: <u>SINGLE FAMILY RES 1 HOUSE/S</u></p> <p>Date of Issuance: <u>08/04/2016</u> (Expires in 365 Days)</p> <p>Owner of Property Described: <u>MIRAMAR, VILLA</u> <u>6800 FREEDOM AVE. NW</u> <u>NORTH CANTON, OH 44720</u></p> <p>By: <u>[Signature]</u> Licensed Drain Layer <u>SCHNEIDER ELECTRIC &amp;</u></p> <p>Issued By: <u>RLH</u> <u>PLMG INC</u></p> <p>County Sanitary Engineer: <u>JAMES F. TROIKE, P.E.</u></p>	<p>Sewer District <u>16</u> Project No: _____</p> <p>Property is located on the <u>S</u> side (direction) of <u>MONTELLA</u> St. between <u>WEST END OF MONTELLA St.</u> and <u>MONTELLA S CUL-DE SA St.</u></p> <p>Main sewer is in <u>R/W N SIDE MONTELLA</u> Y, branch is <u>72</u> feet (direction) <u>E</u> of MH No. <u>16-1462</u> at <u>WEST DEAD END OF MONTELLA</u></p> <p>LATERAL SEWER: House conn. is <u>52</u> feet long and end of branch is <u>72</u> feet (direction) <u>E</u> of MH No. <u>16- 1462</u> and is approx. <u>10.0</u> feet deep. Height above</p> <p>Downstream Manhole Flowline: _____</p> <p>Service sewer: <u>6</u> inch <u>PVC</u> pipe</p> <p>Sewer Book No. <u>5</u> Page <u>596</u></p> <p>Wye Book No. <u>10</u> Page <u>376</u></p>
--	---

**Notes:**

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of MASSILLON

DISTRIBUTION OF COPIES: White (County) Yellow (Contractor) Pink (City) Gold (Inspection Dept.)



**STARK COUNTY METROPOLITAN SEWER DISTRICT**  
**SANITARY ENGINEERING DEPARTMENT**

**Permit for Sewer Connection**

**Permit No. 48471**

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation thereof, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

**The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.**

<p>Address: <u>7605 ROLLING GREEN NW</u></p> <p>Lot: <u>14</u></p> <p>Parcel: <u>16-28251</u></p> <p>Subdivision: <u>ROLLING GREEN #1</u></p> <p>Township: <u>JACKSON NW 8</u></p> <p>Area Charge: <u>2,000.00</u></p> <p>Local Charge: <u>0.00</u> (if app.)</p> <p>Permit Fee: <u>50.00</u></p> <p>Connection Charge: <u>2,050.00</u> (Total)</p> <p>Installation: <u>Payments: Check #3508 08/29/2016</u></p> <p>Usage: <u>SINGLE FAMILY RES 1 HOUSE/S</u></p> <p>Date of Issuance: <u>08/29/2016</u> (Expires in 365 Days)</p> <p>Owner of Property Described: <u>AURORA CUSTOM HOMES,</u> <u>PO BOX 35365</u> <u>CANTON, OHIO 44720</u></p> <p>By: <u>[Signature]</u> Licensed Drain Layer <u>BACHTEL EXCAVATING,</u> Issued By: <u>SJB</u> <u>INC.</u></p> <p>County Sanitary Engineer: <u>JAMES F. TROIKE, P.E.</u></p>	<p>Sewer District <u>16</u> Project No: _____</p> <p>Property is located on the <u>W</u> side (direction) of <u>ROLLING GREEN</u> St. between <u>AT IRONS</u> St. and _____ St.</p> <p>Main sewer is in <u>IRONS</u> Y, branch is <u>141</u> feet (direction) <u>WEST</u> of MH No. <u>16-1837</u> at <u>ROLLING GREEN</u></p> <p>LATERAL SEWER: House conn. is <u>22</u> feet long and end of branch is <u>141</u> feet (direction) <u>WEST</u> of MH No. <u>16-1837</u> and is approx. <u>10.5</u> feet deep. Height above _____</p> <p>Downstream Manhole Flowline: _____</p> <p>Service sewer: <u>6</u> inch <u>PVC</u> pipe</p> <p>Sewer Book No. <u>5</u> Page <u>601</u></p> <p>Wye Book No. <u>10</u> Page <u>133</u></p>
--	---

Notes: FLOWLINE IS 0.98 FEET ABOVE DS MH#16-1837 FLOWLINE

Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of MASSILLON

DISTRIBUTION OF COPIES: White (County) Yellow (Contractor) Pink (City) Gold (Inspection Dept.)



STARK COUNTY METROPOLITAN SEWER DISTRICT  
SANITARY ENGINEERING DEPARTMENT

Permit for Sewer Connection

Permit No. 48473

I understand that the connection charge shown below was calculated based on information furnished to your office by me. Further, I understand that if, subsequent to the issuance of a permit and/or connection completion and approval, the use of the serviced premises changes, additional applicable connection charges will be levied in accordance with the regulations of the Stark County Metropolitan Sewer District.

The undersigned hereby applies to construct a sewer connection from the premises described to the sewer and branch mentioned, and agrees that the construction and use of such sewer shall be strictly in accordance with the rules and regulations of the County Sanitary Engineering Department. I/we agree that I/we will be responsible for any damage or claims of any nature arising out of the construction of said connection, or the excavation thereof, and will warrant and defend the County of Stark, its Officers and Agents, against all such damages or claims, that I/we furnish and maintain proper barricades and lights for the protection of the public and that I/we will immediately refill and resurface all excavations and all settlements, and will pay to the County, the cost of any clearing up, removal of dirt or rubbish, refilling or resurfacing ordered or done by the County, over or around the excavation for this connection, within one year of acceptance of this work.

I/we specifically agree that no roof or footer drains, surface water or other prohibited waste shall be discharged into this connection.

The application and permit expire one year from the date of issuance. A fee of \$ 50.00 and the difference between area charges from the time of issuance to the time of re-issuance will be due in order to renew the application and permit.

Address: 3836 OLD HICKORY NW	Sewer District 25 Project No: _____
Lot: 10	Property is located on the E side (direction)
Parcel: 10006686	of OLD HICKORY St.
Subdivision: GLENDALE VILLAGE #1	between MARZILLI St.
Township: JACKSON SW 26	and END OF ST St.
Area Charge: 0.00	Main sewer is in OLD HICKORY
Local Charge: 0.00 (if app.)	Y, branch is 72 feet
Permit Fee: 0.00	(direction) NORTH
Connection Charge: 0.00 (Total)	of MH No. 25-1129
Installation: Payments: Check # 08/29/2016	at 2ND NORTH OF MARZILLI
Usage: SINGLE FAMILY RES 1 HOUSE/S	LATERAL SEWER: House conn. is 17 feet long and
Date of Issuance: 08/29/2016 (Expires in 365 Days)	end of branch is 72 feet
Owner of Property Described: CONSTRUCTION, REGAL 7056 MEARS GATE NW N. CANTON, OH 44720	(direction) NORTH
By: <i>[Signature]</i> Licensed Drain Layer	of MH No. 25-1129
Issued By: SJB	and is approx. 8.5 feet deep.
County Sanitary Engineer: JAMES F. TROIKE, P.E.	Height above Downstream Manhole Flowline: _____
	Service sewer: 6 inch PVC pipe
	Sewer Book No. 8 Page 252
	Wye Book No. 8 Page 350
Notes: FL IS 3.93' ABOVE DOWNSTREAM MH 25-1129 FL; MONEY TRANSFERRED FROM PERMIT #48427	
Permission is hereby granted for the sewer connection, above described, to be constructed under the conditions stated. Fee of \$50.00 received. This sewer discharges into the sewers of MASSILLON	
DISTRIBUTION OF COPIES: White (County) Yellow (Contractor) Pink (City) Gold (Inspection Dept.)	