



5 January 2009

Abandon & Seal An Existing Pipe

Procedures and specifications to abandon in place an existing pipe at Station _____ shall be as follows: The existing pipe shall be completely filled with a shrinkage-compensating grout meeting the requirements of ASTM C-1107 such as SIKA 212, Edoco Grout or approved equal (see information below for the Specs on these products). The line shall be completely filled; the quantity of grout required to fill the pipe should be determined in advance to equal the volume of the inside of the pipe for its full length between the inlet and outlet headwalls. Filling of the pipe should be monitored and inspected to insure that the pipe has been completely filled for its entire length.

Edoco Grout

http://67.192.65.138/weavecmsresources/c_TechData_sheets/TDS_Edoco2/E_NFNSGrout_TDS.pdf

Sika Grout 212 Grout



SikaGrout212-us.pdf