

DATE: APRIL 7, 2008

CLERK: MARY BETH BAILEY

MASSILLON CITY COUNCIL
CITY OF MASSILLON, OHIO
GLENN E. GAMBER, PRESIDENT

COUNCIL CHAMBERS

LEGISLATIVE DEPARTMENT

ORDINANCE NO. 60 - 2008

BY: ENVIRONMENTAL COMMITTEE

TITLE: AN ORDINANCE amending CHAPTER 925 "SEWERS GENERALLY" of the Codified Ordinances of the City of Massillon, Ohio, by amending Appendix A and adding additional Priority Toxic Pollutants to said appendix, and declaring an emergency.

NOW, THEREFORE, BE IT ORDAINED BY THE COUNCIL OF THE CITY OF MASSILLON, STATE OF OHIO, THAT:

Section 1:

The existing Appendix A of CHAPTER 925 of the Codified Ordinances of the City of Massillon, Ohio, be and hereby is amended by adding additional Priority Toxic Pollutants to said existing appendix which currently contains 126 Priority Toxic Pollutants.

Section 2:

Appendix A of CHAPTER 925 of the Codified Ordinances of the City of Massillon, Ohio, is hereby amended by adding to the existing appendix additional Priority Toxic Pollutants numbered 127 through 137.

(SEE ATTACHED EXHIBIT "A" HERETO)

Section 3:

This ordinance is hereby declared to be an emergency measure, the reason for the emergency being that changes are necessary for keeping the City of Massillon in compliance with the Ohio EPA guidelines for pretreatment. Provided it receives the affirmative vote of two-thirds of the elected members to Council, it shall take effect and be in force immediately upon its passage and approval by the Mayor. Otherwise, it shall take effect and be in force from and after the earliest period allowed by law.

PASSED IN COUNCIL THIS 17th DAY OF April, 2008

ATTEST: Mary Beth Bailey
MARY BETH BAILEY, CLERK OF COUNCIL

Glenn Gamber
GLENN E. GAMBER, PRESIDENT

APPROVED April 8, 2008

Francis H. Cicchinelli, Jr.
FRANCIS H. CICCHINELLI, JR., MAYOR

I hereby certify that the foregoing ordinance
is a true copy of the original, as passed by
the Council of the City of Massillon, Ohio,
and approved as noted thereon:

Mary Beth Bailey
Clerk of Council

Date 4/7/08

APPENDIX A

<u>Pollutant</u>	<u>Limit</u>
127 Arsenic	0.081 mg/l
128 Cadmium	0.457 mg/l
129 Chromium (Total)	22.129 mg/l
130 Chromium (Hexavalent)	2.742 mg/l
131 Copper	1.805 mg/l
132 Cyanide	0.133 mg/l
133 Lead	3.190 mg/l
134 Mercury	0.004 mg/l
135 Nickel	0.816 mg/l
136 Selenium	0.450 mg/l
137 Silver	0.227 mg/l
138 Zinc	1.816 mg/l