

**CITY OF MASSILLON
SATELLITE SEWER DISCHARGE CONTROL PROGRAM**

**PERMIT FOR SANITARY SEWER CONNECTION
(8-inch and Larger)**

Request From : James F. Troike, PE Title Sanitary Engineer Community Stark County
Date : 05/10/2019
Approved By : Jason Popier Title City Engineer, City of Massillon
Date : 5-28-19
Permit No. : 3PE0007 *ND

The community of Stark County hereby applies for a permit to discharge into the City of Massillon's sanitary sewer system. We confirm that the drawings and specifications submitted have been approved by the proper personnel within the Stark County Sanitary Engineering Dept. and will be constructed in accordance with the rules and regulations of the Stark County Sanitary Engineering Dept.

We confirm that no roof and/or footer drains, catch basins, surface water or other prohibited waste is discharged into this connection.

By approval of this permit, we understand that we are are not responsible for installing a meter capable of supporting a telemetry system compatible with the City of Massillon.

Location of Connection: Stark County Sanitary Sewer Mahole #29-247, located near the intersection of Strouble Dr. NW and Everhard Rd. NW.

Size of Connection: 8 inch

Size of Sewer
Connecting Into: 8 inch

Projected Flow: Existing N/A MGD Future 0.0105 MGD Ultimate 0.105 MGD
(Design flow) (Peak Hourly Design flow)
Set of Plans Submitted: (Yes)/No

Meter Required: No Location of Meter: Existing Meter #5

Distributed to: _____ (City Engineer) _____ (Safety & Service Director) _____ (File)

This permit may be waived with the approval of the Safety & Service Director.