

Kathy Catazaro-Perry, Mayor



CITY OF MASSILLON, OHIO

151 LINCOLN WAY EAST
MUNICIPAL GOVERNMENT ANNEX
CITY ADMINISTRATION BUILDING
MASSILLON, OHIO 44646
PHONE 330-830-1722 FAX 330-830-1786

PERMIT DATE:

12/19/2014

PERMIT NO.

201400017

PERMIT TO TAP SANITARY SEWER

This permit is issued subject to the latest Codified Ordinances of the City of Massillon, OH. The City Engineer to be notified 24 hours in advance of start of work (330) 830-1722. All permits issued under this ordinance are void after 120 days from date of issuance.

RECEIVED OF:

PERMIT TYPE Repair

CONTRACTOR INFORMATION

SITE INFORMATION

CONTRACTOR: BLIND & SONS
CONTACT: Giuseppe Bilotta
ADDRESS: 3149 Forest Meadows Dr
CITY: Cuyahoga Falls
STATE: OH
ZIP: 44223-
PHONE: (330) 753-7711
FAX: (330) 753-7522
SURETY: Western Surety

OWNER'S NAME: Elkins
FULL STREET ADDRESS: 154 25th St NW
CITY LOT NUMBER: 13090
PURPOSE OF CUT: Repair
ZONING CLASS:
STREET SIDE: East

PHONE OTHER:

SANITARY SEWER CONNECTION:

USE: Residential

NOTE: This permit covers work outside of the building ONLY. Any work inside walls of the building is subject to the Massillon Board of Health Regulations.

SKETCH: DRAWING #:

DATE INSPECTED 12/22/2014

located on the East side of

25TH ST NW between

CHAUNCY AVE NW and

STANTON AVE SW

Direction from downstream Manhole: SOUTH

Distance from downstream Manhole: 110'

Connection Length: 20.00 (FEET)

Connection Depth: 10 (FEET)

Size of Sewer Pipe: 6 (INCHES)

Pipe Material: PVC

INSPECTORS NAME: JEFF KING

INSPECTION REQUEST: 12/22/14

SANITARY SEWER PERMIT FEE: \$75.00

COMMENTS: LATERAL WAS CLOGGED WITH ROOTS

CAPACITY FEE: \$0.00

TOTAL COST: \$75.00

TWO WORKING DAYS BEFORE YOU DIG
Ohio Utilities Protection Service
Call 1-800-362-2764 Toll Free....
Non-Members must be called directly.

AUTHORIZED BY: DIRECTOR OF PUBLIC SAFETY AND SERVICE

ISSUED BY: Gregory McCue

Manhole

Chauncy Ave

NORTH

Clay sewer main
Flows North

110' from manhole

Edge of pavement (No curb)

House #
160

Driveway

25th Street NW

Existing Lateral

Ferroc

Lateral
10' deep

Ferroc

5' from house

Replaced 20'
of pipe

Big
Maple
Tree

House #
154

