

✓

**FOLLOWING DATA TO BE ANSWERED BY INSPECTOR
AND SIGNED WHEN RETURNED**

Nº 2178

Date Inspected May 27th

House No. 1317 921

Size of pipe used 6 in

Was lateral at curb? No

Was attached to main

Show by diagram relation of lateral to wall of building served.

If so how and location from
first manhole down stream

Distance from first manhole
down stream to ditch at
curb line and depth

Name of Contractor

J. Nish
House

7 1/2 ft - Ø

36 ft pipe from curb to House

12 ft pipe from main to curb

8 ft - Ø

Main Sewer

Euclid St

→ South

Signed A. T. Boyd

Inspector for City

Filed at Engineer's Office MAY 28 1926

Remarks

Old lateral taken up full of sand not laid right joints
not up in bell to match cement in side of pipe

OFFICE OF THE DIRECTOR OF PUBLIC SERVICE

No 2178

PERMIT TO TAP SEWER

Massillon, O.,

May 24th 1921

Received of

fee of \$

for which permission is granted

to tap

sewer, on the

side

of

Ave., the premises being Lot. No. 3243

St.

921

House No. 1317

Work to be done in accordance with Ordinance No. 2323, duly passed

by the City Council, and Rules of the Department of Public Service.

Name of Contractor