

**FOLLOWING DATA TO BE ANSWERED BY INSPECTOR
AND SIGNED WHEN RETURNED**

Nº 2389

3-11

Date Inspected Oct-26

If so how and location from
first manhole down stream

House No. 1407

Distance from first manhole
down stream to ditch at
curb line and depth


Size of pipe used 6 in

Was lateral at curb? 11 8 ft back of curb

Name of Contractor J. Brunker

Was attached to main

Show by diagram relation of lateral to wall of building served.



Signed A. F. Boyd
Inspector for City

Filed at Engineer's Office N Mill St
OCT 27 1926

Remarks lateral connected to lateral 8 ft under pavement 9 ft from
street line on House

THE FOLLOWING DATA TO BE ANSWERED BY INSPECTOR
WHEN SIGNED WHEN RETURNED

OFFICE OF THE DIRECTOR OF PUBLIC SERVICE

No 2389

PERMIT TO TAP SEWER

Massillon, O., Oct 25th 19

Received of Mrs Wilson fee of \$ 2.00

for which permission is granted Jess Brunker

to tap Sanitary sewer, on the West

of No Mill Ave., the premises being Lot. No. 1188
St. 2546

House No. 1407 Work to be done in accordance with Ordinance No. 2323, duly passed

by the City Council, and Rules of the Department of Public Service.

Name of Contractor Jess Brunker