

**FOLLOWING DATA TO BE ANSWERED BY INSPECTOR
AND SIGNED WHEN RETURNED**

5-42

Nº 2901

Date Inspected April 7

If so how and location from
first manhole down stream

House No. New 716

Distance from first manhole
down stream to ditch at
curb line and depth

Size of pipe used 6 in

Was lateral at curb? yes


Name of Contractor

Was attached to main

Show by diagram relation of lateral to wall of building served.

Hortetter

House



Main sewer East →

Signed A. F. Boyd

Inspector for City

Milburn Rd N.E.

Filed at Engineer's Office

APR 9 192

Remarks

lateral connected to lateral at curb 24 ft from strait
This connection laid with pres tite line on House

OFFICE OF THE DIRECTOR OF PUBLIC SERVICE

Nº 2901

PERMIT TO TAP SEWER

Massillon, O., March 30th 1921

Received of Chas. Hostetter fee of \$ 2.00

for which permission is granted Chas. Hostetter

to tap Sanitary sewer, on the W. side

of Millbrook Rd. NE Ave., Type of Street drain

the premises being Lot. No. 8231 7979 House No. 716

Work to be done in accordance with Ordinance No. 2323, duly passed by the City Council, and Rule
the Department of Public Service.

Name of Contractor Hostetter

NOTE. This permit covers work outside of building only. Any work inside walls of building is subject to Massillon Board of Health Regulations.