

**FOLLOWING DATA TO BE ANSWERED BY INSPECTOR
AND SIGNED WHEN RETURNED**

Nº 3164

Date Inspected March 28

I so how and location from
first manhole down stream

House No. 420

Distance from first manhole
down stream to ditch at
curb line and depth



Size of pipe used 4 in

Was lateral at curb? yes

Name of Contractor

Was attached to main

Show by diagram relation of lateral to wall of building served:



Investigation by Jones
opened by Mr Early for
Mr Matthews owner

Job of Early was O.K.
Roots caused the
trouble. S. Jones

Signed

A. H. Boyd

Inspector for City

3rd St N. E

Filed at Engineer's Office

APR 1 192

Remarks:

lateral connected to old line at curb 2 ft. from Str
line on House for cellar drain

OFFICE OF THE DIRECTOR OF PUBLIC SERVICE

No 3164

PERMIT TO TAP SEWER

Massillon, O. March 25th 1911Received of Mrs. Earlyfee of \$ 2.00for which permission is granted David Matthewsto tap Sanitarysewer, on the Eastof 3rd St. N. E.Ave., Type of Street paved

St.,

the premises being Lot No. 249House No. 420

Work to be done in accordance with Ordinance No. 2323, duly passed by the City Council, and Rule No. 1, of the Board of Health, and approved by the Department of Public Service.

Name of Contractor Mrs. Early

NOTE. This permit covers work outside of building only. Any work inside walls of building is subject to Massillon Board of Health Regulations.