

**FOLLOWING DATA TO BE ANSWERED BY INSPECTOR
AND SIGNED WHEN RETURNED**

No 3720

Date Inspected 4-29-35 I so how and location from
first manhole down stream
House No. 1461 Distance from first manhole
down stream to ditch at
Size of pipe used 6" WITH PRESS TITE curb line and depth 6' 50" FROM H.H. AT INGOLD AVE 9' DEE

Was lateral at curb? YES

Name of Contractor Smart

Was attached to main

Show by diagram relation of lateral to wall of building served.

SEWER HAS 1 FOOT FALL
FROM BACK OF HOUSE TO
CURB LINE 64'

9' DEEP FROM
HSE. FND.

9' DEEP

1st CURB

FIRST ST. N.E.

Signed Shertzer Inspector for City

Filed at Engineer's Office

Remarks: connected on to a 6" pipe that drained into cesspool which was discarded

APR 30 1935

NOTE

1461
AVE
INGOLD

56
46

OFFICE OF THE DIRECTOR OF PUBLIC SERVICE

No. 3720

PERMIT TO TAP SEWER

Massillon, O.,

Received of

Frank Lawrence

fee of \$ 2

for which permission is granted

to tap

Sanitary

sewer, on the

West

of

1st St. N. E.

Ave., Type of Street

St.,

Paved

the premises being Lot No.

2842

House No.

1461

Work to be done in accordance with Ordinance No. 2323, duly passed by the City Council, and by the Department of Public Service.

Name of Contractor

Frank Lawrence

NOTE. This permit covers work outside of building only. Any work inside walls of building is subject to Massillon Board of Health Regulations.