

**FOLLOWING DATA TO BE ANSWERED BY INSPECTOR
AND SIGNED WHEN RETURNED**

No. 3727

Date Inspected 5-24-35

I so how and location from first manhole down stream MEASUREMENT FOR CON. O.K.

House No. 1723

Distance from first manhole down stream to ditch at curb line and depth 26.8 FT. FROM M.H. SOUTH 5'-6" DEEP

Size of pipe used 6" WITH TITE

Was lateral at curb? YES - #31


Name of Contractor L.H. SMART

Was attached to main

Show by diagram relation of lateral to wall of building served.

Time 1 hr 45 mins

→ Z



Signed Shertzer

Filed at Engineer's Office

MAY 24 19

Inspector for City

Remarks: PLENTY FELL

OFFICE OF THE DIRECTOR OF PUBLIC SERVICE

No. 3727

PERMIT TO TAP SEWER

Massillon, O.,

May 17

19

Received of

Edward Clancy

fee of \$

2.00

for which permission is granted

to tap

Sanitary

sewer, on the

West

of

11th St.

Ave., Type of Street

Public

the premises being Lot No.

2427 - 2428

, House No.

1723

Work to be done in accordance with Ordinance No. 2329, duly passed by the City Council, and by the Department of Public Service.

Name of Contractor

L. W. Smith

NOTE. This permit covers work outside of building only. Any work inside walls of building is subject to Massillon Board of Health Regulations.