

**FOLLOWING DATA TO BE ANSWERED BY INSPECTOR
AND SIGNED WHEN RETURNED**

No. 3733

3 hrs. for inspection

Date Inspected 6-22-35

I so how and location from
first manhole down stream

House No. 622

Distance from first manhole
down stream to ditch at

Size of pipe used 4" WITH TIE

curb line and depth 77' FROM LAMP HOLE 4' DEEP at cu.


Was lateral at curb? YES

Name of Contractor GEO. EARLY

Was attached to main

Show by diagram relation of lateral to wall of building served.

SEWER IN STREET VERY FLAT. GAVE lateral to building all the fall we could so as to keep line clean. pipe laid from 14" to 24" under ground the way they wanted it.



64' OF 4" PIPE USED

17' TO CLEAN OUT FROM CURB LINE

MAIN SEWER

PIPE
FIRST ST. N.

connection. 4" stopper in cleanout with piece of flag stone on top of pipe.

Signed *[Signature]*

Inspector for City

Filed at Engineer's Office

JUN 24 1935

Remarks: *connection at curb is 11' south of north line of present building now occupied by VETS CLUB.*

OFFICE OF THE DIRECTOR OF PUBLIC SERVICE

No 3733

PERMIT TO TAP SEWER

Massillon, O.,

Received of

Veterans of Foreign Wars

fee of \$ 2.

for which permission is granted

to tap

sewer, on the

of

Ave., Type of Street
St.,

the premises being Lot No.

House No.

Work to be done in accordance with Ordinance No. 2323, duly passed by the City Council, and by the Department of Public Service.

Name of Contractor

NOTE. This permit covers work outside of building only. Any work inside walls of building is subject to Massillon Board of Health Regulations.