

**FOLLOWING DATA TO BE ANSWERED BY INSPECTOR
AND SIGNED WHEN RETURNED**

Nº 3909

Date Inspected 8/18/37

I so how and location from
first manhole down stream

90'

House No. 3072

Distance from first manhole
down stream to ditch at
curb line and depth

70' ~ 7' deep

Size of pipe used 6"


Was lateral at curb? Yes

Name of Contractor

Geo Carley
HOUSE.

Was attached to main Yes

Show by diagram relation of lateral to wall of building served.



M.H. ⊙

WALK.

90'

CURB LINE

LINCOLN WA.

Signed

John E. Evers
Inspector for City

Filed at Engineer's Office

AUG 19 37

Remarks:

4' on N. side of walk.

OFFICE OF THE DIRECTOR OF PUBLIC SERVICE

No 3909

PERMIT TO TAP SEWER

Massillon, O.,

7, 0

19

Received of

L. T. Culp

fee of \$ 2.00

for which permission is granted

L. T. Culp

to tap

Sanitary

sewer, on the

North

of

Lincoln Highway

Ave., Type of Street

paved

the premises being Lot No.

97 190

House No.

3072

Work to be done in accordance with Ordinance No. 2323, duly passed by the City Council, and Rule No. 1, duly passed by the Board of Health, and approved by the Department of Public Service.

Name of Contractor

H. E. Culp

NOTE. This permit covers work outside of building only. Any work inside walls of building is subject to Massillon Board of Health Regulations.