


**FOLLOWING DATA TO BE ANSWERED BY INSPECTOR
AND SIGNED WHEN RETURNED**

No. 3915

Date Inspected 10/14/37 I so how and location from first manhole down stream 106'5'
 House No. NE WI HOUSE Distance from first manhole down stream to ditch at
 Size of pipe used 6" curb line and depth 106'5' 7' deep
 Was lateral at curb? Yes Name of Contractor Smart From main to curb.
 Was attached to main Yes Early From curb to basement
 Show by diagram relation of lateral to wall of building served.

18TH ST, N.W.



Signed John E. Chamberlain
 Inspector for City

Filed at Engineer's Office

OCT 16 1937

Remarks:

Lateral at Main was lowered about
2 1/2 Ft. to get cellar drainage. The end
of lateral is about 2 ft. west of east
curbline. Contractor Smart.

3
2

No 3915

OFFICE OF THE DIRECTOR OF PUBLIC SERVICE

PERMIT TO TAP SEWER

Massillon, O., 9-18-19

Received of Chas R Boyd fee of \$ 2.00

for which permission is granted Short and Early

to tap Sanitary sewer, on the East

of 18th St. N.W. Ave., Type of Street Gravel
St.,

the premises being Lot No. 5051, House No. (New)

Work to be done in accordance with Ordinance No. 2323, duly passed by the City Council, and by the Department of Public Service.

Name of Contractor Smart

NOTE. This permit covers work outside of building only. Any work inside walls of building is subject to Massillon Board of Health Regulations.