

New connection

No. 4329

FOLLOWING DATA TO BE ANSWERED BY INSPECTOR
AND SIGNED WHEN RETURNED

DATE INSPECTED 5/29/42

IF SO HOW AND LOCATION FROM
FIRST MANHOLE DOWN STREAM

Connection made to existing
Stub in M.H. with 6" bend

HOUSE No. 817

DISTANCE FROM FIRST MANHOLE
DOWN STREAM TO DITCH AT
CURB LINE AND DEPTH

SIZE OF PIPE USED 6"

WAS LATERAL AT CURB? no

NAME OF CONTRACTOR

Dickel

WAS ATTACHED TO MAIN Manhole

SHOW BY DIAGRAM RELATION OF LATERAL TO WALL OF BUILDING SERVED.


Length of lateral 32'-7" from
house to "X" on curb. and

47'-3" from House to M.H.

Lateral 5'-6" Deep at House

" 6'-4" " " Curb

" 8'-6" " " M.H.



SIGNED

J. H. Hennrich
INSPECTOR FOR CITY

FILED AT ENGINEER'S OFFICE

June 2 1942 - G

REMARKS:

Clay soil

OFFICE OF THE DIRECTOR OF PUBLIC SERVICE

No. 4329

PERMIT TO TAP SEWER

MASSILLON, OHIO,

May 26 19

RECEIVED OF

P. E. Rickett

FEE OF \$ 2.00

FOR WHICH PERMISSION IS GRANTED

W. N. Blackett

TO TAP

Sanitary

SEWER, ON THE

South

OF

Sheffield Ave N E

AVE.
ST.

TYPE OF STREET

drift

THE PREMISES BEING LOT No.

2744

HOUSE No.

817

WORK TO BE DONE IN ACCORDANCE WITH ORDINANCE No. 2323, DULY PASSED BY THE CITY COUNCIL
RULES OF THE DEPARTMENT OF PUBLIC SERVICE.

NAME OF CONTRACTOR

P. E. Rickett

Note. This permit covers work outside of building only. Any work inside of building is subject to Massillon Board of Health Regulations.