

New Connection.

FOLLOWING DATA TO BE ANSWERED BY INSPECTOR
Nº 4332 AND SIGNED WHEN RETURNED

DATE INSPECTED 6-19-42

IF SO HOW AND LOCATION FROM
FIRST MANHOLE DOWN STREAM

HOUSE NO. 837

DISTANCE FROM FIRST MANHOLE
DOWN STREAM TO DITCH AT
CURB LINE AND DEPTH

SIZE OF PIPE USED 6"


48' 6" Manhole to + curb.

WAS LATERAL AT CURB? Yes.

NAME OF CONTRACTOR Molara.

WAS ATTACHED TO MAIN

SHOW BY DIAGRAM RELATION OF LATERAL TO WALL OF BUILDING SERVED.



Soil Clay
House facing East,
48' 6" Manhole to + curb,
14' House line to + curb,
6' 6" Depth lateral at curb,
+ on curb,
53' Lateral curb to house
4' 5" Lateral to house line.
7' 6" Lateral depth at house.

Water line in ditch.

SIGNED

INSPECTOR FOR CITY

FILED AT ENGINEER'S OFFICE June 19 42 - G.C.W.

REMARKS:

New Connection

No. 4332

OFFICE OF THE DIRECTOR OF PUBLIC SERVICE

PERMIT TO TAP SEWER

MASSILLON, OHIO, 6-1 1915

RECEIVED OF James Desirable Inc

FEE OF \$ 2.00

FOR WHICH PERMISSION IS GRANTED James Desirable Inc

TO TAP Sanitary

SEWER ON THE West

OF 17th St

AVE., TYPE OF STREET dist
St.,

THE PREMISES BEING LOT No. 7960

House No. 837

WORK TO BE DONE IN ACCORDANCE WITH ORDINANCE No. 2323, DULY PASSED BY THE CITY COUNCIL
RULES OF THE DEPARTMENT OF PUBLIC SERVICE.

NAME OF CONTRACTOR James Desirable Inc

Note. This permit covers work outside of building only. Any work inside
of building is subject to Massillon Board of Health Regulations.