

New Connection,

FOLLOWING DATA TO BE ANSWERED BY INSPECTOR
AND SIGNED WHEN RETURNED

No. 4335

DATE INSPECTED

6-9-42.

IF SO HOW AND LOCATION FROM
FIRST MANHOLE DOWN STREAM

85' Manhole to house li

HOUSE No.

722

DISTANCE FROM FIRST MANHOLE
DOWN STREAM TO DITCH AT
CURB LINE AND DEPTH

78' curb to manhole dno

SIZE OF PIPE USED

6"

WAS LATERAL AT CURB?


Yes.

NAME OF CONTRACTOR

Molson.

WAS ATTACHED TO MAIN

SHOW BY DIAGRAM RELATION OF LATERAL TO WALL OF BUILDING SERVED.



Lateral at curb
6" Tile House facing south.
6' Lateral depth at curb.
78' Manhole to + on curb.
85' Manhole to house corner.
+ on curb.
Dirt Clay.
45' Curb to house lateral.
8' Lateral depth at house.
Water line in same ditch

SIGNED

W. H. Hensrich.
INSPECTOR FOR CITY

FILED AT ENGINEER'S OFFICE

6-10-42
OK GCU

REMARKS:

New Connection,
No. 4335

OFFICE OF THE DIRECTOR OF PUBLIC SERVICE
PERMIT TO TAP SEWER

MASSILLON, OHIO, 6/1, 19

RECEIVED OF

FEE OF \$ 2.00

FOR WHICH PERMISSION IS GRANTED

TO TAP

SEWER, ON THE

OF

TYPE OF STREET

THE PREMISES BEING LOT No.

HOUSE No.

WORK TO BE DONE IN ACCORDANCE WITH ORDINANCE No. 2323, DULY PASSED BY THE CITY COUNCIL
RULES OF THE DEPARTMENT OF PUBLIC SERVICE.

NAME OF CONTRACTOR

Note. This permit covers work outside of building only. Any work inside
of building is subject to Massillon Board of Health Regulations.