

Existing Connection.
Relocated.

FOLLOWING DATA TO BE ANSWERED BY INSPECTOR
AND SIGNED WHEN RETURNED

Nº 4377

DATE INSPECTED Nov. 6, 1942

IF SO HOW AND LOCATION FROM
FIRST MANHOLE DOWN STREAM

HOUSE NO. 19

SIZE OF PIPE USED 4"

DISTANCE FROM FIRST MANHOLE
DOWN STREAM TO DITCH AT
CURB LINE AND DEPTH 129' 4' deep

WAS LATERAL AT CURB? Yes

NAME OF CONTRACTOR Smart

WAS ATTACHED TO MAIN ---

SHOW BY DIAGRAM RELATION OF LATERAL TO WALL OF BUILDING SERVED.

Length of line 54'
4' Deep at Curb
2'-6" Deep at House
4" Pipe used.
"X" on Curb.

S. Curb Line Edwin St.

Side Walk 3'

4' Deep
Existing lateral st.

4'-6" Deep

Existing 4" line

SIGNED

R. F. Snyder

INSPECTOR FOR CITY

FILED AT ENGINEER'S OFFICE

REMARKS.

Existing 4" line to S. Erie cut off and new line connects
as indicated using 2 $\frac{1}{8}$ Bends. Clay Soil.

GCW-11-9

OFFICE OF THE DIRECTOR OF PUBLIC SERVICE
No. 4377
PERMIT TO TAP SEWER

MASSILLON, OHIO,

19

RECEIVED OF

FEE OF \$

FOR WHICH PERMISSION IS GRANTED

TO TAP

SEWER, ON THE

OF

AVE.,
ST.,

TYPE OF STREET

THE PREMISES BEING LOT No.

HOUSE No.

WORK TO BE DONE IN ACCORDANCE WITH ORDINANCE No. 2323, DULY PASSED BY THE CITY COUNCIL
RULES OF THE DEPARTMENT OF PUBLIC SERVICE.

NAME OF CONTRACTOR

Note. This permit covers work outside of building only. Any work inside
of building is subject to Massillon Board of Health Regulations.