

Nº 4936

FOLLOWING DATA TO BE ANSWERED BY INSPECTOR
AND SIGNED WHEN RETURNED

DATE INSPECTED 5-2-47

IF SO HOW AND LOCATION FROM
FIRST MANHOLE DOWN STREAM

Tapped into M.H.

HOUSE NO. 219 Lin. Way E.

SIZE OF PIPE USED 6

DISTANCE FROM FIRST MANHOLE
DOWN STREAM TO DITCH AT
CURB LINE AND DEPTH

5' 2' Deep.

WAS LATERAL AT CURB? No


WAS ATTACHED TO MAIN No

NAME OF CONTRACTOR

Remley

SHOW BY DIAGRAM RELATION OF LATERAL TO WALL OF BUILDING SERVED.

Lines not complete. Final
location of Bldg. not known.
San. line run in 91' and
stoppered. Storm line
run in 115' at this time.



SIGNED

R. F. Snyder
INSPECTOR FOR CITY

FILED AT ENGINEER'S OFFICE

5/23/47

REMARKS:

Where lines were less than 3' deep conc. was
placed around pipes.

Nº 4936

OFFICE OF THE DIRECTOR OF PUBLIC SERVICE

PERMIT TO TAP SEWER

MASSILLON, OHIO.

RECEIVED OF

Pure Oil Company

FEE OF \$

2.50

FOR WHICH PERMISSION IS GRANTED

Pure Oil Company

TO TAP

Sanitary

SEWER, ON THE

West

OF

3rd St. NE

AVE., TYPE OF STREET

brick

THE PREMISES BEING LOT NO.

268

HOUSE NO.

219 in N

WORK TO BE DONE IN ACCORDANCE WITH ORDINANCE NO. 2323, DULY PASSED BY THE CITY COUNCIL, RULES OF THE DEPARTMENT OF PUBLIC SERVICE.


NAME OF CONTRACTOR

Raymond Remley

Note. This permit covers work outside of building only. Any work walls of building is subject to Massillon Board of Health Regulations.

PURE OIL CO.
STATION at cor.
L. Way E. and 3rd St S.E.

Temporary
Bldg.
1 1/2' Deep



Temporarily stoppered
until permanent bldg.
can be built.



57' (4" pipe)
San. Line

Walk

W. Curb
Cong. Encasement
Where pipes are
less than 3' Deep

3rd St S.E.

Exist. Storm Sewer

E. Curb

N.

Connected from here
to perm. bldg. on
7-3-48 by Remley.

6" x 4" Y - 4' Deep

Retaining Wall

Insp. 5-2-47 and 6-4-47 by R.F. Snyder

Exist. San.