

Project Information

Surveyor Name	Matthew W Adams	Certificate Number	U08180703002746
Owner	City of Massillon	Customer	City of Massillon
Drainage Area	River	PO Number	
Pipe Segment Reference	Pipe #25	Date	6/18/2020 12:43
Street	3rd Street	City	Massillon
Comments			

Manhole

Upstream MH	Pipe #25 Gate Tower	Rim to Invert (U)	
Grade to Invert (U)		Rim to Grade (U)	
Downstream MH	Pipe #25 Outlet	Rim to Invert (D)	
Grade to Invert (D)		Rim to Grade (D)	
Sewer Use	Stormwater Pipe	Direction of Survey	Downstream

Pipe

Height (Diameter)	42	Width	
Shape	Circular	Material	Reinforced Concrete Pipe
Lining Method		Pipe Joint Length	
Total Length		Length Surveyed	14.5
Year Laid		Year Renewed	

Misc

Flow Control		Media Label	DVD
Purpose		Sewer Category	
Pre-Cleaning	Heavy Cleaning	Date Cleaned	6/18/2020 12:44
Weather		Location Code	
Additional Info		Location Details	

Custom

Number of Taps	0	Number of Roots	0
Num Cracks / Fractures	1	Number of Broken / Holes / Collapse	0
Number of Deposits	0	Custom6	
Custom7		Struct Grade	
OM Grade		Overall Grade	

Pacp 6

Reverse Setup ID		Sheet (Group) Number	
Imperial Units (US)	True	Pressure Value	
Work Order		Project	
		Completed	Yes

Project:

Date: 6/18/2020 12:43:00 PM

Street: 3rd Street

Length Surveyed: 14.5

Pacp Quick Overall Rating: 3100

Height (Diameter): 42

Street: 3rd Street

Pipe Segment Reference: Pipe #25

Upstream MH: Pipe #25 Gate Tower

Downstream MH: Pipe #25 Outlet

Direction of Survey: Downstream

Material: Reinforced Concrete Pipe

Distance	Fault Observation	Picture
0.0	Access Point Special Chamber Remarks: Pipe #25 Gate Tower	
0.0	Miscellaneous Water Level	
6.3	Crack Multiple Position: 9 To 2 Joint Remarks: hairline Struct Weight: 3	

Distance	Fault Observation	Picture
14.5	Access Point Discharge Point Remarks: Pipe #25 Outlet River	

Created with the  report generator

Project:

Date: 6/18/2020 12:43:00 PM

Street: 3rd Street

Length Surveyed: 14.5

Pacp Quick Overall Rating: 3100

Height (Diameter): 42

Street: 3rd Street

Pipe Segment Reference: Pipe #25

Upstream MH: Pipe #25 Gate Tower

Downstream MH: Pipe #25 Outlet

Direction of Survey: Downstream

Material: Reinforced Concrete Pipe


Severity
Light
Moderate
Average
Heavy
Severe

(0.0) AOC - Access Point Special Chamber
Remark: Pipe #25 Gate Tower

(0.0) MWL - Miscellaneous Water Level

(14.5) ADP - Access Point Discharge Point
Remark: Pipe #25 Outlet River

Total Distance: 14.5



ID Number: Pipe #25 Gate Tower

(6.3) CM - Crack Multiple - Position: 9 To 2
Remark: hairline

ID Number: Pipe #25 Outlet

Created with the  report generator

Nassco C.C.T.V. Defect Code Information

Session Information			
Surveyors Name	Matthew W Adams	Certificate Number	U08180703002746
System Owner	City of Massillon	Survey Customer	City of Massillon
Drainage Area	River		
P/O Number		Pipeline Segment Ref	Pipe #25
Date	6/18/2020	Time	12:43
Location	3rd Street		
Locality	Massillon		
Further Location Details:			
Manhole Information			
Upstream Manhole Number: Pipe #25 Gate Tower			
Rim to Invert		Grade to Invert	
Rim to Grade			
Downstream Manhole Number: Pipe #25 Outlet			
Rim to Invert		Grade to Invert	
Rim to Grade			
Sewer			
Use of Sewer	Stormwater Pipe	Direction	Downstream
Flow Control		Height	42
Width		Shape	Circular
Material	Reinforced Concrete Pipe	Lining Method	
Pipe Joint Length		Total Length	
Length Surveyed	14.5	Year Laid	
Year Rehabilitated		Tape/Media Number	DVD
Purpose		Sewer Category	
Pre-Cleaning	Heavy Cleaning	Date Cleaned	6/18/2020 12:44
Weather		Location Code	
Additional Information			

Nassco C.C.T.V. Defect Code Information

Grade	Structural	O&M	Overall
5	0	0	0
4	0	0	0
3	3	0	3
2	0	0	0
1	0	0	0
Overall	3	0	3
Number of Defects	1	0	1
Pipe Rating	3100	0000	3100
Pipe Ratings Index	3	0	3

Nassco C.C.T.V. Defect Code Information

Distance	Video Ref	Code	Cont Defect	Value			Joint	Circumferential Location	
				Dimension		%		At / From	To
				1st	2nd				
0	25	AOC - Access Point Special Chamber							
		Pipe #25 Gate Tower							
0	51	MWL - Miscellaneous Water Level				5			
6.3	153	CM - Crack Multiple							
		hairline							
14.5	297	ADP - Access Point Discharge Point							
		Pipe #25 Outlet River							

Created with the  report generator

Videos Created for Session

_Pipe 25 Gate Tower-Pipe 25 Outlet_6182020-1334_D_27947.avi Size: 114 MB

Created with the  report generator