

JOEL P. SMITH
Director of Public Service and Safety

April 12, 2019

Hammontree and Associates
5233 Stoneham Road
North Canton, OH 44720
ATTN: Jennifer Schumacher PE

RE: Aultman West ER Site Plan Review

Mrs. Schumacher:

The City of Massillon Engineering Department has reviewed the submitted site plan for the above referenced project. The following comments have been compiled for the site plan. **In your re-submittal provide a response letter addressing each comment and three (3) revised sets plans and if applicable two (2) copies of supporting documentation.**

GENERAL

- 1) Label the address of the Aultman facility on the plans

SHEET C3.1 – SITE PLAN

- 2) Clearly show limits of building and corporation lines with Jackson township
- 3) Provide calculations showing total number of parking spaces for the facility and how this was calculated based on use and the zoning code.
- 4) Show location of proposed ADA parking spaces
- 5) Label total area of new asphalt/concrete pavement
- 6) Label the proposed canopy structure and square footage.
- 7) Show location of “relocated” dumpster pad


SHEET C4.1 -- UTILITY PLAN

- 8) Provide calculations for the additional storm water flow into the underground storage system. Show that the existing system is adequately sized to handle the additional flow.
- 9) Show and label the location of the existing underground retention system and show where this system ties into the City storm sewer line. Show pipe sizes, weirs? etc.

If you have any questions or require additional information, please contact our office at 330-830-1722.

Respectfully,

Jason M. Popiel, P.E., CPESC
CITY ENGINEER



Jason Haines
Engineering Technician