



CHARLES F. HAMMONTREE, P.E., P.S.
JAMES C. BOLLIBON, P.E., P.S.
ROBERT J. HAMMONTREE, III
MICHAEL M. VALE, P.E., C.P.E.S.C., C.P.S.W.Q.
KARL J. OPRISCH, P.E.
WILLIAM P. UTZMAN, P.E., C.P.E.S.C.
MARK M. ZIMMERMAN, P.E., C.P.E.S.C.
JENNIFER D. SCHUMACHER, P.E., LEED-AP

HAMMONTREE & ASSOCIATES, LIMITED

Engineers Planners Scientists Surveyors

5233 Stoneham Road
North Canton, Ohio 44720

Phone (330) 499-8817
Fax (330) 499-0149
www.hammontree-engineers.com

TIMOTHY J. BRIGGS, P.S.
SHELBY R. PRINGLE, N.I.C.E.T.
THOMAS R. POWELL, P.E.
MELINDA C. CHASE, P.E.
PAUL K. MILLER, P.S., REMOTE PILOT
JOSEPH A. CORALL, P.S., REMOTE PILOT
DANTE C. CELLITTI, R.L.A., C.P.E.S.C., C.P.S.W.Q.
JEFFREY A. RICE, C.P.S.S.

November 4, 2021

Jason Popiel, P.E., CPESC, City Engineer
City of Massillon

Municipal Government Annex, Administration Building
151 Lincoln Way East
Massillon, OH 44646

Re: Steinmetz Warehouse Building Plan Response Letter

Dear Mr. Popiel:

This letter is in response to your comment letter dated October 28th regarding the above-mentioned project. We have revised the site plans and have enclosed the required copies of each.

The following is how each of the comments have been addressed:


GENERAL

1. Sheet C3.1 under Site Data: the note was updated to provide for the proposed use as storage for furniture and household items.
2. Sheet C5.1 was modified to include the SWPPP legend with callouts for silt fence, construction entrance, concrete wash out, topsoil stockpile, seeding, storage area and construction limits. The SWPPP details were added to Sheets C6.2 and C6.3.
3. Sheet C.4 the drainage note was revised to show that the existing building and proposed building will flow to the grass swales along the east and south side of the property. The grass swales connect in the southeast corner into a low area, that then flows east through a 15" storm pipe. The grass swales will slow down the water and the low-wooded area will provide for some infiltration before exiting the site.
4. Sheet C2.1 was revised to show the existing gravel drive and building under construction, same as C2.2.

If additional information is needed, please feel free to give me a call or send me an email.

Sincerely,

HAMMONTREE & ASSOCIATES, LIMITED


Jennifer D. Schumacher, P.E., LEED-AP
Project Manager

Enclosure: As stated

CANTON, OH
330-499-8817

PITTSBURGH, PA
724-468-4622

ST. CLAIRSVILLE, OH
740-695-7237

AKRON, OH
330-633-7274