

## SECTION 101423 - PANEL SIGNAGE

## PART 1 - GENERAL

## 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions, Division 00 and Division 01 Specification Sections, apply to this Section.

## 1.2 SUMMARY

- A. Section Includes:

- 1. Panel signs.
- 2. Room-identification signs.

- B. Related Requirements:

- 1. Section 220553 "Identification for Plumbing Piping and Equipment" for labels, tags, and nameplates for plumbing systems and equipment.
- 2. Section 230553 "Identification for HVAC Piping and Equipment" for labels, tags, and nameplates for HVAC systems and equipment.
- 3. Section 260553 "Identification for Electrical Systems" for labels, tags, and nameplates for electrical equipment.

## 1.3 DEFINITIONS

- A. Accessible: In accordance with the accessibility standard.

## 1.4 ACTION SUBMITTALS

- A. Product Data: For each type of product.

- B. Shop Drawings: For panel signs.

- 1. Include fabrication and installation details and attachments to other work.
- 2. Show sign mounting heights, locations of supplementary supports to be provided by others, and accessories.
- 3. Show message list, typestyles, graphic elements, including raised characters and Braille, and layout for each sign at least half size .

- C. Samples for Initial Selection: For each type of sign assembly, exposed component, and exposed finish.

- 1. Include representative Samples of available typestyles and graphic symbols.

- D. Samples for Verification: For each type of sign assembly showing all components and with the required finish(es), in manufacturer's standard size unless otherwise indicated and as follows:
  - 1. Panel Signs: Full-size Sample.
  - 2. Room-Identification Signs: Full-size Sample.
- E. Sign Schedule: Use same designations specified or indicated on Drawings or in a sign schedule.

## 1.5 INFORMATIONAL SUBMITTALS

- A. Qualification Data: For Installer.

## 1.6 CLOSEOUT SUBMITTALS

- A. Maintenance Data: For signs to include in maintenance manuals.
- B. Closeout submittals as required in Division 00 and Division 01.

## 1.7 QUALITY ASSURANCE

- A. Installer Qualifications: An entity that employs installers and supervisors who are trained and approved by manufacturer.

# PART 2 - PRODUCTS

## 2.1 PERFORMANCE REQUIREMENTS

- A. Accessibility Standard: Comply with applicable provisions in the U.S. Architectural & Transportation Barriers Compliance Board's ADA-ABA Accessibility Guidelines for Buildings and Facilities for signs.

## 2.2 SIGNS

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following :
  - 1. ASI Sign Systems, Inc.; InForm.
  - 2. Best Sign Systems Inc.; Lucent.
  - 3. Apco Signs
- B. Panel Sign (Sign Types C, E, F, G, H, J, K, L, M, P, R, S, T, V, and W): Sign with smooth, uniform surfaces; with message and characters having uniform faces, and precisely formed lines and profiles; and as follows:
  - 1. Vacuum Formed-Laminate Sign: Vacuum formed 1.5 mil, clear, scratch resistant polycarbonate laminated to acrylic mounting panel.

- a. Acrylic Mounting Panel Thickness: 0.125 inch (3 mm).
    - b. Tactile Graphics and Text: Provide tactile copy and grade 2 Braille raised 1/32 inch (0.8 mm) minimum from first surface by manufacturer's vacuum formed embossing process.
    - c. Background Appearance: Solid colors as selected by Architect from manufacturer's full range.
    - d. Tactile Lettering and Graphics Appearance: As selected by Architect from manufacturer's full range of vinyl
  2. Sign-Panel Perimeter: Finish edges smooth.
    - a. Edge Condition: Square cut.
    - b. Corner Condition in Elevation: Square.
  3. Mounting: As indicated with adhesive or two-face tape.
  4. Text and Typeface: Accessible raised characters and Braille typeface as selected by Architect from manufacturer's full range. Finish raised characters to contrast with background color, and finish Braille to match background color.
  5. Flatness Tolerance: Sign panel shall remain flat or uniformly curved under installed conditions as indicated and within a tolerance of plus or minus 1/16 inch (1.5 mm) measured diagonally from corner to corner.
- C. Room-Identification Sign (Sign Types A and B): Sign with smooth, uniform surfaces; with message and characters having uniform faces, sharp corners, and precisely formed lines and profiles; and as follows:
1. Vacuum Formed-Laminate Sign: Vacuum formed 1.5 mil, clear, scratch resistant polycarbonate laminated to acrylic mounting panel.
    - a. Acrylic Mounting Panel Thickness: 0.125 inch (3 mm).
    - b. Tactile Graphics and Text: Provide tactile copy and grade 2 Braille raised 1/32 inch (0.8 mm) minimum from first surface by manufacturer's vacuum formed embossing process.
    - c. Background Appearance: Solid colors as selected by Architect from manufacturer's full range.
    - d. Tactile Lettering and Graphics Appearance: As selected by Architect from manufacturer's full range of vinyl
  2. Sign-Panel Perimeter: Finish edges smooth.
    - a. Edge Condition: Square cut.
    - b. Corner Condition in Elevation: Square.
  3. Mounting: with adhesive or two-face tape.
  4. Text and Typeface: Accessible raised characters and Braille typeface as selected by Architect from manufacturer's full range. Finish raised characters to contrast with background color, and finish Braille to match background color.
  5. Accessories: Clear acrylic paper insert as indicated on Drawings.

## 2.3 PANEL-SIGN MATERIALS

- A. Acrylic Sheet: ASTM D 4802, category as standard with manufacturer for each sign, Type UVF (UV filtering).
- B. Vinyl Film: UV-resistant vinyl film of nominal thickness indicated, with pressure-sensitive, permanent adhesive on back; die cut to form characters or images as indicated and suitable for exterior applications.
- C. Paints and Coatings for Sheet Materials: Inks, dyes, and paints that are recommended by manufacturer for optimum adherence to surface and are UV and water resistant for colors and exposure indicated.

## 2.4 ACCESSORIES

- A. Adhesives: As recommended by sign manufacturer and with a VOC content of 70 g/L or less for adhesives used inside the weatherproofing system and applied on-site when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
- B. Adhesives: As recommended by sign manufacturer and that comply with the testing and product requirements of the California Department of Health Services' "Standard Practice for the Testing of Volatile Organic Emissions from Various Sources Using Small-Scale Environmental Chambers."
- C. Two-Face Tape: Manufacturer's standard high-bond, foam-core tape, 0.045 inch (1.14 mm) thick, with adhesive on both sides.

## 2.5 FABRICATION

- A. General: Provide manufacturer's standard sign assemblies according to requirements indicated.
- B. Surface-Engraved Graphics: Machine engrave characters and other graphic devices into panel surface indicated to produce precisely formed copy, incised to uniform depth.
  - 1. Engraved Metal: Fill engraved graphics with manufacturer's standard baked enamel.
  - 2. Engraved Opaque Acrylic Sheet: Fill engraved graphics with manufacturer's standard enamel.
  - 3. Face-Engraved Clear Acrylic Sheet: Fill engraved copy with manufacturer's standard enamel. Apply manufacturer's standard opaque background color coating to back face of acrylic sheet.
  - 4. Engraved Plastic Laminate: Engrave through exposed face ply of plastic-laminate sheet to expose contrasting core ply.
- C. Subsurface-Applied Graphics: Apply graphics to back face of clear face-sheet material to produce precisely formed image. Image shall be free of rough edges.
- D. Subsurface-Engraved Graphics: Reverse engrave back face of clear face-sheet material. Fill resulting copy with manufacturer's standard enamel. Apply opaque manufacturer's standard background color coating over enamel-filled copy.

## 2.6 GENERAL FINISH REQUIREMENTS

- A. Appearance of Finished Work: Noticeable variations in same piece are not acceptable. Variations in appearance of adjoining components are acceptable if they are within the range of approved Samples and are assembled or installed to minimize contrast.
- B. Directional Finishes: Run grain with long dimension of each piece and perpendicular to long dimension of finished trim or border surface unless otherwise indicated.

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- A. Examine substrates, areas, and conditions, with Installer present, for compliance with requirements for installation tolerances and other conditions affecting performance of signage work.
- B. Verify that sign-support surfaces are within tolerances to accommodate signs without gaps or irregularities between backs of signs and support surfaces unless otherwise indicated.
- C. Verify that anchor inserts are correctly sized and located to accommodate signs.
- D. Proceed with installation only after unsatisfactory conditions have been corrected.

### 3.2 INSTALLATION

- A. General: Install signs using mounting methods indicated and according to manufacturer's written instructions.
  - 1. Install signs level, plumb, true to line, and at locations and heights indicated, with sign surfaces free of distortion and other defects in appearance.
  - 2. Install signs so they do not protrude or obstruct according to the accessibility standard.
  - 3. Before installation, verify that sign surfaces are clean and free of materials or debris that would impair installation.
- B. Room-Identification Signs and Other Accessible Signage: Install in locations on walls as indicated and according to accessibility standard .
- C. Mounting Methods:
  - 1. Adhesive: Clean bond-breaking materials from substrate surface and remove loose debris. Apply linear beads or spots of adhesive symmetrically to back of sign and of suitable quantity to support weight of sign after cure without slippage. Keep adhesive away from edges to prevent adhesive extrusion as sign is applied and to prevent visibility of cured adhesive at sign edges. Place sign in position, and push to engage adhesive. Temporarily support sign in position until adhesive fully sets.
  - 2. Two-Face Tape: Clean bond-breaking materials from substrate surface and remove loose debris. Apply tape strips symmetrically to back of sign and of suitable quantity to

support weight of sign without slippage. Keep strips away from edges to prevent visibility at sign edges. Place sign in position, and push to engage tape adhesive.

- D. Signs Mounted on Glass: Provide opaque sheet matching sign material and finish onto opposite side of glass to conceal back of sign.

### 3.3 ADJUSTING AND CLEANING

- A. Remove and replace damaged or deformed signs and signs that do not comply with specified requirements. Replace signs with damaged or deteriorated finishes or components that cannot be successfully repaired by finish touchup or similar minor repair procedures.
- B. Remove temporary protective coverings and strippable films as signs are installed.
- C. On completion of installation, clean exposed surfaces of signs according to manufacturer's written instructions, and touch up minor nicks and abrasions in finish. Maintain signs in a clean condition during construction and protect from damage until acceptance by Owner.

END OF SECTION 101423