

SECTION 238333 - ELECTRIC UNIT HEATERS

PART 1-GENERAL

1.1 SECTION INCLUDES

- A. Electric Unit Heaters

1.2 SUBMITTALS

- A. Submittals are required and shall include product data noting capacities at the specified conditions, materials, sizes, and dimensions.

PART 2-PRODUCTS

2.1 MANUFACTURERS

- A. Q-Mark
- B. Markel
- C. Berko

2.2 COMPONENTS

- A. Heavy gauge die formed steel housing.
- B. Completely enclosed fan motor.
- C. Fan delay feature eliminates cold drafts.
- D. Individually adjustable discharge louvers to control air flow.
- E. Aluminum-finned, copper clad steel sheath heating element has longer useful life, because of cooler sheath temperature and faster heat dissipation.
- F. Automatic reset linear thermal cut-out, capillary type, provides protection over entire length of element areas

PART 3-EXECUTION

3.1 INSTALLATION

- A. Install per manufacturers requirements.

END OF SECTION 238333

THIS PAGE IS INTENTIONALLY LEFT BLANK