





PROJECT NO	2203-2
DRAWN BY	WAM
CHECKED BY	TJC

SECOND FLOOR PLAN - LIGHTING A - UNIT C

SCALE: 1/8" = 1'-0" E-102-C

Hex Notes

MATCHLINE: UNIT A MATCHLINE: UNIT C

① CONNECT TO RESPECTIVE ROOM EMERGENCY LIGHTING CIRCUIT AHEAD OF ALL SWITCHING/RELAYS.

② ROUTE CIRCUIT THROUGH RESPECTIVE LIGHTING CONTROL RELAY PANEL AS REQUIRED. SEE LIGHTING CONTROL RELAY PANEL WIRING DIAGRAMS FOR DETAILS.

③ PROVIDE DUAL LEVEL DIMMING IN THIS ROOM. ONE DIMMER SHALL CONTROL THE ROW OF LIGHT FIXTURES AT THE TEACHING WALL, THE OTHER DIMMER SWITCH SHALL CONTROL ALL OF THE OTHER LIGHT FIXTURES IN THE ROOM.

SECOND FLOOR PLAN - LIGHTING - UNIT C
SCALE: 1/8" = 1'-0"