ARK	DESCRIPTION	MANUFACTURERS AND CATALOG #'S	LAMPS	VOLTS	MOUNTING	REMARKS
A	2' x 4' LED VOLUMETRIC LAY-IN	METALUX #24CZ-LD4-50-UNV-L835-CD LITHONIA #2BLT4-48L-ADP-MVOLT-GZ1-LP835	LED	277	LAY-IN	
A2	2' x 2' LED VOLUMETRIC LAY-IN	COLUMBIA #LCAT-24-35-ML-G-ED-U METALUX #22CZ-LD4-34-UNV-L835-CD LITHONIA #2BLT2-33L-ADP-MVOLT-GZ1-LP835	LED	277	LAY-IN	
3	1' x 4' LED FLAT PANEL LAY-IN	COLUMBIA #LCAT-22-35-ML-G-ED-U LITHONIA #CPX-1X4-4000LM-80CRI-35K-SWL-MIN10-ZT-MVOLT OR APPROVED EQUAL MANUFACTURER	LED	277	LAY-IN	
$\overline{}$	2" LED RECESSED DOWN LIGHT	GOTHAM #EVO2-35/15-AR-LSS-WD-MVOLT-UGZ OR APPROVED EQUAL BY PORTFOLIO OR PRESCOLITE	LED	277	RECESSED	
	4' LED SURFACE MOUNTED FIXTURE W/ DIMMING SENSOR	LITHONIA #STL4-48L-MVOLT-EZ1-LP835-LSXRHL-SC1 OR APPROVED EQUAL BY COLUMBIA OR METALUX	LED	277	SURFACE	
	LED RECESSED LINEAR FIXTURE WALL-TO-WALL	LITECONTROL #L20-WALL-TO-WALL-D080-35K-CWM-D10-1CWQ-277 OR APPROVED EQUAL BY A-LIGHT OR FOCAL POINT	LED	277	RECESSED	
<u> </u>	4' LED INDUSTRIAL FIXTURE	METALUX #4-SNLED-LD4-49SL-LN-UNV-L835-CD-1-AYC-CHAIN/SET LITHONIA #CLX-L48-5000LM-SEF-RDL-MVOLT-GZ10-35K-80CRI-WH-HC36 COLUMBIA #LCL-4-35-ML-ED-U-CSHC	LED	277	SURFACE/CHAIN	
-	LED INDUSTRIAL HIGH-BAY FIXTURE	LITHONIA #CPHB-30000LM-SEF-GCL-MD-MVOLT-GZ10-35K-80CRI-DWH, #WGCPHBMD, #HG36 - OR APPROVED EQUAL BY COLUMBIA OR METALUX	LED	277	SURFACE/CHAIN	
<	2' x 4' LED FLAT PANEL LAY-IN	LITHONIA #CPX-2X4-6000LM-80CRI-35K-SWL-MIN10 OR APPRVOED EQUAL BY COLUMBIA OR METALUX	LED	277	LAY-IN	
	4" LED RECESSED DOWN LIGHT	LITHONIA #LDN4-35/20-LO4-AR-LSS-MVOLT-GZ1 OR APPROVED EQUAL	LED	277	RECESSED	
<u></u>	4' LED LINEAR SUSPENDED FIXTURE	AXIS #TB4DILED-600-1200-80-35-SO-SO-4'-C-UNV-DP-1-CA(60) OR APPROVED EQUAL MANUFACTURER	LED	277	SUSPENDED	COLOR SELECTION BY ARCHITECT.
<u></u> // 1	8' LED LINEAR SUSPENDED FIXTURE	AXIS #TB4DILED-600-1200-80-35-SO-SO-8'-C-UNV-DP-1-CA(60) OR APPROVED EQUAL MANUFACTURER	LED	277	SUSPENDED	COLOR SELECTION BY ARCHITECT.
<u>л</u>	12' LED LINEAR SUSPENDED FIXTURE	AXIS #TB4DILED-600-1200-80-35-SO-SO-12'-C-UNV-DP-1-CA(60) OR APPROVED EQUAL MANUFACTURER	LED	277	SUSPENDED	
л <u>—</u> ЛЗ	28' LED LINEAR SUSPENDED FIXTURE	AXIS #TB4DILED-600-1200-80-35-SO-SO-28'-C-UNV-DP-1-CA(60) OR APPROVED EQUAL MANUFACTURER	LED	277	SUSPENDED	COLOR SELECTION BY ARCHITECT. COLOR SELECTION BY ARCHITECT.
//4	32' LED LINEAR SUSPENDED FIXTURE	AXIS #TB4DILED-600-1200-80-35-SO-SO-32'-C-UNV-DP-1-CA(60) OR APPROVED EQUAL MANUFACTURER	LED	277	SUSPENDED	COLOR SELECTION BY ARCHITECT. COLOR SELECTION BY ARCHITECT.
15	4' LED LINEAR SURFACE MOUNTED FIXTURE	AXIS #TB4SLED-1200-80-35-SO-4'-C-UNV-DP-1-SB15 OR APPROVED EQUAL MANUFACTURER	LED	277	SURFACE	COLOR SELECTION BY ARCHITECT. COLOR SELECTION BY ARCHITECT.
16	8' LED LINEAR SURFACE MOUNTED FIXTURE	AXIS #TB4SLED-1200-80-35-SO-8'-C-UNV-DP-1-SB15 OR APPROVED EQUAL MANUFACTURER	LED	277	SURFACE	
// T	12' LED LINEAR SURFACE MOUNTED FIXTURE	AXIS #TB4SLED-1200-80-35-SO-12'-C-UNV-DP-1-SB15 OR APPROVED EQUAL MANUFACTURER	LED	277	SURFACE	COLOR SELECTION BY ARCHITECT. COLOR SELECTION BY ARCHITECT.
/18	16' LED LINEAR SURFACE MOUNTED FIXTURE	AXIS #TB4SLED-1200-80-35-SO-16'-C-UNV-DP-1-SB15 OR APPROVED EQUAL MANUFACTURER	LED	277	SURFACE	
\ \	2' x 4' LED VOLUMETRIC FLANGED FOR DRYWALL	METALUX #24CZ-LD4-50-UNV-L835-CD-DF-24-W LITHONIA #2BLT4-48L-ADP-MVOLT-EZ1-LP835-DGA24	LED	277	RECESSED	COLOR SELECTION BY ARCHITECT.
)	4" LED RECESSED SHOWER DOWN LIGHT	GOTHAM #EVO4SH-35/15-4DFF-SMO-MVOLT-GZ10 OR APPROVED EQUAL BY PRESCOLITE OR PORTFOLIO	LED		RECESSED	
)	4' LED VAPOR-TITE ELEVATOR PIT FIXTURE	LITHONIA #VAP-6000LM-FST-WD-MVOLT-GZ10-40K-80CRI OR APPROVED EQUAL BY HUBBELL OR METALUX	LED	120	SURFACE WALL	
<u> </u>	4" LED PENDANT CYLINDER FIXTURE	GOTHAM LTG #EVO4CC-35/25-AR-LSS-WD-MVOLT-GZ1-JBX-CCAN-C120-XX OR APPROVED EQUAL MANUFACTURER	LED	277	PENDANT	COLOR OF LEGISON BY ADOLUTEGE
` Q 1	4" LED PENDANT CYLINDER FIXTURE - HIGH LUMEN	GOTHAM LTG #EVO4CC-35/50-AR-LSS-MD-MVOLT-GZ1-JBX-CCAN-C120-XX	LED	277	PENDANT	COLOR SELECTION BY ARCHITECT.
2	4" LED PENDANT CYLINDER FIXTURE	OR APPROVED EQUAL MANUFACTURER GOTHAM LTG #EVO4CC-35/35-AR-LSS-MWD-MVOLT-GZ1-JBX-CCAN-C120-XX OR APPROVED EQUAL MANUFACTURER	LED	277	PENDANT	COLOR SELECTION BY ARCHITECT.
?	4" LED RECESSED DOWN LIGHT - HIGH LUMEN	GOTHAM LTG #EVO4-35/50-AR-LSS-MD-MVOLT-GZ1 OR APPROVED EQUAL MANUFACTURER	LED	277	RECESSED	COLOR SELECTION BY ARCHITECT.
21	4" LED RECESSED DOWN LIGHT	GOTHAM LTG #EVO4-35/35-AR-LSS-MWD-MVOLT-GZ1 OR APPROVED EQUAL MANUFACTURER	LED	277	RECESSED	
2	4" LED RECESSED DOWN LIGHT	GOTHAM LTG #EVO4-35/25-AR-LSS-WD-MVOLT-GZ1 OR APPROVED EQUAL MANUFACTURER	LED	277	RECESSED	
′	8' BY 8' LED SQUARE SHAPED PENDANT FIXTURE	AXIS #TB4DILEDPAT-S(8')-FF(32')-OPR(90)-600-1200-80-35-SO-SO-NL-C-UNV-DP-1-CA(60) OR APPROVED EQUAL MANUFACTURER	LED	277	SUSPENDED	
/ 1	8' BY 4' LED SQUARE SHAPED PENDANT FIXTURE	AXIS #TB4DLEDPAT-R(4'X8')-FF(24')-OPR(90)-1000-80-35-SO-NL-C-UNV-DP-1-CT15(12") OR APPROVED EQUAL MANUFACTURER	LED		SUSPENDED	CUSTOM COLOR SELECTION BY ARCHITECT.
/		AXIS #SCR-600-80-35-FL-2X2-W-UNV-DP-1-MFTB15		277		CUSTOM COLOR SELECTION BY ARCHITECT.
V	2' X 2' LED RECESSED FIXTURE	OR APPROVED EQUAL MANUFACTURER AXIS #SCR-600-80-35-FL-2X4-W-UNV-DP-1-MFTB15	LED	277	RECESSED	
V2	2' X 4' LED RECESSED FIXTURE	OR APPROVED EQUAL MANUFACTURER AXIS #SCR-600-80-35-FL-2X6-W-UNV-DP-1-MFTB15	LED	277	RECESSED	
V3	2' X 6' LED RECESSED FIXTURE	OR APPROVED EQUAL MANUFACTURER	LED	277	RECESSED	
V4	2' X 8' LED RECESSED FIXTURE	AXIS #SCR-600-80-35-FL-2X8-W-UNV-DP-1-MFTB15 OR APPROVED EQUAL MANUFACTURER	LED	277	RECESSED	
/	2' X 2' LED RECESSED FIXTURE	AXIS #SCR-500-80-35-FL-2X2-W-UNV-DP-1-MFTB15 OR APPROVED EQUAL MANUFACTURER	LED	277	RECESSED	COLOR SELECTION BY ARCHITECT.
7	2" LED RECESSED DOWN LIGHT	GOTHAM #EVO2-35/05-AR-LSS-WD-MVOLT-UGZ OR APPROVED EQUAL BY PORTFOLIO OR PRESCOLITE	LED	277	RECESSED	COLOR SELECTION BY ARCHITECT.
31	LED SINGLE HEAD FIXTURE ON 30' POLE	LITHONIA #RSX2-LED-P6-40K-R4-MVOLT-RPA-NLTAIR2-PIRHN-DBLXD OR EQUAL BY McGRAW EDISON OR BEACON	LED	277	POLE BASE	POLE LITHONIA #RSA306GDM19ASFBCVDDBL OR EQUAL BY McGRAW EDISON OR BEACON
32	LED (2) HEAD FIXTURE ON 30' POLE	LITHONIA (2) #RSX2-LED-P6-40K-R5-MVOLT-RPA-NLTAIR2-PIRHN-DBLXD	LED	277	POLE BASE	POLE LITHONIA #RSA306GDM28ASFBCVDDBL OR EQUAL BY McGRAW EDISON OR BEACON
		OR EQUAL BY McGRAW EDISON OR BEACON LITHONIA #RSX2-LED-P6-40K-R3-MVOLT-RPA-NLTAIR2-PIRHN-DBLXD				VERIFY COLOR SELECTION WITH ARCHITECT. POLE LITHONIA #RSA306GDM19ASFBCVDDBL OR EQUAL BY McGRAW EDISON OR BEACON
53	LED SINGLE HEAD FIXTURE ON 30' POLE	OR EQUAL BY McGRAW EDISON OR BEACON	LED	277	POLE BASE	OR EQUAL BY McGRAW EDISON OR BEACON VERIFY COLOR SELECTION WITH ARCHITECT.
7	LED WALL PACK	LITHONIA #WDGE2-LED-P5-40K-80CRI-VF-MVOLT-DBLXD OR APPROVED EQUAL	LED	277	WALL	VERIFY COLOR SELECTION WITH ARCHITECT.
8	6" RECESSED LED DOWN LIGHT	GOTHAM #EVO-35/30-6AR-MWD-LSS-MVOLT-EZ1 OR EQUAL BY PRESCOLITE OR PORTFOLIO	LED	277	RECESSED	
59	WALL MOUNT CYLINDER UP/DOWN LIGHT	GOTHAM #IC04UDWC-35-20-AR-LSS-20D-SHLD-U20LM-U20D-USHLD-MVOLT-GZ10-JBX-XX OR APPROVED EQUAL	LED	277	WALL	CUSTOM COLOR SELECTION BY ARCHITECT.
	LED EXIT FIXTURE	SURE-LITES #LPX-60-R-WH LITHONIA #LQM-S-W-3-R-120/277	INCLUDED	277	UNIVERSAL	SHADED PORTION DENOTES ORIENTATION. PROVIDE (2) FACE WHERE SHOWN OR REQUIRED
	LEG EMITTATORIE	DUAL LITE #LXURW	 	211	ONIVEROAL	WALL MOUNT WHERE POSSIBLE.
) WG	LED EXIT FIXTURE WITH WIRE GUARD	SURE-LITES #LPX-60-R-WH-WG-10 LITHONIA #LQM-S-W-3-R-120/277-WG	INCLUDED	277	UNIVERSAL	SHADED PORTION DENOTES ORIENTATION. PROVIDE (2) FACE WHERE SHOWN OR REQUIRED WALL MOUNT WHERE POSSIBLE.

LIGHTING FIXTURE NOTES:

CONTRACTOR SHALL PROVIDE POINT-BY-POINT CALCULATIONS TO THE ENGINEER FOR ALL
TYPICAL ROOMS IN THE BUILDING WITH THE SHOP DRAWING CUT SHEET SUBMITTALS USING THE
ACTUAL FIXTURES BEING SUBMITTED.

2. PROVIDE VIBRATION DAMPENING FOR ALL EXTERIOR POLES.


3. THE FOLLOWING MANUFACTURERS SHALL BE APPROVED EQUAL MANUFACTURERS FOR THE LIGHTING FIXTURES FOR THIS PROJECT: PHILLIPS DAYBRITE, PHILLIPS LIGHTOLIER, PHILLIPS GARDCO, PHILLIPS CHLORIDE, PHILLIPS LUMEC, FINELITE, INTENSE LIGHTING, ENVOY LIGHTING, NULITE, DAY-O-LITE, CREATIVE SYSTEMS LIGHTING, PMC LIGHTING, H. E. WILLIAMS, PINNACLE, G. E. LIGHTING, EMERGI-LITE, FORUM LIGHTING, FC LIGHTING, CYCLONE LIGHTING, AND LSI LIGHTING

4. ALL PENDANT MOUNTED LIGHTING FIXTURES IN OPEN CEILING AREAS SHALL BE SUSPENDED FROM THE STRUCTURE. MOUNTING TO THE ROOF DECK SHALL NOT BE PERMITTED. PROVIDE UNISTRUT SUPPORT AS NEEDED BETWEEN STRUCTURAL ELEMENTS FOR FIXTURE MOUNTING. COORDINATE ALL EXTERIOR LIGHTING FIXTURE LOCATIONS AND MOUNTING HEIGHTS WITH THE ARCHITECT PRIOR TO ROUGH-IN.

LI	GHTING FIXTURE SYMBOL KEY
SYMBOL	DESCRIPTION
А	2' x 4' LAY-IN FIXTURE
A	1' x 4' LAY-IN FIXTURE
$\alpha_{\mathbb{A}}$	RECESSED DOWN LIGHT
⊢ V V V A	TRACK LIGHTING
A	HATCHING DENOTES FIXTURE ON EMERGENCY POWER.
A NL	"NL" DENOTES NIGHT LIGHT. WIRE FOR CONTINUOUS OPERATION.

SYMBOL	DESCRIPTION
\$	HUBBELL #HBL1221-I SINGLE POLE TOGGLE SWITCH 20A 120-277V
\$ 3	HUBBELL #HBL1223-I 3 WAY TOGGLE SWITCH 20A 120-277V
\$,	HUBBELL #HBL1224-I 4 WAY TOGGLE SWITCH 20A 120-277V
\$ 5	LEVITON #IP710-LFZ 0-10V LED SLIDE DIMMER WITH ON/OFF SWITCH
\$	LEVITON #IP710-LFZ
+ D3 +	3-WAY 0-10V SLIDE DIMMER WITH ON/OFF SWITCH HUBBELL #HBL1221RKL
<u> </u>	20A BARREL LOCK AND KEYED SWITCH - SINGLE POLE HUBBELL #AD200011
Pos —	DUAL TECHNOLOGY OCCUPANCY SENSOR/WALL SWITCH LEVITON #IPV15
Tys The state of t	DUAL TECHNOLOGY VACANCY SENSOR/WALL SWITCH HUBBELL
<u> </u>	LOW VOLTAGE PUSH BUTTON SWITCH
\$ _T	INTERMATIC #FF12HC SPRING WOUND TIMER SWITCH
XX	LOW VOLTAGE SWITCH
DX	LOW VOLTAGE TOUCH SCREEN DIMMING CONTROL SWITCH
	HUBBELL #HBL5362-I-TR 20A TAMPER RESISTANT DUPLEX RECEPTACLE 125 VOLT WITH BRASS BACK STRAP
	QUANTITY OF 2 HUBBELL #HBL5362-I-TR WITH BRASS BACK STRAP 2-20AMP 125VOLT TAMPER RESISTANT DUPLEX RECEPTACLES INSTALLED IN ONE 4" SQUARE BOX
°	DOT DENOTES TO INSTALL DEVICE ABOVE COUNTER TOP SEE ARCHITECTURAL DRAWINGS. COORDINATE AS NECESSARY. VERIFY MOUNTING HEIGHTS.
G OR GFI	HUBBELL #GFRST20I - WP DENOTES WEATHER PROOF COVER GFCI DUPLEX RECEPTACLE
G OR GFI	HUBBELL #GFTRST20I TAMPER RESISTANT GFCI DUPLEX RECEPTACLE
USB	HUBBELL #USB20AC5I 20A USB TAMPER RESISTANT DUPLEX RECEPTACLE 125 VOLT WITH BRASS BACK STRAP
	HUBBELL 30A, 208 VOLT, 1 PHASE RECEPTACLE
1-1	HUBBELL #HBL2611 L5-30P 30A, 120 VOLT, 1 PHASE RECEPTACLE
	HUBBELL
	208 VOLT, 4 WIRE DRYER OUTLET - 30A HUBBELL #S1R8PTFIT2 FIRE RATED POKE THROUGH WITH A #S1R8CVRALU COVER. PROVIDE (2) #S1R8PSPZ 20A DUPLEX RECEPTACLES AND (3) #S1R8CSPK STYLE LINE DECORATOR OPENINGS. FINAL
(°)	COLOR SELECTIONS SHALL BE BY ARCHITECT. STUB (2) 1" BUSHED CONDUITS BELOW FLOOR, UP AN ADJACENT WALL, AND TO NEAREST CABLE TRAY.
	HUBBELL 208 VOLT, 1 PHASE, 20 AMP RECEPTACLE
0	HUBBELL #CFB6G30RCR WITH A #CFBS1R8CVRALU COVER PROVIDE (4) #FBMPDUB DUPLEX COVERS AND (2) #FBMPBNK BLANK COVERS. PROVIDE (4) 20A, 125V DUPLEX RECEPTACLES. FINAL COLOR SELECTION SHALL BE BY THE ARCHITECT.
	STUB TWO (2) 1" BUSHED CONDUITS BELOW THE FLOOR AND UP AN ADJACENT WALL TO ABOVE ACCESSIBLE CEILING FOR VOICE/DATA. HUBBELL #CFB4G30RCR WITH A #CFBS1R8CVRALU COVER
	PROVIDE (2) #FBMPDUB DUPLEX COVERS AND (2) #FBMPBNK BLANK COVERS. PROVIDE (2) 20A, 125V DUPLEX RECEPTACLES. FINAL COLOR SELECTION SHALL BE BY THE ARCHITECT. STUB TWO (2) 1" BUSHED CONDUITS BELOW THE FLOOR AND UP AN ADJACENT WALL TO ABOVE ACCESSIBLE CEILING FOR VOICE/DATA.
•	HUBBELL #CFB4G30RCR WITH A #CFBS1R8CVRALU COVER PROVIDE (2) #FBMPDUB DUPLEX COVERS AND (2) #FBMPBNK BLANK COVERS. PROVIDE (2) 20A, 125V DUPLEX RECEPTACLES. FINAL COLOR SELECTION SHALL BE BY THE ARCHITECT. STUB TWO (2) 1" BUSHED CONDUITS BELOW THE FLOOR AND UP AN ADJACENT WALL TO ABOVE ACCESSIBLE CEILING FOR VOICE/DATA.
\bigotimes	HUBBELL 20 AMP, 208 VOLT, 1 PHASE RECEPTACLE - PEDESTAL MOUNTED
	HUBBELL 20 AMP, 125 VOLT GFCI DUPLEX RECEPTACLE - PEDESTAL MOUNTED
•	CORD REEL HUBBELL #HBLC40123TT
, OP	HUBBELL #HBL5352-I 20A DUPLEX RECEPTACLE 125 VOLT WITH BRASS BACK STRAP PROTECTED UPSTREAM BY GFCI CIRCUIT BREAKER OR GFCI OUTLET
F	MANUAL ADDRESSABLE PULL STATION. MOUNT AT +46" A.F.F. TO THE CENTER OF THE DEVICE.
V F	HORN/STROBE UNIT 6" DOWN FROM FINISHED CEILING BUT MAX. OF 80" ABOVE FINISHED FLOOR
\I/	ADA STROBE UNIT 6" DOWN FROM FINISHED CEILING BUT MAX. OF 80" ABOVE FINISHED FLOOR - MINI UNIT
SD >	
<u></u>	SMOKE DETECTOR
(DD)	SMOKE DETECTOR FOR ELEVATOR RECALL
	DUCT SMOKE DETECTOR WITH REMOTE TEST/STATUS PANEL
(HD)	HEAT DETECTOR
(00)	CARBON MONOXIDE DETECTOR
(DH)	FIRE ALARM SYSTEM MAGNETIC DOOR HOLD OPEN DEVICE
(FS)	FLOW SWITCH - PROVIDE MONITOR ZONE MODULE (ZAM)
TS	TAMPER SWITCH - PROVIDE MONITOR ZONE MODULE (ZAM)
	FUSED OR NONFUSED DISCONNECT AS NOTED ON DRAWINGS OR EQUIPMENT SCHEDULE(S).
	FUSIBLE COMBINATION STARTER - SIZE AS NOTED ON DRAWINGS
J	JUNCTION BOX - SIZE AS REQUIRED
JA	PROVIDE 120V CIRCUIT AND WIRING FOR THE DOOR HARDWARE TRANSFORMER AND MAKE ALL CONNECTIONS AS REQUIRED
\$ _M	MANUAL MOTOR STARTER
Е	DENOTES EMERGENCY POWER CIRCUIT.
Js	SENSOR (ELECTRONIC) FLUSH VALVE CONNECTION. THE SENSOR SHALL BE FLUSH IN THE WALL AND ALL TRANSFORMERS AND WIRING SHALL BE CONCEALED ABOVE ACCESSIBLE CEILING. EXTEND THE LOW VOLTAGE WIRING TO EACH SENSOR CONCEALED.
ED PP	ELECTRIC DOOR OPERATOR AND WALL PUSH PLATE. PROVIDE ALL CONDUIT, WIRING, BACK BOXES, ETC. AS REQUIRED.
HD	HAND DRYER CONNECTION AS REQUIRED.
(OS)	HUBBELL #ATD2000CRP SENSOR, #CU300A POWER PACK
	24VDC DUAL TECHNOLOGY OCCUPANCY SENSOR HUBBELL #ATD1600WRP SENSOR, #CU300M POWER PACK, 24VDC DUAL TECHNOLOGY WALL MOUNTED VACANCY SENSOR
VS _W	TIE WALL SWITCH OR DIMMER INTO THE POWER PACK AS REQUIRED FOR MANUAL-ON OPERATION LEVITON #ATD2000CRP SENSOR, #CU300M POWER PACK, 24VDC DUAL TECHNOLOGY VACANCY SENSOR
(VS)	TIE WALL SWITCH OR DIMMER INTO THE POWER PACK AS REQUIRED FOR MANUAL-ON OPERATION
1 = 7	GENERATOR EMERGENCY STOP PUSH BUTTON

2203-2







MASSILLON CITY SCHOOLS

ILLON EAST ELEMENTARY PK-3

E BROWN DRIVE SE, MASSILLON, OHIO 44646

ON CITY SCHOOL DISTRICT MASSILLON, OHIO

PROJECT NO 2203-2 DRAWN BY WAM CHECKED BY TJC

DATE 07/12/23

SYMBOLS AND SCHEDULES

SHEET NO E-402