



CODED PLAN NOTES

1. PROVIDE 18" W CABLE RUNWAY.
2. PROVIDE TELECOMMUNICATIONS MAIN GROUNDING BUSBAR "TMGB".
3. PROVIDE 4' x 8' AC GRADE PLYWOOD BACKBOARD. MOUNT BOARDS 6" AFF WITH 'A' SIDE FACING TOWARDS USER (TYPICAL).
4. PROVIDE 4-POST TECHNOLOGY DISTRIBUTION RACK.
5. PROVIDE 6" WIDE VERTICAL WIRE MANAGER ON BOTH ENDS OF LINE OF RACKS AND 10" WIDE VERTICAL WIRE MANAGERS BETWEEN EACH RACK.
6. BOND EACH RACK WITH A DEDICATED BONDING CONDUCTOR WITH A CABLE SIZED AT 2 KCMIL PER LINEAR FOOT OF CONDUCTOR TO TMGB. BONDING CONDUCTOR SHALL BE NO LESS THAN #6 AWG.
7. 2U FIBER LIU.
8. 2U HORIZONTAL WIRE MANAGER.
9. 2U 48-PORT PATCH PANEL FOR BACKBONE CABLING.
10. 2U 48-PORT PATCH PANEL FOR CAT 6 UTP CABLING.
11. 2U 48-PORT PATCH PANEL FOR CAT 6A UTP CABLING.
12. SPACE FOR OWNER-PROVIDED NETWORK SWITCH.
13. SPACE FOR OWNER-PROVIDED UPS.
14. APPROXIMATE LOCATION OF CABLE TRAY ENTERING ROOM. REFER TO PATHWAYS DRAWINGS FOR ADDITIONAL INFORMATION. CONTRACTOR SHALL PROVIDE CABLE WATERFALL AT CABLE TRAY.
15. APPROXIMATE LOCATION OF CABLE TRAY LOCATED IN CEILING SPACE BELOW. REFER TO PATHWAYS DRAWINGS FOR ADDITIONAL INFORMATION.
16. CONTRACTOR SHALL PROVIDE (3) 4" C. SLEEVES INTO CEILING SPACE BELOW.
17. CONTRACTOR SHALL PROVIDE 18" W. CABLE RUNWAY VERTICALLY ON WALL.

PROJECT NO  
2203-2

ARCHITECTURAL VISION GROUP, LTD  
PLANNERS  
ARCHITECTS  
23850 SPERRY DRIVE  
CLEVELAND, OHIO 44145

STATE OF OHIO  
PROFESSIONAL SEAL  
ANTHONY J. BROWN  
REGISTERED PROFESSIONAL ELECTRICAL ENGINEER  
EXPIRES 12-31-24  
P.E.C. # 21183018  
Dana R. Knecht  
www.osborn-eng.com

OSBORN  
ENGINEERING  
1100 Superior Avenue, Suite 202, Cleveland, OH 44114  
216.891.8020  
www.osborn-eng.com

MASSILLON CITY SCHOOL DISTRICT  
MASSILLON EAST ELEMENTARY PK-3  
1 PAULE BROWN DRIVE SE, MASSILLON, OHIO 44646  
MASSILLON CITY SCHOOL DISTRICT MASSILLON, OHIO

PROJECT NO 2203-2  
DRAWN BY DRK  
CHECKED BY AMW  
DATE 07/12/23

TECHNOLOGY  
ENLARGED  
PLANS AND  
ELEVATIONS  
SCALE: As Indicated  
SHEET NO  
T-403