


#	Name	Parameter	Min	Max	Average	Mean/Min	Max/Min
1	Calculation Surface	Perpendicular Illuminance	0.002 fc	21.6 fc	2.20 fc	1394	13682

Luminaire list (Site 1)							
Index	Manufacturer	Article name	Item number	Fitting	Luminous flux	Light loss factor	Connected load
S3	LITHONIA	W50 LED with P3 PERFORMANCE PACKAGE, 4000K CCT, 5000 LUMENS, 4000 MVOLT, 5000 LUMENS	W50 LED P3 SR4 40K MVOLT	1x	4666 lm	0.80	39.3 W
S1 & S2	LITHONIA	Q-Series Spot 1: New Luminaire P3 Performance Package 4200K CCT 3500 LUMENS, 4000 MVOLT, 4000 LUMENS	QX1 LED P3 40K 7020 TSM	1x	35509 lm	0.80	277.1 W



PHOTOMETRIC SITE PLAN
SCALE: 1" = 40'-0"

PROJECT NO
2203-2

ARCHITECTURAL VISION GROUP, LTD
PLANNERS
ARCHITECTS
23850 SPERRY DRIVE
CLEVELAND, OHIO 44145

MASSILLON CITY SCHOOLS
MASSILLON EAST ELEMENTARY PK-3
1 PAUL E BROWN DRIVE SE, MASSILLON, OHIO 44646
MASSILLON CITY SCHOOL DISTRICT
MASSILLON, OHIO

MARK	DATE	DESCRIPTION
6/30/23 <td>6/30/23<td>DESIGN DEVELOPMENT</td></td>	6/30/23 <td>DESIGN DEVELOPMENT</td>	DESIGN DEVELOPMENT
ISSUED AS:		

PROJECT NO
2203-2

DRAWN BY
T.J.C.

CHECKED BY
T.J.C.

DATE
6/30/2023

PHOTOMETRIC
SITE PLAN
SCALE: AS NOTED

SHEET NO
ES001