

## SECTION 104413 - FIRE EXTINGUISHER CABINETS

## PART 1 - GENERAL

## 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

## 1.2 SUMMARY

- A. Section Includes:

- 1. Fire protection cabinets for the following:

- a. Portable fire extinguishers.
    - b. Fire hose valves.

- B. Related Sections:

- 1. Section 104416 "Fire Extinguishers."
  - 2. Section "Facility Fire-Suppression Water-Service Piping" for hose systems, racks, and valves.

## 1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product indicated. Include construction details, material descriptions, dimensions of individual components and profiles, and finishes for fire protection cabinets.

- 1. Fire Protection Cabinets: Include roughing-in dimensions, details showing mounting methods, relationships of box and trim to surrounding construction, door hardware, cabinet type, trim style, and panel style.
  - 2. Show location of knockouts for hose valves.

- B. Product Schedule: For fire protection cabinets. Coordinate final fire protection cabinet schedule with fire extinguisher schedule to ensure proper fit and function.

## 1.4 CLOSEOUT SUBMITTALS

- A. Maintenance Data: For fire protection cabinets to include in maintenance manuals.

## 1.5 QUALITY ASSURANCE

- A. Fire-Rated, Fire Protection Cabinets: Listed and labeled to comply with requirements in ASTM E 814 for fire-resistance rating of walls where they are installed.

## 1.6 COORDINATION

- A. Coordinate size of fire protection cabinets to ensure that type and capacity of fire extinguishers indicated are accommodated.
- B. Coordinate size of fire protection cabinets to ensure that type and capacity of hose valves indicated are accommodated.
- C. Coordinate sizes and locations of fire protection cabinets with wall depths.

## PART 2 - PRODUCTS

### 2.1 MATERIALS

- A. Cold-Rolled Steel Sheet: ASTM A 1008/A 1008M, Commercial Steel (CS), Type B.
- B. Tempered Float Glass: ASTM C 1048, Kind FT, Condition A, Type I, Quality q3, 3 mm thick, Class 1 (clear).

### 2.2 FIRE PROTECTION CABINET (FEC-1)

- A. Cabinet Type: Suitable for fire extinguisher.
  - 1. Products: Subject to compliance with requirements, provide one of the following:
    - a. J. L. Industries, Inc., a division of Activar Construction Products Group; Ambassador Series.
    - b. Larsen's Manufacturing Company; Architectural Series.
    - c. Moon-American; Architectural Series.
- B. Cabinet Construction: Nonrated.
- C. Cabinet Material: Steel sheet.
- D. Semirecessed Cabinet: Cabinet box partially recessed in walls of sufficient depth to suit style of trim indicated; with one-piece combination trim and perimeter door frame overlapping surrounding wall surface with exposed trim face and wall return at outer edge (backbend). Provide where walls are of insufficient depth for recessed cabinets but are of sufficient depth to accommodate semirecessed cabinet installation.
  - 1. Rolled-Edge Trim: 2-1/2-inch (64-mm) backbend depth, minimum.
- E. Cabinet Trim Material: Steel sheet.

- F. Door Material: Steel sheet.
- G. Door Style: Vertical duo panel with frame.
- H. Door Glazing: Tempered float glass (clear).
- I. Door Hardware: Manufacturer's standard door-operating hardware of proper type for cabinet type, trim style, and door material and style indicated.
  - 1. Provide projecting lever handle with cam-action latch.
  - 2. Provide continuous hinge, of same material and finish as trim, permitting door to open 180 degrees.
- J. Accessories:
  - 1. Mounting Bracket: Manufacturer's standard steel, designed to secure fire extinguisher to fire protection cabinet, of sizes required for types and capacities of fire extinguishers indicated, with plated or baked-enamel finish.
  - 2. Door Lock: Cam lock that allows door to be opened during emergency by pulling sharply on door handle.
  - 3. Identification: Lettering complying with authorities having jurisdiction for letter style, size, spacing, and location.
    - a. Identify fire extinguisher in fire protection cabinet with the words "FIRE EXTINGUISHER ."
      - 1) Location: Applied to cabinet door.
      - 2) Application Process: Pressure-sensitive vinyl letters.
      - 3) Lettering Color: Red.
      - 4) Orientation: Vertical.
- K. Finishes:
  - 1. Manufacturer's standard baked-enamel paint for the following:
    - a. Exterior of cabinet door and trim except for those surfaces indicated to receive another finish.
    - b. Interior of cabinet and door.
  - 2. Steel: Baked enamel or powder coat.

## 2.3 FIRE PROTECTION CABINET (FEC-2)

- A. Cabinet Type: Suitable for fire extinguisher.
  - 1. Products: Subject to compliance with requirements, provide one of the following:
    - a. J. L. Industries, Inc., a division of Activar Construction Products Group; Ambassador Series.
    - b. Larsen's Manufacturing Company; Architectural Series.

- c. Moon-American; Architectural Series.
- B. Cabinet Material: Steel sheet.
- C. Semirecessed Cabinet: Cabinet box partially recessed in walls of sufficient depth to suit style of trim indicated; with one-piece combination trim and perimeter door frame overlapping surrounding wall surface with exposed trim face and wall return at outer edge (backbend). Provide where walls are of insufficient depth for recessed cabinets but are of sufficient depth to accommodate semirecessed cabinet installation.
  - 1. Rolled-Edge Trim: 2-1/2-inch (64-mm) backbend depth.
- D. Cabinet Trim Material: Steel sheet.
- E. Door Material: Steel sheet.
- F. Door Style: Solid opaque panel with frame.
- G. Door Hardware: Manufacturer's standard door-operating hardware of proper type for cabinet type, trim style, and door material and style indicated.
  - 1. Provide projecting lever handle with cam-action latch.
  - 2. Provide continuous hinge, of same material and finish as trim, permitting door to open 180 degrees.
- H. Accessories:
  - 1. Mounting Bracket: Manufacturer's standard steel, designed to secure fire extinguisher to fire protection cabinet, of sizes required for types and capacities of fire extinguishers indicated, with plated or baked-enamel finish.
  - 2. Door Lock: Cam lock that allows door to be opened during emergency by pulling sharply on door handle.
  - 3. Identification: Lettering complying with authorities having jurisdiction for letter style, size, spacing, and location.
    - a. Identify fire extinguisher in fire protection cabinet with the words "FIRE EXTINGUISHER."
      - 1) Location: Applied to cabinet door.
      - 2) Application Process: Pressure-sensitive vinyl letters.
      - 3) Lettering Color: Red.
      - 4) Orientation: Vertical.
- I. Finishes:
  - 1. Manufacturer's standard baked-enamel paint for the following:
    - a. Exterior of cabinet door and trim except for those surfaces indicated to receive another finish.
    - b. Interior of cabinet and door.

2. Steel: Baked enamel or powder coat.

## 2.4 FIRE PROTECTION CABINET (FEC-3)

### A. Cabinet Type: Suitable for fire extinguisher.

1. Products: Subject to compliance with requirements, provide one of the following:

- a. J. L. Industries, Inc., a division of Activar Construction Products Group; Ambassador Series FX.
- b. Larsen's Manufacturing Company; Architectural Series, Flame Shield.
- c. Moon-American; Architectural Series, Flame Shield.

### B. Cabinet Construction: 1-hour fire rated.

1. Fire-Rated Cabinets: Construct fire-rated cabinets with double walls fabricated from 0.0428-inch- (1.1-mm-) thick, cold-rolled steel sheet lined with minimum 5/8-inch- (16-mm-) thick, fire-barrier material. Provide factory-drilled mounting holes.

### C. Cabinet Material: Steel sheet.

### D. Semirecessed Cabinet: Cabinet box partially recessed in walls of sufficient depth to suit style of trim indicated; with one-piece combination trim and perimeter door frame overlapping surrounding wall surface with exposed trim face and wall return at outer edge (backbend). Provide where walls are of insufficient depth for recessed cabinets but are of sufficient depth to accommodate semirecessed cabinet installation.

1. Rolled-Edge Trim: 2-1/2-inch (64-mm) backbend depth.

### E. Cabinet Trim Material: Steel sheet.

### F. Door Material: Steel sheet.

### G. Door Style: Vertical duo panel with frame.

### H. Door Glazing: Tempered float glass (clear).

### I. Door Hardware: Manufacturer's standard door-operating hardware of proper type for cabinet type, trim style, and door material and style indicated.

1. Provide projecting lever handle with cam-action latch.
2. Provide continuous hinge, of same material and finish as trim, permitting door to open 180 degrees.

### J. Accessories:

1. Mounting Bracket: Manufacturer's standard steel, designed to secure fire extinguisher to fire protection cabinet, of sizes required for types and capacities of fire extinguishers indicated, with plated or baked-enamel finish.

2. Door Lock: Cam lock that allows door to be opened during emergency by pulling sharply on door handle.
3. Identification: Lettering complying with authorities having jurisdiction for letter style, size, spacing, and location.
  - a. Identify fire extinguisher in fire protection cabinet with the words "FIRE EXTINGUISHER."
    - 1) Location: Applied to cabinet door cabinet glazing location indicated on Drawings.
    - 2) Application Process: Silk-screened Engraved Etched Decals Pressure-sensitive vinyl letters.
    - 3) Lettering Color: Red.
    - 4) Orientation: Vertical.

K. Finishes:

1. Manufacturer's standard baked-enamel paint for the following:
  - a. Exterior of cabinet door and trim except for those surfaces indicated to receive another finish.
  - b. Interior of cabinet and door.
2. Steel: Baked enamel or powder coat.

2.5 FIRE PROTECTION CABINET (VC-1)

A. Cabinet Type: Suitable for fire hose valve.

1. Products: Subject to compliance with requirements, provide one of the following:
  - a. J. L. Industries, Inc., a division of Activar Construction Products Group; Crowline Series, 8516.
  - b. Larsen's Manufacturing Company; VC 1818RK.
  - c. Moon-American; VC 1818RK.

B. Cabinet Construction: Nonrated.

C. Cabinet Material: Steel sheet.

D. Semirecessed Cabinet: Cabinet box partially recessed in walls of sufficient depth to suit style of trim indicated; with one-piece combination trim and perimeter door frame overlapping surrounding wall surface with exposed trim face and wall return at outer edge (backbend). Provide where walls are of insufficient depth for recessed cabinets but are of sufficient depth to accommodate semirecessed cabinet installation.

1. Square-Edge Trim: 1-1/4 (32-mm) backbend depth.

E. Cabinet Trim Material: Steel sheet.

- F. Door Material: Steel sheet.
- G. Door Style: Solid opaque panel with frame.
- H. Door Hardware: Manufacturer's standard door-operating hardware of proper type for cabinet type, trim style, and door material and style indicated.
  - 1. Provide projecting lever handle with cam-action latch.
  - 2. Provide continuous hinge, of same material and finish as trim, permitting door to open 180 degrees.
- I. Accessories:
  - 1. Mounting Bracket: Manufacturer's standard steel, designed to secure fire extinguisher to fire protection cabinet, of sizes required for types and capacities of fire extinguishers indicated, with plated or baked-enamel finish.
  - 2. Door Lock: Cylinder lock, keyed alike to other cabinets.
  - 3. Identification: Lettering complying with authorities having jurisdiction for letter style, size, spacing, and location.
    - a. Identify fire extinguisher in fire protection cabinet with the words "FIRE DEPT CONNECTION."
      - 1) Location: Applied to cabinet door.
      - 2) Application Process: Pressure-sensitive vinyl letters.
      - 3) Lettering Color: Red.
      - 4) Orientation: Vertical.
- J. Finishes:
  - 1. Manufacturer's standard baked-enamel paint for the following:
    - a. Exterior of cabinet door and trim except for those surfaces indicated to receive another finish.
    - b. Interior of cabinet and door.
  - 2. Steel: Baked enamel or powder coat.

## 2.6 FABRICATION

- A. Fire Protection Cabinets: Provide manufacturer's standard box (tub) with trim, frame, door, and hardware to suit cabinet type, trim style, and door style indicated.
  - 1. Weld joints and grind smooth.
  - 2. Provide factory-drilled mounting holes.
  - 3. Prepare doors and frames to receive locks.
  - 4. Install door locks at factory.
- B. Cabinet Doors: Fabricate doors according to manufacturer's standards, from materials indicated and coordinated with cabinet types and trim styles selected.

1. Fabricate door frames with tubular stiles and rails and hollow-metal design, minimum 1/2 inch (13 mm) thick.
  2. Fabricate door frames of one-piece construction with edges flanged.
  3. Miter and weld perimeter door frames.
- C. Cabinet Trim: Fabricate cabinet trim in one piece with corners mitered, welded, and ground smooth.

## 2.7 GENERAL FINISH REQUIREMENTS

- A. Comply with NAAMM's "Metal Finishes Manual for Architectural and Metal Products" for recommendations for applying and designating finishes.
- B. Protect mechanical finishes on exposed surfaces of fire protection cabinets from damage by applying a strippable, temporary protective covering before shipping.
- C. Finish fire protection cabinets after assembly.
- D. Appearance of Finished Work: Noticeable variations in same piece are not acceptable. Variations in appearance of adjoining components are acceptable if they are within the range of approved Samples and are assembled or installed to minimize contrast.

## 2.8 STEEL FINISHES

- A. Surface Preparation: Remove mill scale and rust, if present, from uncoated steel, complying with SSPC-SP 5/NACE No. 1, "White Metal Blast Cleaning" or SSPC-SP 8, "Pickling". After cleaning, apply a conversion coating suited to the organic coating to be applied over it.
- B. Baked-Enamel or Powder-Coat Finish: Immediately after cleaning and pretreating, apply manufacturer's standard two-coat, baked-on finish consisting of prime coat and thermosetting topcoat. Comply with coating manufacturer's written instructions for applying and baking to achieve a minimum dry film thickness of 2 mils (0.05 mm).

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- A. Examine roughing-in for hose valves and cabinets to verify actual locations of piping connections before cabinet installation.
- B. Examine walls and partitions for suitable framing depth and blocking where semirecessed cabinets will be installed.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.



### 3.2 PREPARATION

- A. Prepare recesses for semirecessed fire protection cabinets as required by type and size of cabinet and trim style.

### 3.3 INSTALLATION

- A. General: Install fire protection cabinets in locations and at mounting heights indicated .
- B. Fire Protection Cabinets: Fasten cabinets to structure, square and plumb.
  - 1. Fasten mounting brackets to inside surface of fire protection cabinets, square and plumb.
  - 2. Valve Cabinets:
    - a. Install cabinet with not more than 1/16-inch (1.6-mm) tolerance between pipe OD and knockout OD. Center pipe within knockout.
- C. Identification: Apply vinyl lettering at locations indicated.

### 3.4 ADJUSTING AND CLEANING

- A. Remove temporary protective coverings and strippable films, if any, as fire protection cabinets are installed unless otherwise indicated in manufacturer's written installation instructions.
- B. Adjust fire protection cabinet doors to operate easily without binding. Verify that integral locking devices operate properly.
- C. On completion of fire protection cabinet installation, clean interior and exterior surfaces as recommended by manufacturer.
- D. Touch up marred finishes, or replace fire protection cabinets that cannot be restored to factory-finished appearance. Use only materials and procedures recommended or furnished by fire protection cabinet and mounting bracket manufacturers.
- E. Replace fire protection cabinets that have been damaged or have deteriorated beyond successful repair by finish touchup or similar minor repair procedures.

END OF SECTION 104413

THIS PAGE INTENTIONALLY LEFT BLANK