SECTION 233726 - ROOF CURBS

PART 1-GENERAL

- 1.1 SECTION INCLUDES
 - A. Roof curbs for equipment mounting.

1.2 SUBMITTALS

- A. Submit shop drawings and product data per applicable Division I Specifications.
- B. Shop drawing shall include material, quantities, and dimensions.

1.3 WARRANTY

A. Contractor shall warranty entire systems and equipment for a period of one (1) year.

PART 2-PRODUCTS

2.1 MANUFACTURERS

- A. Pate
- B. Thy Curb.
- C. RPS Systems

2.2 COMPONENTS

- A. Roof Curbs
 - 1. Minimum height shall be 24".
 - 2. Roof curb shall be constructed of galvanized steel with welded corner beads and pressure treated 2 by 2 wood nailer.
 - 3. Curbs shall be pre-insulated with 1-1/2 inch rigid insulation.
 - 4. Top of curb shall be set dead level.
 - 5. Base of curb shall match roof slope.

PART 3-EXECUTION

- 3.1 INSTALLATION
 - A. Roof curbs and equipment rails shall be mounted with top dead level, properly anchored to the deck.
 - B. All roof curbs shall be furnished and set by mechanical contractor. Cutting of opening is by

Mechanical Contractor. Flashing is by the General Contractor.

END OF SECTION 233726