



CODED NOTES:

NOZZLE.

- (1) 6" RDL FROM ABOVE. PROVIDE CLEANOUT AT BASE OF STACK. SEE SHEET P-101-B FOR CON'T. 2 PROVIDE AND INSTALL SOLENOID VALVE TO BE INTERLOCKED WITH HOOD CONTROL PANEL TO SHUT OFF GAS SUPPLY TO THE EQUIPMENT IN THE EVENT OF FIRE. INSTALL VALVE AT PIPE
- DROP AND BELOW CEILING.
- (3) 1/2" CW AND HW LINE DOWN FOR CONNECTION TO FIXTURE. 4 2" GAS LINE DOWN WITH SHUT OFF VALVE AND HEADER FULL SIZE FOR CONNECTION TO EQUIPMENT.
- 5 3/4" CW LINE DOWN FOR CONNECTION TO WH AT 2'-0" A.F.F.
- (6) 6" RDL DOWN. SEE SHEET P-101-B FOR CON'T.
- 7 6" EMERGENCY ROOF DRAIN LEADER TRU WALL ABOVE CEILING WITH J.R. SMITH (WATTS OR ZURN) NO. 1770 DOWNSPOUT
- 8 BALANCE VALVE AND CHECK VALVE. SET BALANCE VALVE TO FLOW INDICATED ON DRAWING.
- 9 3/4" CW AND HW ROUTED TO 1071 THERMOSTATIC MIXING VALVE AND 3/4" TEPID WATER ROUTED TO EEW.
- 10 1/2" CW AND HW LINES DOWN FOR CONNECTION TO FIXTURE WITH ASSE 1070 MIXING VALVE.
- (11) 1/2" CW LINE DOWN TO FILTER WITH WATTS LF009QT BFP. (12) 3/4" CW LINE DOWN TO FILTER WITH WATTS LF009QT BFP.
- (13) 3/4" CW LINE DOWN TO EQUIPMENT WITH WATTS LF009QT BFP.
- (14) 3/4" CW LINE UP TO ROOF HYDRANT.
- (15) 3/4" (7"-14" W.C.) GAS LINE TO EQUIPMENT.
- (16) 1" (7"-14" W.C.) GAS LINE TO EQUIPMENT.
- 17) 1 1/4" (7"-14" W.C.) GAS LINE UP FOR CONNECTION TO EQUIPMENT WITH UNION, SHUT OFF VALVE, AND DIRT LEG.
- (18) 1/2" CW AND HW LINES DOWN FOR CONNECTION TO EQUIPMENT.
- (19) 1/2" CW LINE DOWN FOR CONNECTION TO DRAIN WATER TEMPERING KIT WITH WATTS LF009QT BFP.

(20) 1/2" HW LINE DOWN FOR CONNECTION TO FIXTURE.

		ווח
ITEM	CONN#	PLl
2		STACKE REQUIRI
3		MOP SIN ROUGH-
5		(1) REQL
6		(1) REQU COOLER
17	(1)	(1) EACH (SPLASH
17	(2)	(1) REQU PREP SI
19	(1)	(1) EACH (HAND S
19	(2)	(1) REQL (HAND S
23	(1)	(1) REQU (ICE CUE
23	(2)	(1) EACH (ICE CUE
23	(3)	(1) EACH (ICE CUE
27	(1)	(1) REQU (PRE-RIN
27	(2)	(1) REQU SINK).
30	(1)	(1) REQU (EYE WA
30	(2)	(1) REQU (EYE WA
33	(1)	(1) REQU (DISHWA
33	(2)	(1) REQL
33	(3)	(1) REQU COMPON
34		(1) EACH MIXING I COMPON
35	(1)	(1) EACH (FOOD V
35	(2)	(1) REQU (FOOD V
41		(1) REQU SEE GAS DEVICE
42		(1) REQU ROUGH-
43	(1)	(1) EACH (30 GALL
43	(2)	(1) REQU MIN 11
44		(1) REQU PLUMBIN CONVEC
45	(1)	(1) REQU SYSTEM
45	(2)	(1) REQU
45	(3)	(1) REQU (COMBI-0
45	(4)	(1) REQU CONTRA
45	(5)	(1) REQU CONTRA
63		(1) REQI (COLD F
64		(1) REQU EXTEND
69		(1) REQU EXTEND
70		(1) REQU (COLD F

12

11

10

UMBING CONNECTION SCHEDULE DESCRIPTION ED WASHER / DRYER ... THIS EQUIPMENT IS SUPPLIED BY OTHERS .. PLUMBING CONTRACTOR TO VERIFY ALL REMENTS PRIOR TO ROUGH-IN. INK & FAUCET ... ITEM IS SUPPLIED BY PLUMBER .. PLUMBING CONTRACTOR TO VERIFY ALL REQUIREMENTS PRIOR TO UIRED .. 3/4" INDIRECT WASTE; (COOLER EVAPORATOR COIL DRAIN) ; EXTEND TO FUNNEL FLOOR DRAIN. UIRED .. 3/4" INDIRECT WASTE; (FREEZER EVAPORATOR COIL DRAIN) ; EXTEND INTO COOLER AND INTERCONNECT WITH R DRAIN. NOTE: HEAT TAPE REQUIRED ON EXPOSED DRAIN LINE WITHIN FREEZER COMPARTMENT. CH REQUIRED .. 1/2" HOT WATER & 1/2" COLD WATER; AT 16" AFF.; EXTEND TO H MOUNT FAUCET) MOUNTED ON (2-COMPARTMENT PREP SINK). QUIRED .. 2" INDIRECT WASTE; MANIFOLD (2) SINK WASTES TO COMMON AND EXTEND TO FLOOR SINK.; (2-COMPARTMENT SINK WASTE). CH REQUIRED .. 1/2" HOT WATER & 1/2" COLD WATER; AT 16" AFF.; 9 SINK) . NOTE: (3) LOCATIONS ON PLAN. QUIRED .. 1-1/2" DIRECT WASTE; AT 24" AFF.; SINK) . NOTE: (3) LOCATIONS ON PLAN. QUIRED .. 1/2" COLD WATER; AT 72" AFF. EXTEND THROUGH WATER FILTER TO JBER) WATER INLET. REDUCE TO 3/8" AT CONNECTION. H REQUIRED .. 1/2" ICE MAKER DRAIN INDIRECT WASTE; EXTEND TO FLOOR SINK CH REQUIRED .. 3/4" BIN DRAIN INDIRECT WASTE; EXTEND TO FLOOR SINK BER BIN) QUIRED .. 1/2" HOT WATER & 1/2" COLD WATER; AT 16" AFF.; EXTEND TO NSE FAUCET) MOUNTED ON (3-COMPARTMENT SINK). UIRED .. 2" INDIRECT WASTE; MANIFOLD (3) SINK WASTES TO COMMON AND EXTEND TO FLOOR SINK. (3-COMPARTMENT QUIRED .. 1/2" COLD WATER; AT 16" AFF.; EXTEND TO CONNECTION ON ASH STATION) . QUIRED .. 1-1/4" DIRECT WASTE; AT 24" AFF.; ASH STATION) . UIRED .. 1/2" HOT WATER (110°F MIN); AT 12" AFF.; EXTEND TO HOT WATER CONNECTION ON ASHER) QUIRED .. 1/2" COLD WATER; AT 12" AFF.; EXTEND TO CONNECTIONS ON (DISHMACHINE DRAIN TEMPERING DEVICE). QUIRED .. 2" INDIRECT WASTE; EXTEND TO FLOOR SINK. NOTE: PLUMBING CONTRACTOR TO INTERPIPE DRAIN TEMPERING ONENTS. VERIFY GREASE TRAP. (DISHMACHINE DRAIN) CH REQUIRED .. 1/2" HOT WATER & 1/2" COLD WATER; AT 18" AFF. EXTEND TO FAUCET; CONTINUE ON TO (HOSE REEL) MOUNTED APPROX. 96" AFF. NOTE: PLUMBING CONTRACTOR TO INSTALL DNENTS AS INDICATED ON MANUFACTURER'S SPECIFICATION SHEET. CH REQUIRED .. 1/2" HOT WATER & 1/2" COLD WATER; AT 12" AFF.; EXTEND TO WASTE COLLECTOR) INLET. QUIRED .. 2" INDIRECT WASTE; EXTEND TO FLOOR SINK. WASTE COLLECTOR) QUIRED .. 3/4" NATURAL GAS; 70,000 BTU; AT 24" AFF.; CONNECTION AT GAS HEADER; AS HEADER NOTE THIS SHEET.NOTE: PLUMBING CONTRACTOR TO INSTALL QUICK DISCONNECT E & RESTRAINING CABLE PROVIDED WITH UNIT. (2-BURNER RANGE) QUIRED .. 3" WASTE; (STUB-UP); PLUMBING CONTRACTOR TO REFER TO MANUFACTURER'S SPECIFICATION SHEET FOR I-IN DATA. (FLOOR TROUGH) CH REQUIRED .. 1/2" HOT WATER & 1/2" COLD WATER; AT 16" AFF.; EXTEND TO LLON TILTING SKILLET) MOUNTED FAUCET. QUIRED .. 3/4" NATURAL GAS; 130,000 BTU'S; CONNECTION AT GAS HEADER; SEE GAS HEADER NOTE - THIS SHEET. (5.0" W.C 1.0" W.C MAX.). (30 GALLON TILTING SKILLET) QUIRED .. 3/4" NATURAL GAS; 120,000 BTU'S; CONNECTION AT GAS HEADER; SEE GAS HEADER NOTE - THIS SHEET. NOTE: ING CONTRACTOR TO INSTALL QUICK DISCONNECT DEVICE & RESTRAINING CABLE PROVIDED WITH UNIT. (DOUBLE CTION OVEN). QUIRED .. 3/4" FILTERED COLD WATER; AT 60" AFF.; EXTEND FROM WATER FILTRATION M TO (DOUBLE COMBI-OVEN) WATER INLET. CONNECTION TO WATER INJECTION INLET. QUIRED .. 3/4" COLD WATER; AT 16" AFF.; EXTEND FROM ROUGH-IN TO CONNECTION TO CLEANING, RECOIL HAND SHOWER NON-FILTERED. (DOUBLE COMBI-OVEN) UIRED .. 2" INDIRECT WASTE; EXTEND TO FLOOR SINK. I-OVEN). QUIRED .. 3/4" NATURAL GAS; 109,200 BTU'S; CONNECTION AT GAS HEADER; SEE GAS HEADER NOTE THIS SHEET. PLUMBING ACTOR TO INSTALL QUICK DISCONNECT DEVICE PROVIDED WITH UNIT. (COMBI-OVEN LOWER DECK) QUIRED .. 3/4" NATURAL GAS; 68,200 BTU'S; CONNECTION AT GAS HEADER; SEE GAS HEADER NOTE THIS SHEET. PLUMBING ACTOR TO INSTALL QUICK DISCONNECT DEVICE PROVIDED WITH UNIT. (COMBI-OVEN UPPER DECK) QUIRED .. 3/4" INDIRECT WASTE; EXTEND TO FLOOR DRAIN. FOOD SERVING COUNTER) QUIRED .. 3/4" INDIRECT WASTE; MANIFOLD FOOD WELL DRAINS TO COMMON; D TO FLOOR SINK. (HOT FOOD SERVING COUNTER) QUIRED .. 3/4" INDIRECT WASTE; MANIFOLD FOOD WELL DRAINS TO COMMON; D TO FLOOR SINK. (HOT FOOD SERVING COUNTER) QUIRED .. 3/4" INDIRECT WASTE; EXTEND TO FLOOR DRAIN. FOOD SERVING COUNTER)

