
CODED NOTES:


- 1 14x14 EA DUCT UP THROUGH ROOF. TRANSITION FOR CONNECTION TO
- (2) 36 X 36 EA DUCT UP THROUGH ROOF. TRANSITION FOR CONNECTION TO
- 3 18" DEEP AND 120" TALL INSULATED S.M. PLENUM. SLOPE BOTTOM OF PLENUM TO ONE SIDE AND INSTALL DRAIN PLUG AND STUB WITH SHUT OFF VALVE.
- 4 24 X 24 INTAKE DUCT FROM PLENUM. CENTERLINE OF INTAKE SHALL BE 4'-0" A.F.F. INSTALL LOW LEAK INSULATED MOD IN DUCT TO OPEN WHEN EF-14 IS IN OPERATION. COVER OPENING WITH BIRD SCREEN.
- 5 30 X 30 EA DUCT UP THROUGH ROOF. TRANSITION FOR CONNECTION TO GRV-2. 6 10"ø BOILER FLUE UP THROUGH ROOF. TERMINATE 36" ABOVE ROOF WITH RAIN CAP PER FLUE MANUFACTURER INSTALLATION DETAILS.
- 7 18" DEEP AND 96" TALL INSULATED S.M. PLENUM. SLOPE BOTTOM OF PLENUM TO ONE SIDE AND INSTALL DRAIN PLUG AND STUB WITH SHUT
- 8 30 X 42 EA DUCT UP THROUGH ROOF. TRANSITION FOR CONNECTION TO GRV-4.
- 9 26 X 26 EA DUCT UP THROUGH ROOF. TRANSITION FOR CONNECTION TO GRV-3.
- (10) 36 X 44 EA DUCT UP THROUGH ROOF. TRANSITION FOR CONNECTION TO GRV-5.
- 46 X 46 EA DUCT UP THROUGH ROOF. TRANSITION FOR CONNECTION TO GRV-6.
- 12) 14x14 EA DUCT UP THROUGH ROOF. TRANSITION FOR CONNECTION TO EF-19.
- 13) 14x14 EA DUCT UP THROUGH ROOF. TRANSITION FOR CONNECTION TO EF-20.
- 70 X 26 RA DUCT UP FROM FLOOR BELOW. SEE SHEET M-101-A FOR CONTINUATION. (15) 44 X 16 RA DUCT UP FROM FLOOR BELOW. SEE SHEET M-101-A FOR CONTINUATION.
- 70 X 20 RA DUCT UP FROM FLOOR BELOW. SEE SHEET M-101-A FOR CONTINUATION. 40 X 18 SA DUCT DOWN TO FLOOW BELOW. SEE SHEET M-101-A FOR CONTINUATION.
- (18) 50 X 22 SA DUCT DOWN TO FLOOR BELOW. SEE SHEET M-101-A FOR CONTINUATION.
- 24 X 24 INTAKE DUCT FROM PLENUM. CENTERLINE OF INTAKE SHALL BE 4'-0" A.F.F. INSTALL LOW LEAK INSULATED MOD IN DUCT TO OPEN WHENEF-19 AND EF-20 ARE IN OPERATION. COVER OPENING WITH BIRD


 \mathcal{L}

PROJECT NO

2203-1







PROJECT NO 2203-1 DRAWN BY MAR CHECKED BY ARB

ENLARGED MECHANICAL ROOMS - HVAC

SCALE: 1/4" = 1'-0" SHEET NO

M-103