

GENERAL FPB AND VAV SCHEDULE NOTES

CHILLER SCHEDULE NOTES:

1. BASIS OF DESIGN IS DAIKIN. REFER TO SPECIFICATIONS FOR ADDITIONAL MANUFACTURERS.
2. CHILLED WATER SYSTEM SHALL HAVE 30% PG WATER SOLUTION.
3. MAXIMUM SOUND PRESSURE LEVEL AT PROPERTY LINE SHALL BE 55 dBA. FURNISH WITH SOUND ATTENUATING PACKAGE AS REQUIRED TO ACHIEVE SOUND LEVELS.
4. CAPACITIES ARE BASED ON 95°F AMBIENT TEMPERATURE.

CHILLER SCHEDULE NOTES:

1. BASIS OF DESIGN IS DAIKIN. REFER TO SPECIFICATIONS FOR ADDITIONAL MANUFACTURERS.
2. CHILLED WATER SYSTEM SHALL HAVE 30% PG WATER SOLUTION.
3. MAXIMUM SOUND PRESSURE LEVEL AT PROPERTY LINE SHALL BE 55 dBA. FURNISH WITH SOUND ATTENUATING PACKAGE AS REQUIRED TO ACHIEVE SOUND LEVELS.
4. CAPACITIES ARE BASED ON 95°F AMBIENT TEMPERATURE.

1. ALL FAN POWERED VAV BOX AND SINGLE DUCT VAV BOXES REHEAT COIL SHALL BE PROVIDED WITH TWO-WAY CONTROL VALVE UNLESS NOTED OTHERWISE.
2. BASIS OF DESIGN IS TITUS. REFER TO SPECIFICATIONS FOR ADDITIONAL MANUFACTURERS.
3. ALL REHEAT COILS ARE SIZED WITH 30% PG WATER SOLUTION, 60°F PLEN TEMP, AND 50°F PRIMARY AIR TEMPRAYURE.