

North End Trunk Sewer

To serve Mill Street and contiguous area in the north end, a trunk line has been routed to follow the River Valley via Earl Street and crossing both river and canal near Commonwealth Street. This sewer will permit abandonment of the pumps in Mill Street. Lateral sewers in Earl Street and in James will serve the area bordering Neuman Creek, although it will be impracticable to more than drain ground floor levels at the extreme north end of Earl Street. At West Cherry Street a branch to the west has been planned and included as trunk sewer to beyond the railroad crossing. This latter subtrunk will serve the Cliff and Guy Street area.

Wooster Trunk

The Pigeon Run Road section will be afforded outlet through a main drain which follows the valley and creek, crossing West Main Street and Wooster Street. Branches to serve Marshall Hill Avenue and the area centering to Howells Avenue have been included. The crossing at Wooster Street will permit the Wooster Street sewer to be relieved of some of its present load and will to that extent alleviate sewerage difficulties along that street. This line constructed, it will be possible to abandon existing septic tanks near West Main Street.

Sippo Trunk

This main drain has been routed over East Tremont Street and through Sippo Park to the existing pumping installation at Front and Kendal Streets. This sewer will eliminate the pump and will also pick up the drainage from Sippo Heights, and, by means of a lateral in Tremont Street, will afford outlet to the Canton Road. At the north end has been provided a branch which can be extended to some future time to serve part of the area north from the Canton Road.

Wetmore Street Trunk

Most of the area south of Canton Road and East of the City limits will find outlet to Little Sippo Creek which parallels the Pennsylvania Railroad. Owing to the lack of present development in this area, the trunk sewer has been extended only to the Corporation line. It is planned, however, of size to enable extension as needed. By its construction to the corporation line accommodation will be afforded to residential and industrial area within the city. This trunk is the extension of the existing trunk in South Erie Street and that line has been made to serve as the outlet. Capacity is adequate. This sewer has been placed in Wetmore Street to Lincoln Street and thence along the Pennsylvania Railroad.

Columbia Heights Trunk

As before indicated, West Park is already sewered. The existing 10 inch pipe outlet is on a good grade and will serve so to accommodate the flow from Columbia Heights. As this section