


MASSILLON-OHIO

REPORT ON TRUNK SEWERS



QUANTITIES AND SEWER SIZES

NORTH END TRUNK

CHERRY STREET

Subdivision → Gallons per Acre Daily	AREAS AND SEWAGE						SEWERS	
	Leak @ 1,100	Indus. @ 12,000	Com. @ 20,000	Dom. @ 1,340	Total M.G.D.	Total M.G.D. C.F.S.	Size and Grade	Cap. and Vel.
AT	— NORTH END TRUNK —							
Mill and Lake	118 0.130			118 0.158	0.288 0.4	0.288 0.4	12" 0.4%	1.8 2.3
Mill and R.W.	25 0.028			25 0.034	0.062 0.5	0.350 0.5	12" 0.4%	1.8 2.3
Siphon								
James & R.W.	72 0.079	45 0.540		23 0.031	0.650 1.5	1.000 1.5	15" 0.22%	2.4 2.0
Coal Ext. & R.W.	42 0.046	38 0.460			0.506 2.3	1.506 2.3	18" 0.17%	3.6 2.0
Earl & Cherry	35 0.039	35 0.420			0.459 1.965	1.965 3.0		
FROM	— CHERRY STREET —							
West Cherry	97 0.107			92 0.123	0.230 0.4	0.230 0.4	8" 1.5%	1.1 3.2
East Cherry	44 0.048	10 0.120		23 0.031	0.209 0.3	0.209 0.3	8" 0.3%	0.5 1.5