

WOOSTER TRUNK

SIPPO TRUNK

Subdivision → Gallons per Acre Daily	AREAS AND SEWAGE						SEWERS	
	Leak. @ 1,100	Indus. @ 12,000	Com. @ 20,000	Dom. @ 1,340	Total M.G.D.	Total M.G.D. C.F.S.	Size and Grade	Cap. and Vel.
— WOOSTER TRUNK —								
FT	1/4 0.125			1/4 0.153	0.278 0.4	8" 1.63-2.57	1/2 33	1.5 4.2
West Main								
Howells Br.						12" 1.38%	3.3	4.2
Wooster	227 0.250			227 0.304	0.554 1.3	12" 3.34-1.68	5.2 6.6	3.3 5.0
W. & L. E. R.R.	1/6 0.127			1/6 0.155	1.114 1.7	12"-15" 0.91-0.29	27 35	2.8 2.3
1200 ft. W. Penn.	89 0.098			89 0.119	1.331 2.1	15" 0.36%	3.1	2.5
Penn. R.R.	53 0.058	20 0.240		26 0.035	1.664 2.6	18" 0.2%	3.9	2.2
Howells Br.	175 0.193			175 0.235	0.428 0.7	12"		
Marsh Hill Br.	66 0.073			66 0.088	0.161 0.3	12" 0.8%	2.5	3.2
— SIPPO TRUNK —								
Kendall & Front	90 0.099			90 0.120	0.219 0.3	12" 0.7%	2.4 3.0	
Dam Rd.	Allowance →				1.119 1.6	12" 1.75-0.7%	3.7-2.4 4.8-3.0	
Branch	Allowance →				2.019 3.1	18"-15" 0.28-8.37	4.6-1.5 2.6-1.2	
Sippo Hts.	84 0.093	✓		84 0.112	2.224 3.4	15"-18" 1.0-0.35	5.2-5.1 4.3-2.5	
Main St.	84 0.093			63 0.085	2.402 3.7	15" 1.0%	5.2 4.3	
Tremont St. Ext.	85 0.094			85 0.114	2.610 4.0	15"-18" 1.24-0.5-0.67	5.8-6.1 4.8-3.5	
Tremont & McLain	62 0.067	2 0.024		55 0.074	2.775 4.3	18" 0.68-0.6	7.0-6.4 4.0-3.6	