



WALL PIPE SCHEDULE
NTS

NOTE:
1. FOR WALLS 12 IN THICK OR GREATER PROVIDE TWO MODULAR MECHANICAL SEALS. FOR WALLS WITH AT LEAST ONE SIDE WET PROVIDE TWO MECHANICAL SEALS.

THIS DRAWING IS AN INSTRUMENT OF SERVICE OWNED BY CTI ENVIRONMENTAL, INC. WHICH SHALL BE DEEMED TO BE THE ORIGINAL DRAWING FOR ALL PURPOSES. THIS DRAWING SHALL NOT BE REPRODUCED, COPIED, OR TRANSMITTED IN ANY MANNER WITHOUT THE WRITTEN CONSENT OF CTI ENVIRONMENTAL, INC. ANY OTHER PURPOSE OR PROJECT WITHOUT PRIOR WRITTEN CONSENT OF CTI ENVIRONMENTAL, INC. ELECTRONIC COPIES OF THIS DRAWING ARE EXACT REPRODUCTIONS OF THE SEALED ORIGINAL DRAWING. THIS DRAWING IS THE PROPERTY OF CTI ENVIRONMENTAL, INC. AND THE SEALED ORIGINAL SHALL GOVERN.

DESIGNED BY		REVISIONS	
NO.	DESCRIPTIONS	DATE	BY
1	RECORD DRAWING	12/15	RWR
			WAD

ENVIRONMENTAL, INC.
ENGINEERS IN WATER AND EARTH SCIENCES
UNIONTOWN, OHIO



CITY OF MASSILLON, OHIO
WWTP UPGRADE 2000
WALL CASTING SCHEDULE

JOB NO. E9031
DATE 8/13/01
SCALE AS NOTED
SHEET C5

THESE RECORD DOCUMENTS HAVE BEEN PREPARED BASED ON INFORMATION PROVIDED BY OTHERS. CTI ENVIRONMENTAL HAS REVIEWED THE INFORMATION SUBMITTED AND BELIEVES IT REFLECTS THE WORK AS CONSTRUCTED. HOWEVER, ALL PERSONS SHALL VERIFY INFORMATION TAKEN FROM THIS DRAWING.