

[illegible]

2

XX CONDUIT & WIRE SCHEDULE
SEE EP383

NOTE: FOR ALL CABLES NOTED USE
(ROME CABLE XHHW-2 OR EQUIVALENT)
(USE BURNDY CO. COMPRESSION "HYDENT"
TYPE "YAXX-2LN" UL LISTED
CONNECTOR OR EQUIVALENT)

USE "NO-OX-ID" INHIBITOR COMPOUND
ON ALL PAD CONNECTIONS.

1. ITEMS FOR ADDITION

2. SEE DWG. P-29 FOR PLAN VIEW

DESIGNED BY		REVISIONS				
NO.	DESCRIPTIONS	DATE	BY	APP'D		
1	REMOVED AS PER CONSTRUCTION	9/22/08	TSS	R/L		
2	REVISED CONDUIT	5/5/03	LWC	R/L		
	CHECKED BY					
	STI/TSS					
	APPROVED BY					
	STI/R/L					

CFI ENVIRONMENTAL, INC.
ENGINEERS IN WATER AND EARTH SCIENCES
UNIONTOWN, OHIO

FE

CITY OF MASSILLON, OHIO
WWTP UPGRADE 2000
TRANSFORMER "F1", MCC-F1 LAYOUT
RETENTION BASIN ELECTRICAL ROOM

JOB NO. E9031
DATE 6/25/01
SCALE 1/2" = 12"
SHEET EP381-2