

PUMP SCHEDULE												
SYMBOL	MAKE	MODEL	TYPE	GPM	HEAD (FT. H ₂ O)	IMPELLER SIZE (IN. DIA.)	EFFIC. (%)	SUCTION SIZE (IN.)	DISCH. SIZE (IN.)	RPM	MOTOR H.P.	VOLTS/PHAS
P-8	B & G	SERIES 500000	BASE MOUNTED	180	85	8-1/4"	71	2-1/2"	2	1750	7-1/2	480/3



COMBINATION LOUVER

GRIT BUILDING HVAC PLAN
SCALE: $\frac{1}{4"} = 1'-0"$

DESIGNED BY		REVISIONS				
E.M.E.		NO.	DESCRIPTIONS	DATE	BY	APP'D
DRAWN BY			ADDED CRT BUILDING HVAC PLAN	7-3-00	DME	
E.M.E.						
CHECKED BY						
E.M.E.						
APPROVED BY						

GTI
ENVIRONMENTAL, INC.
ENGINEERS IN WATER AND EARTH SCIENCES
UNIONTOWN, OHIO

CITY OF MASSILLON, OHIO
WWTP UPGRADE 2000
SOLIDS HANDLING FACILITIES - HEATING & VENTILATING DETAILS

JOB NO.
E9031
DATE
08/13/01
SCALE
AS SHOWN
SHEET
M16