

7101

7102

7103

7104

7105

7106

7107

7108

7109

7110

7111

7112

7113

7114

7115

7116

7117

7118

7119

7120

7121

7122

7123

7124

7125

FROM DRAWING
DTSI-02040-070
LINE 7009

7002

7001N

7105H

7106

7107H

7108

7109H

7110

7111H

7112

7113H

7114

7115H

7116

7002

7001N

TO LINE 7127

ALLEN BRADLEY
1794-IA8
8 POINT DIGITAL
INPUT FLEX I/O MODULE
SLOT 0

16

34

0

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

33

51

TERTIARY FILTER #1:
LOCATED IN TERTIARY
FILTER/UV BUILDING

TERTIARY FILTER #2:
LOCATED IN TERTIARY
FILTER/UV BUILDING

UV DISINFECTION:
LOCATED IN TERTIARY
FILTER/UV BUILDING

TERTIARY FILTER #1
BRIDGE PREWASH
PUMP
RUNNING
(EL-3420)

TERTIARY FILTER #1
BRIDGE WASHWATER
PUMP
~~ALARM~~ **RUNNING**
(XAH-3422)

TERTIARY FILTER #2
PREWASH PUMP
RUNNING
(EL-3426)

TERTIARY FILTER #2
WASHWATER PUMP
~~ALARM~~ **RUNNING**
(XAH-3428)

UV RUN INPUT
(EL-648)

UV ALARM INPUT
(LAL-650)

SPARE

SPARE

