

DATE	SYM	REVISION RECORD	AUTH	DR	CK
5/12/03	A	FOR APPROVAL	CUST	RTR	OG

L13 FIELD

PLC PANEL NODE 10



TAG: LE-/LT-L13

MANUFACTURER: DREXELBROOK
MODEL: 705-0200/405-2400
POWER: 120VAC/60Hz
ENCLOSURE: NEMA 4X
CALIBRATION RANGE: 0-10 FEET


05/19/03 13:01

WIRE LUGS - NO ☒ YES ☐ RING ☐ LOCKING SPADE ☐

INSULATION: NYLON ☐ PVC ☒

WIRE SPECIFICATIONS:

USAGE	SIZE	COLOR	INSULATION
AC PANEL POWER	AWG #12	BLK	THW/THHN
AC PANEL NEUTRAL	AWG #12	WHT	THW/THHN
AC PANEL GROUND	AWG #12	GRN	THW/THHN
AC CONTROL POWER	AWG #14	RED	THW/THHN
AC CONTROL NEUTRAL	AWG #14	WHT	THW/THHN
AC FOREIGN	AWG #14	YELLOW	THW/THHN
DC POWER	AWG #16	BLUE	THW/THHN
DC CONTROL	AWG #16	BLUE	THW/THHN
SIGNAL/INSTRUMENTS	AWG #16	2 CONDUCTOR SHLD	THW/THHN



KOKOSING
CONSTRUCTION CO.
P.O. #
DUBLIN TECHNICAL
SYSTEMS INC.
PROJECT # 02040

TOLERANCES	DRAWN BY	APPROVED BY
DECIMAL ± .03	RTR	JK
FRACTIONAL ± 1/32"		
ANGULAR ± 1°		
DATE 9/18/02	DRAWING NUMBER DTSI - 02040 - 265	

DUBLIN TECHNICAL SYSTEMS, INC.

CITY OF WASSILON, OHIO
REGIONAL WASTEWATER TREATMENT
PLANT - UPGRADE 2000
PROJECT NO. E9031

TITLE
NIPW WET WELL LEVEL, L13