









STAINLESS STEEL CORBELS MAY BE PROVIDED BY THE COVER MANUFACTURER AS AN ALTERNATE TO THE CONC CORBELS. IF S. STL. ARE USED, THE MANUFACTURER SHALL PROVIDE APPROPRIATE CALCULATIONS PREPARED BY AN OHIO REGISTERED ENGINEER RELATED TO THE DESIGN OF THE CORBELS INDICATING THEIR SUITABILITY ALL CONDITIONS OF OPERATION INCLUDING COVER SUPPORT IN AN EMPTY TANK WITH LIVE LOADS APPLIED.

CTI ENVIRONMENTAL, INC.
ENGINEERS IN WATER AND EARTH SCIENCES
UNIONTOWN, OHIO

CITY OF MASSILLON, OHIO
WWTP UPGRADE 2000
ANAEROBIC DIGESTER MODIFICATIONS – SECTIONS AND DETAILS

JOB NO.
E9031
DATE
08/13/01
SCALE
AS NOTED
SHEET
SP36