

South

**FOLLOWING DATA TO BE ANSWERED BY INSPECTOR
AND SIGNED WHEN RETURNED**

No. 3876

Date Inspected 5/14/37 I so how and location from
first manhole down stream

House No. 725 Distance from first manhole


Size of pipe used 6" down stream to ditch at
curb line and depth

Was lateral at curb? yes

Name of Contractor Smart

Was attached to main

Show by diagram relation of lateral to wall of building served.



*Sewer lateral ok for distance
but was under curb not at
back side of walk*

Wake Ave N.E.

Signed Frank B. Jones

Inspector for City

Filed at Engineer's Office

5/14/37

Remarks:

40' 0" of 12" pipe
North

7/4

RETURNING DATA TO BE ANSWERED BY INSPECTOR
AND SIGNED WHEN RETURNED

OFFICE OF THE DIRECTOR OF PUBLIC SERVICE

No 3876

PERMIT TO TAP SEWER

5/11/19
Massillon, O.,

Received of

fee of \$ 2.00

for which permission is granted

to tap

sewer, on the

of

Ave., Type of Street

St.,

the premises being Lot No.

House No.

Work to be done in accordance with Ordinance No. 2323, duly passed by the City Council, and Rt
the Department of Public Service.

Name of Contractor

NOTE. This permit covers work outside of building only. Any work inside walls of bu
is subject to Massillon Board of Health Regulations.