

New Connection.

FOLLOWING DATA TO BE ANSWERED BY INSPECTOR
AND SIGNED WHEN RETURNED

Nº 4333

DATE INSPECTED 6-11-42

IF SO HOW AND LOCATION FROM
FIRST MANHOLE DOWN STREAM

HOUSE NO. 901


SIZE OF PIPE USED 4" up DISTANCE FROM FIRST MANHOLE
DOWN STREAM TO DITCH AT CURB LINE AND DEPTH 74 ft. 8' Deep

WAS LATERAL AT CURB? Yes.

NAME OF CONTRACTOR Molson

WAS ATTACHED TO MAIN

SHOW BY DIAGRAM RELATION OF LATERAL TO WALL OF BUILDING SERVED.



4" Tile
8' Depth at curb lateral,
74' Manhole up stream to lateral at curb.
12' 6" Lateral to house line at curb,
Soil: Clay
50' Lateral curb to house.
6' 6" Lateral depth at house.
2' 6" Lateral to house corner.
Water line in same ditch.

SIGNED W. Hensrich
INSPECTOR FOR CITY

FILED AT ENGINEER'S OFFICE OK GCW-6-12-

REMARKS:

New Connection

NO. 4333

OFFICE OF THE DIRECTOR OF PUBLIC SERVICE

PERMIT TO TAP SEWER

MASSILLON, OHIO, 6/1

RECEIVED OF

FEE OF \$ 2.00

FOR WHICH PERMISSION IS GRANTED

TO TAP

SEWER, ON THE

OF

AVE. TYPE OF STREET

ST.

THE PREMISES BEING LOT No.

House No.

WORK TO BE DONE IN ACCORDANCE WITH ORDINANCE No. 2323, DULY PASSED BY THE CITY COUNCIL
RULES OF THE DEPARTMENT OF PUBLIC SERVICE.

NAME OF CONTRACTOR

Note. This permit covers work outside of building only. Any work inside of building is subject to Massillon Board of Health Regulations.