

New Connection.
Nº 4351

FOLLOWING DATA TO BE ANSWERED BY INSPECTOR
AND SIGNED WHEN RETURNED

DATE INSPECTED 8-14-42

IF SO HOW AND LOCATION FROM
FIRST MANHOLE DOWN STREAM

33' House line to + on curb to

HOUSE NO. 828 17th St. N.E.

7' Depth lateral at curb.

SIZE OF PIPE USED 6"

DISTANCE FROM FIRST MANHOLE
DOWN STREAM TO DITCH AT
CURB LINE AND DEPTH

109' Lateral to Manhole down


WAS LATERAL AT CURB? Yes.

NAME OF CONTRACTOR

Melson

WAS ATTACHED TO MAIN

SHOW BY DIAGRAM RELATION OF LATERAL TO WALL OF BUILDING SERVED.



+ on curb.
House facing street
Soil: Clay.
6" Tile.

109' Lateral to Manhole down stream.

7' Lateral depth at curb

33' House line to + on curb

6' Lateral depth at House connection.

55' Lateral from curb to house

15' House connection to n.w. corner of house. GCW-91

SIGNED H. Heinrich
INSPECTOR FOR CITY

FILED AT ENGINEER'S OFFICE

REMARKS:

New Connection

OFFICE OF THE DIRECTOR OF PUBLIC SERVICE

NO 4351

PERMIT TO TAP SEWER

MASSILLON, OHIO, 8/7 1922

RECEIVED OF *James M. ...*

FEE OF \$ 2.00

FOR WHICH PERMISSION IS GRANTED *James M. ...*

TO TAP *James M. ...*

SEWER, ON THE *East*

OF *17th NE*

AVE., TYPE OF STREET *Paved*
ST.,

THE PREMISES BEING LOT No. *8006*

House No. *828*

WORK TO BE DONE IN ACCORDANCE WITH ORDINANCE No. 2323, DULY PASSED BY THE CITY COUNCIL
RULES OF THE DEPARTMENT OF PUBLIC SERVICE.

NAME OF CONTRACTOR *J. M. ...*

Note. This permit covers work outside of building only. Any work inside
of building is subject to Massillon Board of Health Regulations.