

Nº 4719

FOLLOWING DATA TO BE ANSWERED BY INSPECTOR
AND SIGNED WHEN RETURNED

DATE INSPECTED 4-19-46

IF SO HOW AND LOCATION FROM
FIRST MANHOLE DOWN STREAM _____

HOUSE NO. 430

SIZE OF PIPE USED 4"

DISTANCE FROM FIRST MANHOLE
DOWN STREAM TO DITCH AT
CURB LINE AND DEPTH _____

WAS LATERAL AT CURB? _____

WAS ATTACHED TO MAIN _____

NAME OF CONTRACTOR Remley

SHOW BY DIAGRAM RELATION OF LATERAL TO WALL OF BUILDING SERVED.

Relay job. Lateral dug up between curb and wall only. One full length of pipe, 1" y for cleanout and 1 short length of pipe used. Calktite joint compound u solid mass roots taken out of pipe that was relaid. als cut solid mass of roots from section of pipe about 6' out in street from curb. Dunham ran root-cutter thr

SIGNED R. F. Dunham

INSPECTOR FOR CITY

FILED AT ENGINEER'S OFFICE _____

REMARKS:

section from curb to main line. 4" Cleanout stack run to ground level between curb and walk.

OFFICE OF THE DIRECTOR OF PUBLIC SERVICE

Nº 4719

PERMIT TO TAP SEWER

MASSILLON, OHIO, 4/20RECEIVED OF R. RemleyFEE OF \$ 2.FOR WHICH PERMISSION IS GRANTED McMagnerTO TAP SewerSEWER, ON THE EOF 6th S.W.AVE.,
ST.TYPE OF STREET PavedTHE PREMISES BEING LOT NO. 1714HOUSE NO. 430

WORK TO BE DONE IN ACCORDANCE WITH ORDINANCE NO. 2323, DULY PASSED BY THE CITY COUNCIL
RULES OF THE DEPARTMENT OF PUBLIC SERVICE.

NAME OF CONTRACTOR R. Remley

Note. This permit covers work outside of building only. Any work
walls of building is subject to Massillon Board of Health Regulations.