

N^o 10473

**FOLLOWING DATA TO BE ANSWERED BY INSPECTOR
AND SIGNED WHEN RETURNED**

DATE INSPECTED 7/19/95

IF SO HOW AND LOCATION FROM
FIRST MANHOLE DOWN STREAM

MH in culdesac

HOUSE NO. 2500

SIZE OF PIPE USED 6" plastic


DISTANCE FROM FIRST MANHOLE
DOWN STREAM TO DITCH AT
CURB LINE AND DEPTH

WAS LATERAL AT CURB? YES

WAS ATTACHED TO MAIN YES

NAME OF CONTRACTOR TISDOT

SHOW BY DIAGRAM RELATION OF LATERAL TO WALL OF BUILDING SERVED.



SIGNED

[Signature]
Inspector for City

FILED AT ENGINEER'S OFFICE

REMARKS

Nº 10473

OFFICE OF THE DIRECTOR OF PUBLIC SE

PERMIT TO TAP SEWER

MASSILLON, OHIO,

RECEIVED OF

FEE OF

FOR WHICH PERMISSION IS GRANTED

TO TAP

SEWER ON THE

OF

AVE.

ST. TYPE OF STREET

THE PREMISES BEING LOT NO.

HOUSE NO.

WORK TO BE DONE IN ACCORDANCE WITH
OF THE DEPARTMENT OF PUBLIC SERVICE.

Section 29
Codified Ordinances

DULY PASSED BY THE CITY COUNCIL, AND

NAME OF CONTRACTOR

**Note: This permit covers work outside of building only. Any work
walls of building is subject to Massillon Board of Health Regulations.**