



CITY OF MASSILLON, OHIO

151 LINCOLN WAY EAST
MUNICIPAL GOVERNMENT ANNEX
CITY ADMINISTRATION BUILDING
MASSILLON, OHIO 44646
PHONE 330-830-1722 FAX 330-830-1786

PERMIT DATE:

1/20/2009

PERMIT NO.

3957

PERMIT TO TAP SANITARY SEWER

This permit is issued subject to the latest Codified Ordinances of the City of Massillon, OH. The City Engineer to be notified 24 hours in advance of start of work (330) 830-1722. All permits issued under this ordinance are void after 120 days from date of issuance.

RECEIVED OF:

CONTRACTOR INFORMATION

CONTRACTOR: ABC DRAIN & PLUMBING
CONTACT: ROBERT WILLIAMS
ADDRESS:
CITY:
STATE:
ZIP:
PHONE: (330) 773-5002
FAX:
SURETY: OHIO FARMERS

PERMIT TYPE Repair

SITE INFORMATION

OWNER'S NAME:
FULL STREET ADDRESS: 1327 OAK AVE SE
CITY LOT NUMBER OL 59, OL 3
PURPOSE OF CUT: REPAIR
ZONING CLASS:
STREET SIDE:

PHONE OTHER:

NOTE: This permit covers work outside of the building ONLY. Any work inside walls of the building is subject to the Massillon Board of Health Regulations.

SANITARY SEWER CONNECTION:

USE: Residential

DATE INSPECTED 1/16/2009

located on the SOUTH side of
OAK AVE SE between
INDEPENDENCE and
16TH ST SE

Direction from downstream Manhole: EAST

Distance from downstream Manhole: 162'

Connection Length: 15.00 (FEET)

Connection Depth: 9 (FEET)

Size of Sewer Pipe: 6 (INCHES)


Pipe Material: PVC

INSPECTORS NAME: JEFF KING

COMMENTS: Replaced 15' of 6" clay with 15' of 6" pvc. Added cleanout. See old permit # 5578 for original

SKETCH:

DRAWING #: #3957



INSPECTION REQUEST:

SANITARY SEWER PERMIT FEE: \$50.00

CAPACITY FEE: \$0.00

TOTAL COST: \$50.00

TWO WORKING DAYS BEFORE YOU DIG
Ohio Utilities Protection Service
Call 1-800-362-2764 Toll Free....
Non-Members must be called directly.

AUTHORIZED BY: DIRECTOR OF PUBLIC SAFETY AND SERVICE

ISSUED BY: Linda Mikutel

Nº 5578

FOLLOWING DATA TO BE ANSWERED BY INSPECTOR
AND SIGNED WHEN RETURNED.

DATE INSPECTED 2-6-51

IF SO HOW AND LOCATION FROM
FIRST MANHOLE DOWN STREAM _____

HOUSE NO. 1327

SIZE OF PIPE USED 6"

DISTANCE FROM FIRST MANHOLE
DOWN STREAM TO DITCH AT
CURB LINE AND DEPTH 162"


WAS LATERAL AT CURB? _____

WAS ATTACHED TO MAIN _____

NAME OF CONTRACTOR Diana

SHOW BY DIAGRAM RELATION OF LATERAL TO WALL OF BUILDING SERVED.

OAK AVE S.E.



74-1/2"



162

SIGNED

John Elmer
INSPECTOR FOR CITY

FILED AT ENGINEER'S OFFICE

2-26-51

REMARKS: _____