



CITY OF MASSILLON, OHIO
151 LINCOLN WAY EAST
MUNICIPAL GOVERNMENT ANNEX
CITY ADMINISTRATION BUILDING
MASSILLON, OHIO 44646
PHONE 330-830-1722 FAX 330-830-1786

PERMIT DATE:

1/11/2012

PERMIT NO.

4165

PERMIT TO TAP SANITARY SEWER

This permit is issued subject to the latest Codified Ordinances of the City of Massillon, OH. The City Engineer to be notified 24 hours in advance of start of work (330) 830-1722. All permits issued under this ordinance are void after 120 days from date of issuance.

RECEIVED OF:

PERMIT TYPE Repair

CONTRACTOR INFORMATION

CONTRACTOR: MIRACLE PLUMBING

CONTACT: _____

ADDRESS: _____

CITY: _____

STATE: _____

ZIP: _____

PHONE: (330) 477-2402

FAX: _____

SURETY: _____

SITE INFORMATION

OWNER'S NAME: MCMILLAN

FULL STREET ADDRESS: 160 25TH ST NW

CITY LOT NUMBER 13091

PURPOSE OF CUT: REPAIR

ZONING CLASS: _____

STREET SIDE: _____

PHONE OTHER: _____

NOTE: This permit covers work outside of the building ONLY. Any work inside walls of the building is subject to the Massillon Board of Health Regulations.

SANITARY SEWER CONNECTION:

USE: Residential

DATE INSPECTED 1/23/12

located on the East side of

25th St NW between

Chauncy Ave and

Stanton Ave

Direction from downstream Manhole: South

Distance from downstream Manhole: 37'

Connection Length: 40 (FEET)

Connection Depth: 8 (FEET)

Size of Sewer Pipe: 6" (INCHES)

Pipe Material: PVC

INSPECTORS NAME: Jason Haines

COMMENTS: Replaced 40' of clay lateral w/PVC
Dug by Malavite

SKETCH: DRAWING #: _____

INSPECTION REQUEST: @ 2:00
1/17/2012

SANITARY SEWER PERMIT FEE: \$50.00

CAPACITY FEE: \$0.00

TOTAL COST: \$50.00

TWO WORKING DAYS BEFORE YOU DIG
Ohio Utilities Protection Service
Call 1-800-362-2764 Toll Free....
Non-Members must be called directly.

AUTHORIZED BY: DIRECTOR OF PUBLIC SAFETY AND SERVICE

ISSUED BY: Linda Mikutel

North

Chauncy Ave. NW

Ex Manhole

← 37' from manhole →

8" main sewer

25th St. NW

12" water clay layer

6" gas

storm basin

Ferenco coupling clay to PVC

40' of new 6" PVC

8' deep

Tree

10' behind edge of asphalt

Edge of asphalt

4" Plastic

Gas Line

#160 25th St NW

7' from corner

Ferenco Coupling clay to PVC at house footer - under 6" clay footer drain -